

FORT MYERS HARBOR, FL, USA

WMO: 997346

Lat: 26.6471N

Lon: 81.8709W

Elev: 6

StdP: 101.25

Time Zone: -5.00 (NAE)

Period: 05-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) 6.7	(c) 8.8	(d) N/A	(e) N/A	(f) N/A	(g) N/A	(h) N/A	(i) N/A	(j) 10.5	(k) 16.3	(l) 8.4	(m) 15.6	(n) 3.7	(o) 20	(p) 0.322

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a) 8	(b) 7.1	(c) 33.3	(d) N/A	(e) 32.6	(f) N/A	(g) 32.0	(h) N/A	(i) N/A	(j) N/A	(k) N/A	(l) N/A	(m) N/A	(n) N/A	(o) 2.3	(p) 280

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a) N/A	(b) N/A	(c) N/A	(d) N/A	(e) N/A	(f) N/A	(g) N/A	(h) N/A	(i) N/A	(j) N/A	(k) N/A	(l) N/A	(m) N/A	(n) N/A	(o) N/A	(p) N/A

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a) 7.9	(b) 6.6	(c) 5.6	(e) N/A	(f) N/A	(g) N/A	(h) N/A	(i) N/A	(j) N/A	(k) N/A	(l) N/A	(m) N/A	(n) N/A	(o) N/A	(p) N/A		
			DB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
			WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	24.0	17.8	19.8	20.9	23.7	25.8	27.6	28.3	28.6	27.7	25.9	21.6	20.0		
	DBStd	4.51	4.14	3.93	3.03	2.06	1.50	1.33	1.14	1.01	1.14	2.44	3.18	3.84		
	HDD10.0	4	3	1	0	0	0	0	0	0	0	0	0	1		
	HDD18.3	146	60	30	14	1	0	0	0	0	0	0	10	30		
	CDD10.0	5109	246	274	338	411	491	527	566	576	531	492	348	309		
	CDD18.3	2208	43	71	94	161	232	277	308	318	281	235	108	81		
	CDH23.3	19173	146	305	454	1098	1978	2813	3274	3514	2709	2010	533	339		
	CDH26.7	6167	8	28	41	223	598	1047	1256	1367	912	572	79	36		
(14) Wind	WSAvg	2.7	3.0	2.8	3.2	2.9	2.8	2.5	2.2	2.3	2.5	2.9	3.0	2.7		
(15) Precipitation	PrecAvg	1390	51	54	72	42	86	249	224	248	212	73	45	41		
	PrecMax	1901	202	275	472	144	262	510	369	427	437	280	205	133		
	PrecMin	834	0	0	1	0	5	50	58	101	49	1	0	0		
	PrecStd	255	47	46	79	39	64	110	78	89	94	65	48	38		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	27.8	28.9	29.0	30.8	32.7	33.9	34.1	34.2	33.2	32.1	30.6	29.0		
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
	2%	DB	26.3	27.5	27.8	29.9	31.5	32.7	33.0	33.3	32.3	31.2	28.9	27.7		
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
	5%	DB	25.1	26.5	26.9	29.0	30.6	31.9	32.3	32.5	31.6	30.5	27.6	26.5		
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	DB	23.7	25.4	26.0	28.0	29.7	31.0	31.5	31.7	30.8	29.7	26.5	25.4		
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
	2%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
	5%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
(35) Mean Daily Temperature Range	5% DB	MDBR	9.0	8.7	8.8	8.3	7.9	7.2	7.2	7.1	6.8	6.9	8.2	8.4		
		MCDBR	9.2	8.6	9.0	9.0	9.1	8.3	8.0	7.9	7.5	7.2	8.1	8.5		
	5% WB	MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
		MCDBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
(40) Clear-Sky Solar Irradiance	taub		0.349	0.364	0.377	0.392	0.419	0.444	0.460	0.449	0.421	0.400	0.362	0.353		
	taud		2.513	2.481	2.430	2.368	2.346	2.353	2.300	2.360	2.419	2.447	2.495	2.528		
	Ebn at Noon		901	913	917	907	876	849	834	844	862	864	879	881		
	Edh at Noon		93	103	114	124	127	126	132	124	114	105	94	88		
(44) All-Sky Solar Radiation	RadAvg		3.71	4.53	5.52	6.42	6.60	5.94	5.83	5.63	5.08	4.74	4.00	3.42		
	RadStd		0.26	0.27	0.35	0.27	0.44	0.52	0.39	0.28	0.32	0.27	0.21	0.24		

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (34 neighbors)		+0.41	+0.87	N/A	N/A	N/A	N/A	-1	-25	+146	+111

Nomenclature: See separate page