

KEY WEST HARBOR, FL, USA

WMO: 997348

Lat: 24.5558N

Lon: 81.8078W

Elev: 7

StdP: 101.24

Time Zone: -5.00 (NAE)

Period: 05-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) 13.1	(c) 14.7	(d) N/A	(e) N/A	(f) N/A	(g) N/A	(h) N/A	(i) N/A	(j) 11.5	(k) 17.8	(l) 10.6	(m) 18.1	(n) 3.4	(o) 10	(p) N/A

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a) 8	(b) 5.1	(c) 33.5	(d) N/A	(e) 33.0	(f) N/A	(g) 32.6	(h) N/A	(i) N/A	(j) N/A	(k) N/A	(l) N/A	(m) N/A	(n) N/A	(o) 0.5	(p) 160

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a) N/A	(b) N/A	(c) N/A	(d) N/A	(e) N/A	(f) N/A	(g) N/A	(h) N/A	(i) N/A	(j) N/A	(k) N/A	(l) N/A	(m) N/A	(n) N/A	(o) N/A	(p) N/A

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a) 8.0	(b) 6.5	(c) 5.3	(e) 10.8	(f) 34.1	(g) 2.1	(h) 0.3	(i) 9.3	(j) 34.3	(k) 8.1	(l) 34.5	(m) 6.9	(n) 34.7	(o) 5.4	(p) 34.9		
			DB													
			WB													

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	26.0	21.3	22.0	23.3	25.6	27.4	29.1	29.8	30.0	29.0	27.5	24.1	23.0		
	DBStd	3.75	3.29	3.27	2.70	1.88	1.42	1.36	1.13	1.06	1.20	1.67	2.43	2.98		
	HDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0		
	HDD18.3	32	14	9	3	0	0	0	0	0	0	0	1	5		
	CDD10.0	5841	349	337	412	467	538	572	613	618	569	542	422	402		
	CDD18.3	2831	104	112	157	217	280	322	355	360	319	284	172	148		
	CDH23.3	28432	341	496	784	1678	2896	4053	4714	4854	3988	2986	958	684		
	CDH26.7	10433	16	44	81	341	833	1731	2272	2402	1663	860	126	64		
(14) Wind	WSAvg	1.3	2.5	1.8	1.5	1.8	0.9	0.7	0.7	0.8	0.9	1.4	1.3	1.5		
(15) Precipitation	PrecAvg	1015	50	41	44	48	86	125	89	138	158	122	62	51		
	PrecMax	1598	448	124	246	269	328	366	297	343	469	548	703	284		
	PrecMin	508	0	3	0	0	14	8	11	57	43	19	0	1		
	PrecStd	236	76	30	44	47	72	88	55	68	77	99	106	51		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	28.0	29.0	29.1	30.7	31.9	33.6	34.0	34.0	33.5	32.3	30.7	29.1		
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
	2%	DB	27.2	27.9	28.4	30.0	31.4	32.9	33.4	33.4	32.8	31.4	29.2	28.3		
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
	5%	DB	26.4	27.1	27.7	29.4	30.7	32.4	32.9	32.9	32.1	30.7	28.2	27.6		
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
	2%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
	5%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
(35) Mean Daily Temperature Range	5% DB	MDBR	4.6	4.8	4.8	4.7	4.7	4.9	5.1	5.1	4.9	4.2	4.0	4.2		
		MCDBR	5.1	5.1	5.2	5.2	5.3	5.5	5.4	5.6	5.5	5.0	4.8	4.6		
	5% WB	MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
		MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
(40) Clear-Sky Solar Irradiance	taub	0.363	0.376	0.383	0.400	0.424	0.439	0.450	0.433	0.417	0.409	0.377	0.371			
	taud	2.549	2.515	2.476	2.407	2.394	2.421	2.394	2.463	2.478	2.485	2.522	2.549			
	Ebn at Noon	897	908	916	901	873	853	844	861	871	863	875	874			
	Edh at Noon	92	101	110	120	122	118	121	112	109	103	94	89			
(44) All-Sky Solar Radiation	RadAvg	3.89	4.87	5.99	6.75	6.84	6.36	6.48	6.15	5.40	4.85	4.21	3.70			
	RadStd	0.31	0.36	0.26	0.29	0.58	0.50	0.31	0.22	0.29	0.33	0.23	0.32			

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
Station Only		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (16 neighbors)		+0.34	+0.84	N/A	N/A	N/A	N/A	N/A	-15	+109	+90

Nomenclature: See separate page