

ST PETERSBURG, FL, USA

WMO: 997353

Lat: 27.750N

Lon: 82.620W

Elev: 33

StdP: 14.68

Time Zone: -5.00 (NAE)

Period: 05-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	44.3	47.7	N/A	N/A	N/A	N/A	N/A	N/A	22.8	65.8	20.0	65.4	8.2	0	0.353

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	9.2	90.7	N/A	89.4	N/A	88.4	N/A	N/A	N/A	N/A	N/A	N/A	N/A	5.4	60

Dehumidification DP/MCDB and HR

0.4%			1%			2%			0.4%		1%		2%		Extreme Max WB
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		DB	WB
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
21.5	18.0	15.7	38.2	93.7	4.1	1.5	35.2	94.7	32.8	95.6	30.5	96.5	27.6	97.5		
			N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
Temperatures, Degree-Days and Degree-Hours	DBAvg	74.2	61.7	65.2	68.3	73.4	78.4	81.8	82.9	83.9	82.1	77.3	68.8	65.7	
	DBStd	8.93	6.81	6.49	5.50	4.21	3.19	2.36	2.11	1.93	2.23	4.60	5.71	6.81	
	HDD50	11	6	2	0	0	0	0	0	0	0	0	0	3	
	HDD65	361	140	71	35	5	0	0	0	0	0	2	31	77	
	CDD50	8834	370	426	566	702	880	955	1020	1050	964	846	565	490	
	CDD65	3709	39	75	136	257	415	505	555	585	514	383	146	99	
	CDH74	32721	41	153	321	1252	3235	5422	6349	7063	5394	2894	419	178	
	CDH80	9855	0	10	10	142	738	1718	2205	2755	1657	588	30	2	
	WSAvg	7.1	6.7	6.9	8.0	8.3	8.0	7.9	6.9	6.7	6.7	6.8	6.5	6.2	
	PrecAvg	50.2	2.5	2.7	3.0	2.4	2.5	6.9	8.4	8.6	6.7	2.6	1.5	2.4	
Precipitation	PrecMax	69.6	5.5	11.6	9.1	8.6	8.9	14.1	15.2	13.6	13.6	6.6	4.8	15.6	
	PrecMin	38.6	0.4	0.4	0.3	0.2	0.2	3.1	4.0	4.6	1.7	0.4	0.2	0.5	
	PrecStd	8.0	1.5	2.3	2.4	1.7	2.1	3.0	2.6	2.8	3.1	1.4	1.1	3.8	
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	77.8	81.9	81.5	85.2	90.4	91.9	91.5	92.6	91.5	88.8	83.4	79.8	
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
	2%	DB	75.3	78.1	79.2	83.2	87.8	89.4	89.8	90.7	89.4	86.6	80.5	77.9	
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
	5%	DB	73.1	75.6	77.4	81.8	85.8	87.9	88.4	89.2	88.0	84.9	78.4	76.2	
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
	10%	DB	71.0	73.6	75.8	80.0	84.0	86.6	87.1	88.1	86.7	83.4	76.8	74.2	
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
	0.4%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
	2%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
	5%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
	10%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
	5% DB	MDBR	12.7	12.2	11.7	11.2	10.6	9.5	9.0	9.2	9.7	10.1	11.6	11.6	
		MCDBR	12.7	12.5	12.3	12.6	12.9	11.2	10.4	10.3	10.8	10.7	11.5	11.3	
Mean Daily Temperature Range	5% WB	MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
		MCDWR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
	5% WB	MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
		MCDWR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
Clear-Sky Solar Irradiance	taub		0.343	0.356	0.369	0.393	0.423	0.447	0.471	0.451	0.422	0.390	0.355	0.344	
	taud		2.529	2.499	2.448	2.341	2.316	2.330	2.269	2.337	2.383	2.461	2.505	2.550	
	Ebn at Noon		287	291	293	287	277	268	261	267	272	276	280	281	
	Edh at Noon		29	32	35	41	42	41	43	40	37	33	29	27	
All-Sky Solar Radiation	RadAvg		1130	1367	1727	2070	2195	1988	1885	1810	1644	1518	1236	1046	
	RadStd		82	89	142	98	117	160	113	113	109	93	65	86	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (32 neighbors)	+0.77	+1.44	N/A	N/A	N/A	N/A	-5	-81	+311	+218

Nomenclature: See separate page