

CAPE CANAVERAL TRIDENT PIER, FL, USA

WMO: 997354

Lat: 28.4160N

Lon: 80.5930W

Elev: 33

StdP: 14.68

Time Zone: -5.00 (NAE)

Period: 05-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) 42.9	(c) 46.8	(d) N/A	(e) N/A	(f) N/A	(g) N/A	(h) N/A	(i) N/A	(j) 22.3	(k) 58.3	(l) 20.2	(m) 60.0	(n) 10.0	(o) 310	(p) 0.356

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a) 8	(b) 10.5	(c) 89.4	(d) N/A	(e) 88.4	(f) N/A	(g) 87.4	(h) N/A	(i) N/A	(j) N/A	(k) N/A	(l) N/A	(m) N/A	(n) N/A	(o) 7.6	(p) 130

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a) N/A	(b) N/A	(c) N/A	(d) N/A	(e) N/A	(f) N/A	(g) N/A	(h) N/A	(i) N/A	(j) N/A	(k) N/A	(l) N/A	(m) N/A	(n) N/A	(o) N/A	(p) N/A

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a) 19.3	(b) 17.1	(c) 15.5	(e) 39.1	(f) 92.6	(g) 4.1	(h) 1.7	(i) 36.1	(j) 93.8	(k) 33.7	(l) 94.8	(m) 31.5	(n) 95.7	(o) 28.5	(p) 96.9		
			DB													
			WB													

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	73.7	62.2	65.2	67.1	72.9	77.0	80.7	82.0	82.6	81.3	77.0	69.5	66.6
	DBStd	8.57	7.49	7.13	6.03	4.05	2.99	2.25	2.02	1.76	1.99	4.53	5.75	7.04
	HDD50	16	10	3	0	0	0	0	0	0	0	0	0	3
	HDD65	373	141	78	52	3	0	0	0	0	0	3	27	69
	CDD50	8671	387	428	529	687	837	921	992	1010	938	838	586	518
	CDD65	3552	53	82	116	240	372	471	527	545	488	376	163	119
	CDH74	29084	68	172	279	1049	2503	4567	5654	5982	5026	2993	552	239
CDH80	7621	1	10	14	88	387	1244	1830	1996	1479	538	31	3	
Wind	WSAvg	7.6	8.1	7.5	8.4	8.4	8.1	7.3	6.5	6.7	7.1	7.9	8.0	7.5
Precipitation	PrecAvg	52.1	2.3	2.1	3.0	2.4	3.5	7.1	6.7	7.5	6.9	5.1	2.1	2.3
	PrecMax	71.0	5.6	7.1	12.2	5.6	11.9	14.3	11.0	20.5	13.6	12.2	8.1	9.3
	PrecMin	37.8	0.0	0.1	0.0	0.6	0.8	0.6	2.6	1.9	3.7	0.9	0.2	0.5
	PrecStd	9.1	1.3	1.5	2.9	1.3	2.4	2.9	2.5	3.5	2.6	2.9	1.8	2.2
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	78.7	81.5	82.1	85.2	88.0	91.1	90.5	90.9	89.5	87.5	83.7	80.1
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	2%	DB	76.1	78.1	78.7	82.3	85.1	88.6	89.0	89.4	87.9	85.7	80.7	78.3
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5%	DB	74.2	76.1	77.1	80.6	83.5	87.1	87.8	88.3	87.0	84.4	78.9	76.9
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	10%	DB	72.2	73.9	75.3	79.2	82.2	85.7	86.8	87.2	86.1	83.1	77.4	75.2
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	0.4%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	2%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Mean Daily Temperature Range	5% DB	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
	5% WB	MCDBR	12.9	12.8	12.5	11.5	10.5	10.7	10.3	10.5	10.4	10.5	11.3	11.8
		MCDBR	12.7	12.7	12.1	11.5	11.3	12.1	10.7	11.2	10.8	9.9	10.9	10.8
	5% WB	MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Clear-Sky Solar Irradiance	taub	0.347	0.359	0.374	0.397	0.428	0.456	0.473	0.463	0.426	0.402	0.365	0.354	
	taud	2.544	2.521	2.467	2.383	2.337	2.335	2.284	2.328	2.423	2.460	2.514	2.549	
	Ebn at Noon	284	289	291	285	275	266	261	263	271	272	275	276	
	Edh at Noon	28	31	35	39	41	41	43	41	36	33	29	27	
All-Sky Solar Radiation	RadAvg	1062	1288	1624	1932	1991	1886	1891	1793	1565	1381	1119	965	
	RadStd	77	79	106	77	138	179	94	106	100	89	61	64	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (31 neighbors)	+0.74	N/A	N/A	N/A	N/A	N/A	N/A	-72	+275	+202

Nomenclature: See separate page