

EAGLE POINT, TX, USA

WMO: 997361

Lat: 29.481N

Lon: 94.917W

Elev: 10

StdP: 101.20

Time Zone: -6.00 (NAC)

Period: 05-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) 1.3	(c) 3.4	(d) N/A	(e) N/A	(f) N/A	(g) N/A	(h) N/A	(i) N/A	(j) 11.8	(k) 14.2	(l) 10.8	(m) 12.8	(n) 5.2	(o) 10	(p) 0.523

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a) 8	(b) 4.5	(c) 32.1	(d) N/A	(e) 31.5	(f) N/A	(g) 31.0	(h) N/A	(i) N/A	(j) N/A	(k) N/A	(l) N/A	(m) N/A	(n) N/A	(o) 4.8	(p) 180

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a) N/A	(b) N/A	(c) N/A	(d) N/A	(e) N/A	(f) N/A	(g) N/A	(h) N/A	(i) N/A	(j) N/A	(k) N/A	(l) N/A	(m) N/A	(n) N/A	(o) N/A	(p) N/A

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%		2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		
				Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	
(a)	(b)	(c)		(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
14.4	11.5	10.0	DB	-0.4	33.8	2.2	1.1	-1.9	34.6	-3.2	35.3	-4.4	35.9	-6.0	36.7	
			WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	21.2	11.8	13.7	17.4	20.9	24.4	27.8	28.3	28.8	27.0	22.8	17.0	14.0
	DBStd	6.76	4.43	4.59	3.85	2.84	2.18	1.23	1.12	1.12	1.74	3.39	4.25	4.38
	HDD10.0	74	32	19	4	0	0	0	0	0	0	0	4	14
	HDD18.3	637	204	136	61	11	1	0	0	0	0	7	73	145
	CDD10.0	4162	89	123	233	328	447	534	567	582	509	397	215	138
	CDD18.3	1682	2	6	32	88	189	284	309	323	259	146	33	11
	CDH23.3	16794	1	3	13	187	1323	3363	3858	4189	2815	996	41	6
	CDH26.7	5507	0	0	1	8	103	1136	1483	1793	852	131	1	0
(14) Wind	WSAvg	5.1	4.5	5.0	5.6	6.7	6.5	5.8	4.8	4.3	4.6	4.8	4.6	4.5
(15) Precipitation	PrecAvg	1240	109	74	84	86	91	113	96	112	152	119	101	105
	PrecMax	1724	262	210	190	218	237	333	300	333	307	327	337	239
	PrecMin	673	17	13	7	12	1	12	10	14	34	9	12	27
	PrecStd	284	62	55	49	59	63	76	68	87	72	86	72	50
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	22.4	23.5	24.7	27.7	30.0	33.0	32.7	33.1	32.4	29.8	25.7	24.1
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	2%	DB	20.6	21.8	23.4	25.8	28.5	31.3	31.5	32.2	31.4	28.9	24.6	22.8
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5%	DB	19.4	20.7	22.7	25.1	27.7	30.4	31.0	31.7	30.5	28.1	23.8	21.5
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	10%	DB	18.0	19.6	22.0	24.4	27.2	29.9	30.5	31.2	29.7	27.4	22.7	20.2
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	2%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	10%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(35) Mean Daily Temperature Range	5% DB	MDBR	5.8	5.5	4.4	4.1	3.5	3.7	4.1	4.5	4.0	4.9	5.3	5.8
		MCDBR	7.2	6.5	4.1	4.6	4.1	4.8	4.7	5.2	4.7	4.6	5.6	7.2
		MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5% WB	MCDBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(40) Clear-Sky Solar Irradiance	taub		0.346	0.363	0.378	0.437	0.477	0.469	0.493	0.478	0.454	0.385	0.374	0.355
	taud		2.511	2.474	2.422	2.256	2.180	2.257	2.212	2.256	2.287	2.471	2.447	2.493
	Ebn at Noon		890	903	909	862	824	826	805	816	824	868	849	860
	Edh at Noon		90	101	113	138	150	138	144	137	128	100	95	88
(44) All-Sky Solar Radiation	RadAvg		2.90	3.29	4.52	5.39	6.06	6.28	5.97	5.72	4.98	4.39	3.34	2.59
	RadStd		0.28	0.55	0.38	0.39	0.41	0.47	0.56	0.47	0.53	0.53	0.34	0.30

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46) Station Only		N/A	(e) N/A	(f) N/A	(g) N/A	(h) N/A	(i) N/A	(j) N/A	(k) N/A	(l) N/A	(m) N/A
(47) Regional (31 neighbors)		+0.34	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+113	+94

Nomenclature: See separate page