

MORGANS POINT, TX, USAWMO: **997370**Lat: **29.682N**Lon: **94.985W**Elev: **33**StdP: **14.68**Time Zone: **-6.00 (NAC)**Period: **05-19**WBAN: **99999****Annual Heating, Humidification, and Ventilation Design Conditions**

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	34.6	38.3	N/A	N/A	N/A	N/A	N/A	N/A	25.7	50.9	22.3	52.5	11.1	10	0.431

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	9.9	92.2	N/A	91.0	N/A	89.8	N/A	N/A	N/A	N/A	N/A	N/A	N/A	8.3	150

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4)	25.0	20.5	17.8	30.4	96.4	3.7	1.9	27.7	97.8	25.6	99.0	23.5	100.1	20.8	101.5	
(5)				N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	70.7	54.0	57.2	64.2	70.5	76.4	83.1	83.8	85.1	81.0	73.1	62.2	57.1
	DBStd	12.54	7.91	8.65	7.48	5.64	4.48	2.41	2.58	2.51	3.32	6.35	8.15	8.27
	HDD50	139	52	36	9	1	0	0	0	0	0	0	12	29
	HDD65	1127	346	232	101	20	2	0	0	0	0	15	144	267
	CDD50	7702	175	237	448	617	820	994	1049	1088	930	716	378	250
	CDD65	3213	4	13	76	186	356	544	584	623	480	265	60	22
	CDH74	32610	2	13	73	614	2747	6571	7279	8092	5177	1902	110	30
	CDH80	11886	0	0	3	27	433	2575	3034	3787	1695	327	4	1
Wind	WSAvg	8.6	8.2	8.5	9.8	10.8	10.4	8.8	7.4	6.7	7.6	8.1	8.3	8.1
Precipitation	PrecAvg	58.5	5.0	3.4	3.8	3.6	5.2	5.6	5.4	4.8	5.9	5.7	4.6	4.7
	PrecMax	80.9	11.7	7.8	9.5	9.3	8.3	15.7	13.8	10.6	14.5	17.8	11.3	8.7
	PrecMin	39.5	0.6	0.9	1.0	0.5	0.1	0.6	0.6	1.1	1.1	0.2	0.6	2.0
	PrecStd	11.3	2.7	2.1	2.1	2.3	2.8	3.7	3.4	3.1	3.1	5.1	2.6	1.8
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	73.2	76.0	79.1	83.2	87.8	93.8	93.2	95.0	91.3	87.4	79.9	77.5
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	2%	DB	69.8	72.4	75.9	80.4	85.8	90.7	91.2	92.7	89.4	85.4	77.1	73.8
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5%	DB	67.5	70.0	74.3	78.9	84.1	89.2	90.0	91.4	88.0	83.5	75.0	71.0
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	10%	DB	65.0	67.6	72.9	77.6	82.4	88.0	88.9	90.4	86.5	81.8	72.9	68.5
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	2%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	10%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Mean Daily Temperature Range	5% DB	MDBR	11.9	11.7	10.1	9.9	9.0	9.3	9.1	9.9	9.8	12.0	12.0	11.9
		MCDBR	14.0	13.3	9.4	9.8	10.2	10.8	10.3	11.1	10.6	11.2	11.8	14.1
		MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5% WB	MCDBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Clear-Sky Solar Irradiance	taub	0.343	0.361	0.376	0.439	0.480	0.473	0.498	0.484	0.458	0.383	0.373	0.352	
	taud	2.513	2.471	2.419	2.240	2.162	2.234	2.186	2.229	2.267	2.466	2.441	2.494	
	Ebn at Noon	283	287	289	272	261	261	254	257	260	276	269	273	
	Edh at Noon	28	32	36	44	48	45	47	44	42	32	30	28	
All-Sky Solar Radiation	RadAvg	916	1033	1422	1699	1902	1974	1899	1817	1578	1382	1046	813	
	RadStd	87	175	120	121	132	151	174	148	164	169	106	95	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (33 neighbors)		+0.61	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+203	+169

Nomenclature: See separate page