

ANCHORAGE HARBOR, AK, USA

WMO: 997381

Lat: 61.238N

Lon: 149.890W

Elev: 3

StdP: 101.29

Time Zone: -9.00 (NAK)

Period: 05-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-19.6	-18.0	N/A	N/A	N/A	N/A	N/A	N/A	10.1	-5.1	8.4	-4.9	1.9	110	0.667

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	4.3	19.2	N/A	18.1	N/A	17.1	N/A	N/A	N/A	N/A	N/A	N/A	N/A	2.6	220

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
8.7	7.2	5.7	-21.1	22.6	2.4	2.3	-22.8	24.2	-24.2	25.5	-25.6	26.8	-27.4	28.4		
			DB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
			WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
Temperatures, Degree-Days and Degree-Hours	DBAvg	3.2	-7.6	-6.0	-3.2	2.3	8.7	12.7	14.6	13.8	9.9	3.6	-4.3	-6.5		
	DBStd	9.10	6.19	5.06	4.49	3.01	2.76	2.08	1.70	1.64	2.67	3.72	5.56	5.21		
	HDD10.0	2869	546	448	411	230	59	2	0	0	34	199	429	512		
	HDD18.3	5518	804	681	669	480	300	168	116	141	254	456	679	770		
	CDD10.0	393	0	0	0	0	17	83	143	118	30	1	0	0		
	CDD18.3	1	0	0	0	0	0	1	1	0	0	0	0	0		
	CDH23.3	1	0	0	0	0	0	1	0	0	0	0	0	0		
	CDH26.7	0	0	0	0	0	0	0	0	0	0	0	0	0		
	WSAvg	2.3	2.3	2.5	2.5	2.1	2.4	2.5	2.3	2.0	2.0	2.1	2.5	2.5		
Precipitation	PrecAvg	416	20	20	17	13	17	28	46	71	75	49	30	29		
	PrecMax	700	69	61	70	48	49	86	114	248	196	109	72	68		
	PrecMin	206	0	3	0	0	1	4	5	8	18	9	1	2		
	PrecStd	89	14	12	13	12	11	19	25	45	44	24	21	17		
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	6.7	5.6	6.6	11.1	18.8	20.8	21.3	20.2	16.8	13.6	8.9	7.8		
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
	2%	DB	3.3	3.3	4.8	9.4	15.6	18.2	19.3	18.9	15.1	11.0	4.7	3.9		
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
	5%	DB	1.6	1.4	3.4	7.8	13.8	16.9	18.2	17.8	14.2	9.5	3.7	1.5		
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
	10%	DB	0.1	0.2	2.2	6.4	12.4	15.7	17.3	16.7	13.4	8.2	2.4	0.0		
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
	2%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
	5%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
	10%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
Mean Daily Temperature Range	5% DB	MDBR	4.8	5.5	6.3	6.1	6.0	4.8	4.3	4.6	4.9	4.7	4.7	4.8		
		MCDBR	5.5	5.7	6.1	7.8	8.1	6.6	5.7	6.2	5.4	5.4	5.1	6.0		
		MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
	5% WB	MCDBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
		MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
Clear-Sky Solar Irradiance	taub		0.234	0.287	0.307	0.348	0.369	0.359	0.372	0.357	0.319	0.298	0.243	0.216		
	taud		2.130	2.236	2.271	2.254	2.315	2.423	2.414	2.464	2.558	2.476	2.129	1.943		
	Ebn at Noon		503	692	812	841	851	869	845	831	810	695	470	310		
	Edh at Noon		37	65	89	110	112	103	102	89	68	52	36	26		
All-Sky Solar Radiation	RadAvg		0.28	0.97	2.59	4.29	5.16	5.32	4.73	3.74	2.43	1.13	0.42	0.15		
	RadStd		0.04	0.14	0.28	0.38	0.47	0.34	0.41	0.41	0.34	0.14	0.06	0.02		

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)		
Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
Regional (26 neighbors)		N/A	+2.00	+1.70	N/A	N/A	N/A	N/A	N/A		

Nomenclature: See separate page