

NIKISKI HARBOR, AK, USA

WMO: 997382

Lat: 60.683N

Lon: 151.399W

Elev: 8

StdP: 101.23

Time Zone: -9.00 (NAK)

Period: 05-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-19.3	-16.5	N/A	N/A	N/A	N/A	N/A	N/A	12.1	-1.3	11.1	-2.1	2.6	90	0.767

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	3.8	17.8	N/A	16.7	N/A	15.7	N/A	N/A	N/A	N/A	N/A	N/A	N/A	3.5	190

Dehumidification DP/MCDB and HR

0.4%			1%			2%			0.4%		1%		2%		Extreme Max WB
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a) N/A	(b) N/A	(c) N/A	(d) N/A	(e) N/A	(f) N/A	(g) N/A	(h) N/A	(i) N/A	(j) N/A	(k) N/A	(l) N/A	(m) N/A	(n) N/A	(o) N/A	

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		Extreme Max WB	
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	(q)	(r)
13.4	11.0	9.3	-21.1	21.2	4.4	2.4	-24.3	23.0	-26.9	24.4	-29.3	25.8	-32.5	27.5		
			N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	3.5	-5.4	-4.9	-2.7	2.2	7.3	10.8	13.1	13.3	10.1	4.7	-2.1	-4.6
	DBStd	8.01	6.49	4.89	4.53	3.21	2.49	1.92	1.59	1.62	2.34	3.20	5.26	5.26
	HDD10.0	2632	478	418	394	236	88	12	0	0	27	164	363	452
	HDD18.3	5406	737	652	653	486	341	227	163	158	247	422	613	710
	CDD10.0	268	0	0	0	0	6	35	96	101	29	1	0	0
	CDD18.3	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDH23.3	1	0	0	0	0	0	1	0	0	0	0	0	0
	CDH26.7	0	0	0	0	0	0	0	0	0	0	0	0	0
Wind	WSAvg	4.3	4.3	4.0	4.4	4.3	4.1	4.5	4.4	4.0	4.0	4.3	4.7	4.6
Precipitation	PrecAvg	507	30	30	21	17	19	29	48	65	90	73	42	43
	PrecMax	682	85	86	100	51	62	56	115	128	171	161	109	112
	PrecMin	354	8	0	3	0	2	8	15	19	31	30	0	7
	PrecStd	85	20	20	21	13	14	14	25	30	40	33	29	27
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	7.1	5.3	7.0	11.2	17.5	19.2	19.0	19.7	16.0	12.4	8.0	5.6
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	2%	DB	4.8	3.8	5.3	9.2	14.0	16.1	17.3	18.0	14.6	10.4	6.4	4.4
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5%	DB	3.4	2.6	4.1	7.7	12.3	14.7	16.3	16.9	13.9	9.6	5.4	3.4
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	10%	DB	2.2	1.3	2.8	6.3	10.8	13.5	15.5	15.8	13.1	8.8	4.5	2.3
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	2%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	10%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Mean Daily Temperature Range	5% DB	MDBR	5.2	5.9	5.9	5.3	5.0	3.9	3.3	3.8	4.3	4.2	4.6	4.7
		MCDBR	4.5	4.9	5.7	6.8	8.0	6.6	5.0	5.6	4.8	4.4	3.4	3.7
		MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5% WB	MCDBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Clear-Sky Solar Irradiance	taub	0.241	0.288	0.307	0.348	0.371	0.360	0.372	0.358	0.325	0.302	0.253	0.227	
	taud	2.149	2.270	2.294	2.273	2.303	2.429	2.428	2.471	2.545	2.458	2.149	1.970	
	Ebn at Noon	518	706	819	845	851	870	848	832	806	696	482	331	
	Edh at Noon	39	65	88	109	114	103	101	90	70	54	38	28	
All-Sky Solar Radiation	RadAvg	0.29	0.96	2.53	4.09	5.18	5.42	4.76	3.78	2.46	1.17	0.42	0.15	
	RadStd	0.04	0.14	0.29	0.40	0.45	0.39	0.47	0.45	0.35	0.13	0.07	0.02	

Historical Trends

	DBAvg	Heating			Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% DP	1% DP	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (23 neighbors)	+0.69	+2.09	+1.81	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page