

NOME NORTON SOUND, AK, USA

WMO: 997383

Lat: 64.500N

Lon: 165.420W

Elev: 26

StdP: 14.68

Time Zone: -9.00 (NAK)

Period: 06-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) -24.2	(c) -19.8	(d) N/A	(e) N/A	(f) N/A	(g) N/A	(h) N/A	(i) N/A	(j) 34.9	(k) 14.3	(l) 31.7	(m) 17.6	(n) 3.4	(o) 40	(p) 0.885

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a) 8	(b) 8.0	(c) 65.0	(d) N/A	(e) 61.9	(f) N/A	(g) 59.6	(h) N/A	(i) N/A	(j) N/A	(k) N/A	(l) N/A	(m) N/A	(n) N/A	(o) 8.8	(p) 80

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a) N/A	(b) N/A	(c) N/A	(d) N/A	(e) N/A	(f) N/A	(g) N/A	(h) N/A	(i) N/A	(j) N/A	(k) N/A	(l) N/A	(m) N/A	(n) N/A	(o) N/A	(p) N/A

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a) 34.4	(b) 28.4	(c) 24.7	(e) -26.1	(f) 72.7	(g) 5.1	(h) 4.3	(i) -29.8	(j) 75.8	(k) -32.8	(l) 78.4	(m) -35.7	(n) 80.8	(o) -39.4	(p) 84.0		
			DB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
			WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	28.7	6.7	10.2	10.0	20.2	35.1	45.9	52.4	52.2	45.3	33.3	20.0	12.4
	DBStd	19.53	16.60	14.95	11.96	11.16	7.96	6.33	5.19	4.68	6.01	6.27	9.57	12.55
	HDD50	8014	1342	1114	1241	894	466	156	31	28	160	516	901	1165
	HDD65	13233	1807	1534	1706	1344	927	574	393	396	590	981	1351	1630
	CDD50	256	0	0	0	0	3	32	104	97	20	0	0	0
	CDD65	2	0	0	0	0	0	0	2	0	0	0	0	0
	CDH74	3	0	0	0	0	0	0	3	0	0	0	0	0
	CDH80	0	0	0	0	0	0	0	0	0	0	0	0	0
(14) Wind	WSAvg	10.2	9.5	11.5	10.0	9.1	9.0	10.2	10.5	10.4	10.5	10.5	10.9	10.6
(15) Precipitation	PrecAvg	15.7	0.9	0.7	0.6	0.7	0.7	1.0	2.2	2.9	2.3	1.5	1.1	0.9
	PrecMax	24.3	2.4	2.1	3.1	2.2	3.0	4.1	6.3	6.6	7.5	3.9	4.4	2.2
	PrecMin	7.4	0.0	0.0	0.0	0.0	0.0	0.0	0.2	0.4	0.1	0.0	0.0	0.0
	PrecStd	3.7	0.6	0.6	0.6	0.6	0.7	0.9	1.3	1.4	1.5	0.9	0.9	0.5
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	39.4	35.5	34.4	43.3	59.4	67.7	72.5	67.0	59.6	48.3	40.1	36.8
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	2%	DB	34.2	33.1	31.9	39.4	53.1	60.8	66.0	64.4	56.7	45.5	37.9	33.6
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5%	DB	32.1	31.8	30.3	37.0	48.3	57.1	62.0	61.8	54.8	43.9	35.2	31.7
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	10%	DB	29.4	30.2	27.9	34.7	44.5	54.5	59.5	59.6	53.4	42.0	32.8	29.3
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	2%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	10%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(35) Mean Daily Temperature Range	5% DB	MDBR	11.8	13.1	13.6	13.6	9.9	7.7	7.3	8.0	7.7	7.2	7.9	9.9
		MCDBR	10.7	10.5	8.9	11.5	15.0	13.6	12.7	10.8	8.3	6.1	6.4	8.4
		MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5% WB	MCDBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(40) Clear-Sky Solar Irradiance	taub		0.179	0.255	0.273	0.327	0.365	0.355	0.373	0.400	0.322	0.283	0.374	0.185
	taud		1.911	2.117	2.188	2.072	2.204	2.430	2.417	2.281	2.512	2.363	2.731	1.892
	Ebn at Noon		120	206	259	265	266	273	264	240	245	199	101	37
	Edh at Noon		8	19	28	40	38	32	31	33	21	15	8	3
(44) All-Sky Solar Radiation	RadAvg		48	259	817	1456	1640	1807	1419	1107	701	284	69	16
	RadStd		7	36	103	95	203	178	95	143	65	33	11	1

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (6 neighbors)	+1.49	N/A	N/A	N/A	+0.86	+0.99	N/A	N/A	+63	N/A

Nomenclature: See separate page