

BAY OF CAMPECHE BUOY 42055, Mexico

WMO: 997398

Lat: 22.124N

Lon: 93.941W

Elev: 10

StdP: 14.69

Time Zone: -6.00 (W06)

Period: 05-18

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	65.4	67.1	49.3	52.0	68.9	51.6	56.7	69.7	36.0	70.5	34.0	70.2	20.4	0	0.610

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	2.8	86.5	79.4	86.3	79.3	85.9	79.2	83.9	84.8	82.1	84.3	81.0	84.3	11.6	110

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
83.7	176.5	84.7	81.6	164.3	83.8	80.1	156.3	83.4	48.0	84.7	45.9	84.5	44.7	84.1	86.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
31.2	27.5	24.9	63.8	89.4	2.7	2.0	61.9	90.8	60.3	92.0	58.7	93.1	56.8	94.6
			N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	79.0	72.9	73.1	74.3	77.5	80.0	82.5	83.6	84.5	83.8	81.5	77.9	75.6	(6)
	DBStd	4.62	2.72	2.88	2.74	2.33	1.90	1.36	1.06	1.13	1.50	2.05	2.36	2.44	(7)
	HDD50	0	0	0	0	0	0	0	0	0	0	0	0	0	(8)
	HDD65	0	0	0	0	0	0	0	0	0	0	0	0	0	(9)
	CDD50	10576	711	648	755	824	929	976	1043	1068	1013	978	837	794	(10)
	CDD65	5101	246	228	290	374	464	526	578	603	563	513	387	329	(11)
	CDH74	48384	494	499	1016	2595	4483	6272	7274	8004	7299	5819	3004	1625	(12)
	CDH80	13725	0	0	1	78	546	1983	2823	3546	3002	1586	158	2	(13)
(14) Wind	WSAvg	14.6	16.0	15.2	15.8	15.6	15.2	14.2	14.1	12.1	12.3	14.2	15.3	15.7	(14)
(15) Precipitation	PrecAvg	25.5	1.9	1.0	0.7	0.6	0.9	2.5	1.7	2.4	4.3	5.1	2.6	1.9	(15)
	PrecMax	40.4	4.9	2.9	2.6	2.7	2.4	7.2	4.2	4.8	9.3	19.4	10.9	5.2	(16)
	PrecMin	14.9	0.4	0.0	0.0	0.0	0.0	0.3	0.3	0.6	1.1	0.2	0.5	0.4	(17)
	PrecStd	5.9	1.2	0.7	0.7	0.6	0.7	1.5	1.0	1.1	1.9	4.1	2.6	1.1	(18)
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	78.4	78.1	79.6	82.6	84.1	85.7	86.3	87.5	87.3	86.0	83.1	80.5	(19)
		MCWB	74.5	74.9	74.6	79.1	79.6	79.9	79.7	80.1	79.5	79.5	77.1	75.6	(20)
	2%	DB	77.7	77.4	78.5	81.7	83.2	85.2	85.8	86.8	86.5	85.3	82.3	79.9	(21)
		MCWB	73.8	74.4	74.3	78.0	78.9	79.7	79.8	79.8	78.9	78.6	76.8	74.8	(22)
	5%	DB	77.1	77.0	78.0	80.9	82.6	84.6	85.4	86.3	86.2	84.8	81.6	79.3	(23)
		MCWB	73.2	74.2	74.2	77.2	78.6	79.4	79.5	79.5	78.8	77.8	75.6	74.1	(24)
	10%	DB	76.4	76.4	77.4	80.3	82.2	84.3	85.1	86.1	85.7	84.4	80.9	78.7	(25)
		MCWB	72.4	73.6	74.1	76.6	78.3	79.3	79.4	79.4	78.5	77.2	74.4	73.4	(26)
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	75.6	77.1	77.5	80.1	81.8	82.6	84.6	85.5	81.8	80.7	80.4	77.4	(27)
		MCDB	77.8	77.2	77.7	81.8	82.3	84.1	84.7	86.5	85.6	84.5	82.4	79.4	(28)
	2%	WB	74.8	76.2	76.9	79.1	81.0	81.7	83.9	84.3	80.8	79.7	77.6	76.7	(29)
		MCDB	77.3	76.6	77.3	80.9	81.8	84.0	84.3	85.8	85.2	83.9	81.7	79.3	(30)
	5%	WB	74.1	75.4	76.2	78.4	80.3	81.0	82.7	81.8	80.1	78.9	76.8	75.9	(31)
		MCDB	76.9	76.3	77.1	80.3	81.6	83.8	84.3	85.4	85.0	83.6	81.3	79.0	(32)
	10%	WB	73.2	74.6	75.4	77.8	79.5	80.4	80.8	80.4	79.6	78.2	75.9	74.3	(33)
		MCDB	76.3	76.1	76.8	80.0	81.5	83.7	84.6	85.6	84.9	83.3	80.6	78.2	(34)
(35) Mean Daily Temperature Range	5% DB	MDBR	2.9	2.7	2.5	2.4	2.1	2.3	2.0	2.8	3.2	2.9	2.7	2.7	(35)
		MCDBR	3.0	2.5	2.8	2.3	2.2	2.5	2.1	2.8	3.3	3.2	3.1	2.9	(36)
	5% WB	MCWBR	3.7	2.3	2.6	2.5	2.5	2.6	2.4	2.7	2.7	2.8	3.3	3.5	(37)
		MCWBR	2.7	2.3	2.4	2.1	2.1	2.2	2.2	3.0	3.0	2.9	3.4	3.2	(38)
(40) Clear-Sky Solar Irradiance	taub		0.380	0.399	0.421	0.485	0.498	0.453	0.469	0.446	0.428	0.404	0.390	0.389	(40)
		taud	2.522	2.455	2.368	2.175	2.165	2.373	2.323	2.408	2.441	2.513	2.512	2.496	(41)
	Ebn at Noon		282	283	280	263	257	267	263	270	274	278	276	274	(42)
		Edh at Noon	31	35	39	49	49	39	41	38	36	32	31	31	(43)
(44) All-Sky Solar Radiation	RadAvg		1184	1464	1777	2016	2106	2088	2158	2030	1737	1593	1316	1156	(44)
	RadStd		107	141	131	125	99	96	110	84	124	82	123	90	(45)

Historical Trends

		DBAvg	Heating			Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP		HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
(47) Regional (0 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	

Nomenclature: See separate page