

BAY OF CAMPECHE BUOY 42055, Mexico

WMO: 997398

Lat: 22.124N

Lon: 93.941W

Elev: 3

StdP: 101.29

Time Zone: -6.00 (W06)

Period: 05-18

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	18.6	19.5	9.6	7.4	20.5	10.9	8.1	20.9	16.1	21.4	15.2	21.2	9.1	0	0.610

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	1.5	30.3	26.3	30.1	26.3	29.9	26.2	28.9	29.3	27.8	29.1	27.2	29.0	5.2	110

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
28.7	25.2	29.3	27.5	23.5	28.8	26.7	22.3	28.6	93.8	29.3	89.0	29.2	86.1	29.0	30.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	(q)
13.9	12.3	11.1	DB	17.7	31.9	1.5	1.1	16.6	32.7	15.7	33.3	14.9	34.0	13.8	34.8	
			WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	26.1	22.7	22.9	23.5	25.3	26.7	28.1	28.7	29.1	28.8	27.5	25.5	24.2
	DBStd	2.56	1.51	1.60	1.52	1.30	1.05	0.75	0.59	0.63	0.83	1.14	1.31	1.36
	HDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD18.3	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDD10.0	5876	395	360	419	458	516	542	579	593	563	543	465	441
	CDD18.3	2834	137	127	161	208	258	292	321	335	313	285	215	183
	CDH23.3	26880	274	277	564	1442	2491	3484	4041	4447	4055	3233	1669	903
	CDH26.7	7625	0	0	1	43	303	1102	1568	1970	1668	881	88	1
Wind	WSAvg	6.5	7.2	6.8	7.1	7.0	6.8	6.4	6.3	5.4	5.5	6.4	6.9	7.0
Precipitation	PrecAvg	648	47	25	19	16	22	63	43	61	110	130	66	47
	PrecMax	1027	125	74	65	69	62	182	107	122	236	494	277	133
	PrecMin	378	11	0	0	1	1	8	7	16	29	5	12	9
	PrecStd	150	30	17	18	16	19	39	26	29	49	104	65	29
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	25.8	25.6	26.4	28.1	28.9	29.8	30.2	30.8	30.7	30.0	28.4	26.9
		MCWB	23.6	23.8	23.6	26.1	26.4	26.6	26.5	26.7	26.4	26.4	25.0	24.2
	2%	DB	25.4	25.2	25.8	27.6	28.4	29.6	29.9	30.4	30.3	29.6	28.0	26.6
		MCWB	23.2	23.6	23.5	25.6	26.1	26.5	26.5	26.5	26.1	25.9	24.9	23.8
	5%	DB	25.1	25.0	25.6	27.2	28.1	29.2	29.7	30.2	30.1	29.3	27.6	26.3
		MCWB	22.9	23.4	23.4	25.1	25.9	26.4	26.4	26.4	26.0	25.5	24.2	23.4
	10%	DB	24.7	24.7	25.2	26.8	27.9	29.1	29.5	30.0	29.8	29.1	27.2	25.9
		MCWB	22.4	23.1	23.4	24.8	25.7	26.3	26.3	26.3	25.8	25.1	23.6	23.0
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	24.2	25.1	25.3	26.7	27.7	28.1	29.2	29.7	27.6	27.1	26.9	25.2
		MCDB	25.4	25.1	25.4	27.7	28.0	29.0	29.3	30.3	29.8	29.1	28.0	26.3
	2%	WB	23.8	24.5	24.9	26.2	27.2	27.6	28.9	29.1	27.1	26.5	25.3	24.8
		MCDB	25.2	24.8	25.2	27.2	27.7	28.9	29.1	29.9	29.5	28.9	27.6	26.3
	5%	WB	23.4	24.1	24.6	25.8	26.8	27.2	28.2	27.6	26.7	26.1	24.9	24.4
		MCDB	24.9	24.6	25.0	26.8	27.5	28.8	29.0	29.7	29.4	28.7	27.4	26.1
	10%	WB	22.9	23.7	24.1	25.4	26.4	26.9	27.1	26.9	26.5	25.7	24.4	23.5
		MCDB	24.6	24.5	24.9	26.7	27.5	28.7	29.2	29.8	29.4	28.5	27.0	25.7
Mean Daily Temperature Range	5% DB	MDBR	1.6	1.5	1.4	1.3	1.2	1.3	1.1	1.5	1.8	1.6	1.5	1.5
		MCDBR	1.7	1.4	1.5	1.3	1.2	1.4	1.2	1.6	1.8	1.8	1.7	1.6
		MCWBR	2.0	1.3	1.4	1.4	1.4	1.5	1.3	1.5	1.5	1.5	1.8	1.9
	5% WB	MCDBR	1.5	1.3	1.3	1.2	1.2	1.2	1.2	1.7	1.7	1.6	1.9	1.8
MCWBR		1.9	1.5	1.8	1.5	1.5	1.5	1.5	1.9	1.7	1.6	2.3	2.3	
Clear-Sky Solar Irradiance	taub	0.380	0.399	0.421	0.485	0.498	0.453	0.469	0.446	0.428	0.404	0.390	0.389	
	taud	2.522	2.455	2.368	2.175	2.165	2.373	2.323	2.408	2.441	2.513	2.512	2.496	
	Ebn at Noon	889	892	884	829	811	841	828	851	865	876	871	865	
	Edh at Noon	97	109	124	153	153	123	130	119	114	102	97	97	
All-Sky Solar Radiation	RadAvg	3.73	4.62	5.60	6.35	6.64	6.58	6.80	6.40	5.48	5.02	4.15	3.64	
	RadStd	0.34	0.45	0.41	0.39	0.31	0.30	0.35	0.26	0.39	0.26	0.39	0.28	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (0 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page