

PILOT STATION EAST, LA, USA

WMO: 997703

Lat: 28.9320N

Lon: 89.4068W

Elev: 10

StdP: 14.69

Time Zone: -6.00 (NAC)

Period: 06-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	39.7	43.4	N/A	N/A	N/A	N/A	N/A	N/A	34.7	50.8	32.6	50.3	19.8	30	N/A

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	9.4	94.4	N/A	92.5	N/A	91.0	N/A	N/A	N/A	N/A	N/A	N/A	N/A	5.9	90

Dehumidification DP/MCDB and HR

0.4%			1%			2%			0.4%		1%		2%		Extreme Max WB
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		DB	WB
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	(q)	(r)
31.7	27.2	24.2	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	73.3	56.8	60.1	63.8	71.3	77.9	83.8	85.3	86.1	84.7	78.1	68.4	63.0
	DBStd	11.49	7.32	6.47	6.15	4.22	4.04	2.82	2.68	3.22	2.66	5.48	6.59	6.98
	HDD50	42	29	8	2	0	0	0	0	0	0	0	0	3
	HDD65	690	263	157	96	7	1	0	0	0	0	2	42	122
	CDD50	8557	238	289	429	638	865	1014	1093	1119	1042	871	552	407
	CDD65	3730	7	19	58	195	400	564	628	654	592	408	144	61
	CDH74	37577	10	30	136	545	2894	6564	7955	8513	7165	3230	411	124
	CDH80	14805	0	2	12	46	595	2469	3554	4125	3010	885	89	18
Wind	WSAvg	11.2	12.8	12.5	11.9	12.8	9.8	9.4	9.3	9.0	10.4	12.1	11.6	12.6
Precipitation	PrecAvg	57.8	4.7	3.8	4.8	4.8	3.9	5.1	6.5	6.5	5.9	4.1	3.5	4.2
	PrecMax	85.0	14.7	8.4	13.1	18.2	10.3	15.9	10.3	12.3	15.1	11.7	14.4	10.7
	PrecMin	35.2	0.1	0.7	0.6	0.5	0.4	1.1	3.0	2.5	1.8	0.7	0.4	1.1
	PrecStd	10.4	3.3	2.0	2.7	3.5	2.5	3.0	2.0	2.6	2.9	2.8	2.8	2.2
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	75.4	78.7	81.6	84.0	90.4	94.4	95.7	97.8	94.6	91.3	87.3	82.5
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	2%	DB	70.9	73.2	77.8	81.3	87.4	91.9	93.0	95.1	92.6	89.1	82.3	77.3
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5%	DB	68.6	70.8	74.6	79.0	85.3	89.8	91.0	92.9	91.1	87.0	78.7	73.7
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	10%	DB	66.7	68.5	71.9	77.2	83.4	87.7	89.2	90.8	89.4	84.8	75.2	71.8
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	2%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	10%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Mean Daily Temperature Range	5% DB	MDBR	13.0	13.1	12.5	10.6	9.7	8.8	8.7	9.4	9.6	11.1	12.9	12.9
		MCDBR	16.2	15.8	15.1	12.5	11.8	11.0	10.9	12.2	11.5	13.1	16.0	15.4
		MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5% WB	MCDBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
MCWBR		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Clear-Sky Solar Irradiance	taub		0.353	0.368	0.378	0.417	0.439	0.454	0.480	0.481	0.442	0.394	0.368	0.358
	taud		2.529	2.500	2.452	2.333	2.317	2.326	2.275	2.278	2.344	2.473	2.492	2.523
	Ebn at Noon		281	286	289	279	272	266	259	258	266	273	273	273
	Edh at Noon		28	31	35	41	42	41	43	43	39	32	29	27
All-Sky Solar Radiation	RadAvg		980	1198	1602	1913	2133	2028	1867	1739	1644	1472	1123	888
	RadStd		79	143	142	185	102	138	123	129	121	128	109	72

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (14 neighbors)	+0.77	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+243	+167

Nomenclature: See separate page