

PILOT STATION EAST, LA, USA

WMO: 997703

Lat: 28.9320N

Lon: 89.4068W

Elev: 3

StdP: 101.29

Time Zone: -6.00 (NAC)

Period: 06-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) 4.3	(c) 6.4	(d) N/A	(e) N/A	(f) N/A	(g) N/A	(h) N/A	(i) N/A	(j) 15.5	(k) 10.5	(l) 14.6	(m) 10.2	(n) 8.9	(o) 30	(p) N/A

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a) 8	(b) 5.2	(c) 34.7	(d) N/A	(e) 33.6	(f) N/A	(g) 32.8	(h) N/A	(i) N/A	(j) N/A	(k) N/A	(l) N/A	(m) N/A	(n) N/A	(o) 2.6	(p) 90

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a) N/A	(b) N/A	(c) N/A	(d) N/A	(e) N/A	(f) N/A	(g) N/A	(h) N/A	(i) N/A	(j) N/A	(k) N/A	(l) N/A	(m) N/A	(n) N/A	(o) N/A	(p) N/A

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a) 14.2	(b) 12.2	(c) 10.8	(d) DB	(e) N/A	(f) N/A	(g) N/A	(h) N/A	(i) N/A	(j) N/A	(k) N/A	(l) N/A	(m) N/A	(n) N/A	(o) N/A	(p) N/A	(q) N/A
(a) 14.2	(b) 12.2	(c) 10.8	(d) WB	(e) N/A	(f) N/A	(g) N/A	(h) N/A	(i) N/A	(j) N/A	(k) N/A	(l) N/A	(m) N/A	(n) N/A	(o) N/A	(p) N/A	(q) N/A

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	23.0	13.8	15.6	17.7	21.8	25.5	28.8	29.6	30.1	29.3	25.6	20.2	17.2
	DBStd	6.38	4.07	3.59	3.42	2.34	2.25	1.57	1.49	1.79	1.48	3.04	3.66	3.88
	HDD10.0	23	16	4	1	0	0	0	0	0	0	0	0	2
	HDD18.3	383	146	87	53	4	1	0	0	0	0	1	23	68
	CDD10.0	4754	132	161	238	354	481	563	607	622	579	484	307	226
	CDD18.3	2072	4	11	32	108	222	313	349	363	329	227	80	34
	CDH23.3	20876	6	17	76	303	1608	3647	4419	4729	3981	1794	228	69
	CDH26.7	8225	0	1	7	26	331	1372	1974	2292	1672	492	49	10
(14) Wind	WSAvg	5.0	5.7	5.6	5.3	5.7	4.4	4.2	4.2	4.0	4.6	5.4	5.2	5.6
(15) Precipitation	PrecAvg	1469	120	96	122	123	98	129	165	166	149	104	89	107
	PrecMax	2160	374	213	333	462	261	403	261	312	384	297	366	272
	PrecMin	894	3	18	16	13	11	27	75	64	45	19	9	27
	PrecStd	265	85	52	68	90	63	75	52	65	74	72	72	56
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	24.1	25.9	27.6	28.9	32.5	34.7	35.4	36.6	34.8	32.9	30.7	28.1
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	2%	DB	21.6	22.9	25.4	27.4	30.8	33.3	33.9	35.1	33.7	31.7	27.9	25.2
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5%	DB	20.3	21.5	23.7	26.1	29.6	32.1	32.8	33.8	32.8	30.6	26.0	23.1
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	10%	DB	19.3	20.3	22.1	25.1	28.6	30.9	31.8	32.6	31.9	29.3	24.0	22.1
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	2%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	10%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(35) Mean Daily Temperature Range	5% DB	MDBR	7.2	7.3	6.9	5.9	5.4	4.9	4.8	5.2	5.4	6.2	7.2	7.1
		MCDBR	9.0	8.8	8.4	6.9	6.5	6.1	6.0	6.8	6.4	7.3	8.9	8.5
		MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5% WB	MCDBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(40) Clear-Sky Solar Irradiance	taub		0.353	0.368	0.378	0.417	0.439	0.454	0.480	0.481	0.442	0.394	0.368	0.358
	taud		2.529	2.500	2.452	2.333	2.317	2.326	2.275	2.278	2.344	2.473	2.492	2.523
	Ebn at Noon		886	901	911	880	857	839	816	814	837	861	861	862
	Edh at Noon		89	99	110	128	131	129	135	134	122	101	92	86
(44) All-Sky Solar Radiation	RadAvg		3.09	3.78	5.05	6.03	6.72	6.39	5.88	5.48	5.18	4.64	3.54	2.80
	RadStd		0.25	0.45	0.45	0.58	0.32	0.43	0.39	0.41	0.38	0.40	0.34	0.23

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (14 neighbors)	+0.43	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+135	+93

Nomenclature: See separate page