

ROBINS REEF, NY, USA

WMO: 997743

Lat: 40.6574N

Lon: 74.0654W

Elev: 236

StdP: 14.57

Time Zone: -5.00 (NAE)

Period: 06-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	13.4	17.5	N/A	N/A	N/A	N/A	N/A	N/A	37.7	20.2	35.0	25.0	19.4	310	0.625

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	10.6	89.6	N/A	86.6	N/A	84.0	N/A	N/A	N/A	N/A	N/A	N/A	N/A	14.4	280

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
32.5	28.0	25.1	DB	8.9	93.7	5.2	2.1	5.1	95.3	2.1	96.5	-0.8	97.7	-4.6	99.3	
			WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	55.1	32.9	34.8	41.4	52.3	62.0	70.8	76.9	74.4	68.6	58.7	47.4	40.1
	DBStd	16.63	9.58	8.62	8.05	7.45	6.89	6.17	4.65	3.67	5.32	6.76	7.22	8.37
	HDD50	1773	534	430	287	55	1	0	0	0	0	11	131	324
	HDD65	4657	996	845	732	387	144	17	0	0	24	214	527	771
	CDD50	3649	3	5	19	125	372	623	835	757	558	281	54	17
	CDD65	1060	0	0	0	7	50	190	370	292	132	19	0	0
	CDH74	6321	0	1	0	52	259	1118	2803	1543	482	63	0	0
	CDH80	1644	0	0	0	14	54	343	897	262	62	12	0	0
Wind	WSAvg	12.7	13.6	14.0	14.5	14.1	12.1	11.7	11.0	10.8	11.7	13.4	13.1	13.2
Precipitation	PrecAvg	46.0	3.5	2.8	4.2	3.7	3.7	4.1	4.1	4.6	3.9	3.9	3.3	4.1
	PrecMax	66.8	7.1	5.6	10.8	11.4	7.8	9.4	8.7	17.5	9.1	13.6	6.3	6.9
	PrecMin	35.4	1.6	0.5	0.8	1.3	1.0	0.3	0.6	0.9	1.1	0.4	0.9	0.8
	PrecStd	7.0	1.3	1.3	2.1	2.1	1.4	2.1	2.0	3.1	2.2	2.8	1.5	1.4
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	60.6	63.4	68.3	81.4	85.5	92.6	94.1	89.0	85.6	80.3	67.4	67.1
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	2%	DB	55.0	55.3	61.0	72.7	80.9	87.7	91.0	85.7	81.7	74.5	63.7	59.6
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5%	DB	50.2	50.0	56.8	67.1	76.5	84.0	88.1	83.0	78.9	70.4	60.6	56.1
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	10%	DB	46.0	45.6	52.6	62.6	72.3	80.2	85.3	80.6	76.8	68.2	58.3	52.4
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	2%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	10%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Mean Daily Temperature Range	5% DB	MDBR	11.2	11.8	11.5	12.5	12.0	11.0	10.6	9.4	9.8	10.7	10.7	9.6
		MCDBR	17.0	17.4	17.7	19.0	17.8	16.1	14.7	13.0	12.5	13.6	13.8	13.5
		MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5% WB	MCDBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Clear-Sky Solar Irradiance	taub		0.313	0.325	0.358	0.381	0.427	0.485	0.487	0.474	0.399	0.360	0.330	0.313
	taud		2.469	2.437	2.404	2.372	2.272	2.147	2.154	2.183	2.365	2.484	2.526	2.529
	Ebn at Noon		269	282	283	283	271	254	252	252	266	266	261	260
	Edh at Noon		24	29	34	37	42	48	47	45	35	28	23	22
All-Sky Solar Radiation	RadAvg		593	880	1185	1525	1691	1858	1893	1649	1371	956	671	507
	RadStd		50	89	99	149	176	170	92	107	133	96	58	48

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (62 neighbors)	+0.72	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+209	+122

Nomenclature: See separate page