

ROBINS REEF, NY, USA

WMO: 997743

Lat: 40.6574N

Lon: 74.0654W

Elev: 72

StdP: 100.46

Time Zone: -5.00 (NAE)

Period: 06-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-10.3	-8.1	N/A	N/A	N/A	N/A	N/A	N/A	16.9	-6.6	15.6	-3.9	8.7	310	0.625

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	5.9	32.0	N/A	30.3	N/A	28.9	N/A	N/A	N/A	N/A	N/A	N/A	N/A	6.4	280

Dehumidification DP/MCDB and HR

0.4%			1%			2%			0.4%		1%		2%		Extreme Max WB
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a) N/A	(b) N/A	(c) N/A	(d) N/A	(e) N/A	(f) N/A	(g) N/A	(h) N/A	(i) N/A	(j) N/A	(k) N/A	(l) N/A	(m) N/A	(n) N/A	(o) N/A	

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	(q)
14.5	12.5	11.2	DB	-12.9	34.3	2.9	1.2	-14.9	35.2	-16.6	35.8	-18.2	36.5	-20.3	37.4	
			WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	

Monthly Climatic Design Conditions

		Annual													
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	(q)
Temperatures, Degree-Days and Degree-Hours	DBAvg	12.9	0.5	1.6	5.2	11.3	16.6	21.5	25.0	23.6	20.3	14.8	8.6	4.5	
	DBStd	9.24	5.32	4.79	4.47	4.14	3.83	3.43	2.58	2.04	2.95	3.76	4.01	4.65	
	HDD10.0	985	297	239	159	31	1	0	0	0	0	6	73	180	
	HDD18.3	2587	553	469	407	215	80	9	0	0	13	119	293	428	
	CDD10.0	2027	2	3	11	69	207	346	464	421	310	156	30	9	
	CDD18.3	589	0	0	0	4	28	106	206	162	73	11	0	0	
	CDH23.3	3512	0	1	0	29	144	621	1557	857	268	35	0	0	
	CDH26.7	913	0	0	0	8	30	191	498	146	34	7	0	0	
Wind	WSAvg	5.7	6.1	6.3	6.5	6.3	5.4	5.2	4.9	4.8	5.2	6.0	5.8	5.9	
Precipitation	PrecAvg	1168	90	72	106	94	93	104	105	118	98	99	85	103	
	PrecMax	1697	181	142	274	290	197	239	220	444	232	345	159	174	
	PrecMin	900	40	13	20	33	26	7	14	22	28	9	23	21	
	PrecStd	179	33	34	54	54	36	54	52	79	55	71	38	36	
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	15.9	17.4	20.2	27.4	29.7	33.7	34.5	31.7	29.8	26.8	19.7	19.5	
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
	2%	DB	12.8	12.9	16.1	22.6	27.2	30.9	32.8	29.8	27.6	23.6	17.6	15.3	
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
	5%	DB	10.1	10.0	13.8	19.5	24.7	28.9	31.2	28.4	26.1	21.4	15.9	13.4	
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
	10%	DB	7.8	7.6	11.4	17.0	22.4	26.8	29.6	27.0	24.9	20.1	14.6	11.3	
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
	2%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
	5%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
	10%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
Mean Daily Temperature Range	5% DB	MDBR	6.2	6.6	6.4	6.9	6.6	6.1	5.9	5.2	5.5	5.9	6.0	5.3	
		MCDBR	9.5	9.7	9.8	10.5	9.9	9.0	8.2	7.2	7.0	7.5	7.7	7.5	
		MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
	5% WB	MCDBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
		MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
Clear-Sky Solar Irradiance	taub	0.313	0.325	0.358	0.381	0.427	0.485	0.487	0.474	0.399	0.360	0.330	0.313		
	taud	2.469	2.437	2.404	2.372	2.272	2.147	2.154	2.183	2.365	2.484	2.526	2.529		
	Ebn at Noon	847	889	893	892	854	802	796	795	839	838	823	821		
	Edh at Noon	77	92	106	118	133	151	149	141	110	88	73	68		
All-Sky Solar Radiation	RadAvg	1.87	2.77	3.74	4.81	5.33	5.86	5.97	5.20	4.32	3.01	2.11	1.60		
	RadStd	0.16	0.28	0.31	0.47	0.56	0.54	0.29	0.34	0.42	0.30	0.18	0.15		

Historical Trends

	DBAvg	Heating			Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP		HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (62 neighbors)	+0.40	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+116	+68

Nomenclature: See separate page