

COVE POINT LNG PIER, MD, USA

WMO: 997781

Lat: 38.402N

Lon: 76.385W

Elev: 7

StdP: 14.69

Time Zone: -5.00 (NAE)

Period: 06-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	17.2	21.5	N/A	N/A	N/A	N/A	N/A	N/A	34.5	26.4	32.3	28.6	17.5	330	0.570

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	9.2	88.7	N/A	86.2	N/A	84.1	N/A	N/A	N/A	N/A	N/A	N/A	N/A	9.6	220

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
30.6	26.5	23.8	DB	14.0	95.2	5.5	2.8	10.1	97.2	6.8	98.9	3.7	100.5	-0.3	102.5	
			WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	58.2	36.2	38.0	44.3	56.1	66.0	74.7	78.7	76.9	71.6	61.4	49.4	43.6
	DBStd	16.42	9.13	8.87	8.20	7.65	6.51	5.14	4.00	3.55	4.90	7.01	7.16	8.08
	HDD50	1364	438	349	216	26	0	0	0	0	0	6	97	232
	HDD65	3935	892	756	640	284	68	3	0	0	6	153	470	663
	CDD50	4351	11	13	40	209	495	740	890	835	647	359	78	34
	CDD65	1446	0	0	0	17	99	293	425	370	202	40	0	0
	CDH74	9466	0	1	3	107	347	1777	3651	2637	857	86	0	0
	CDH80	1957	0	0	0	21	63	376	947	453	91	6	0	0
Wind	WSAvg	11.7	12.4	12.5	13.1	12.5	11.5	10.7	9.8	9.9	11.1	12.5	12.9	11.6
Precipitation	PrecAvg	43.4	3.5	3.3	4.0	3.1	4.1	3.6	4.1	3.7	4.1	3.1	3.1	3.4
	PrecMax	58.7	6.9	6.6	10.4	8.2	11.0	7.4	18.5	9.3	9.4	6.6	6.9	7.5
	PrecMin	32.0	0.5	0.3	0.9	0.4	0.6	0.9	0.8	0.8	0.1	0.0	0.4	0.5
	PrecStd	8.0	1.6	1.5	2.2	1.7	2.2	1.9	3.2	2.4	2.4	1.8	1.7	2.0
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	66.2	69.0	71.5	83.0	85.8	91.0	94.5	90.5	86.5	80.4	69.7	69.7
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	2%	DB	59.8	60.7	65.9	76.8	81.1	86.6	89.7	86.3	82.5	76.2	65.4	63.9
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5%	DB	52.9	54.4	60.2	71.3	77.6	84.0	86.9	84.1	80.3	73.7	61.8	58.7
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	DB	48.0	48.5	55.5	66.4	74.9	81.8	84.6	82.4	78.5	71.1	59.4	54.7
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	2%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Mean Daily Temperature Range	5% DB	MDBR	10.7	11.1	10.9	12.1	10.7	9.5	9.2	8.5	8.2	9.3	9.5	9.6
		MCDBR	18.7	20.8	19.4	19.0	14.0	12.4	12.3	10.8	9.5	11.6	13.0	15.9
		MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5% WB	MCDBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	Clear-Sky Solar Irradiance	taub	0.311	0.320	0.355	0.395	0.436	0.487	0.517	0.508	0.412	0.360	0.326	0.312
taud		2.505	2.474	2.422	2.327	2.243	2.150	2.079	2.088	2.334	2.481	2.536	2.543	
Ebn at Noon		276	289	287	280	269	255	246	245	265	270	269	268	
Edh at Noon		25	29	34	39	44	48	51	49	36	29	24	23	
All-Sky Solar Radiation	RadAvg	695	958	1278	1614	1836	2020	1963	1756	1421	1078	786	612	
	RadStd	52	101	107	115	208	151	94	98	145	117	68	54	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
Station Only	(d) N/A	(e) N/A	(f) N/A	(g) N/A	(h) N/A	(i) N/A	(j) N/A	(k) N/A	(l) N/A	(m) N/A
Regional (82 neighbors)	+0.81	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+257	+158

Nomenclature: See separate page