

PELLICER CREEK, FL, USA

WMO: 998000

Lat: 29.6577N

Lon: 81.2328W

Elev: 13

StdP: 14.69

Time Zone: -5.00 (NAE)

Period: 07-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) 33.6	(c) 37.7	(d) 19.9	(e) 15.0	(f) 41.0	(g) 25.6	(h) 19.6	(i) 45.6	(j) 20.0	(k) 49.5	(l) 17.9	(m) 50.2	(n) 3.2	(o) 270	(p) 0.313

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a) 8	(b) 13.0	(c) 91.2	(d) 79.2	(e) 89.2	(f) 78.8	(g) 87.5	(h) 78.8	(i) 85.8	(j) 86.2	(k) 82.8	(l) 83.9	(m) 80.4	(n) 84.4	(o) 5.2	(p) 260

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
85.8	189.2	86.1	82.6	170.3	83.1	79.3	152.3	82.0	50.1	85.8	46.6	83.9	43.9	84.9	95.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%		2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		
Min		Max		Min	Max		Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)		(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
16.7	14.2	12.2	DB	28.8	95.2	3.0	1.1	26.7	96.0	24.9	96.7	23.3	97.3	21.1	98.1	
			WB	25.0	82.9	3.8	4.7	22.3	86.3	20.1	89.1	17.9	91.8	15.2	95.2	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	69.9	55.9	59.5	62.1	69.2	74.5	79.1	80.3	80.7	78.7	72.6	64.5	60.6	(6)
	DBStd	10.49	8.59	8.72	7.34	4.97	3.89	2.61	2.15	2.02	2.43	5.94	7.60	8.06	(7)
	HDD50	87	41	21	7	0	0	0	0	0	0	0	2	16	(8)
	HDD65	941	301	192	140	19	0	0	0	0	0	15	99	175	(9)
	CDD50	7335	223	286	383	575	759	874	939	952	862	700	437	345	(10)
	CDD65	2714	18	37	50	144	295	424	474	487	412	250	84	39	(11)
	CDH74	21658	54	143	236	694	2000	3746	4345	4622	3753	1672	282	111	(12)
	CDH80	6004	2	18	35	92	356	1220	1544	1563	922	218	28	6	(13)
(14) Wind	WSAvg	5.2	5.2	4.9	5.6	5.7	6.0	4.6	4.1	4.5	5.6	5.6	5.9	5.0	(14)
(15) Precipitation	PrecAvg	51.6	2.8	2.9	3.7	2.4	2.9	7.0	5.7	6.5	8.3	4.6	2.3	2.5	(15)
	PrecMax	66.8	7.6	8.9	9.1	8.0	7.2	10.9	10.4	11.5	15.8	11.1	6.1	9.8	(16)
	PrecMin	33.5	1.0	0.9	0.1	0.4	0.8	0.6	2.1	2.8	1.6	0.6	0.3	0.4	(17)
	PrecStd	9.0	1.7	2.1	2.5	1.9	1.9	2.5	2.2	2.3	4.2	2.8	1.5	2.4	(18)
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	79.0	82.9	84.2	86.2	90.4	93.5	92.9	93.0	90.2	87.3	83.4	80.7	(19)
		MCWB	72.3	71.3	68.6	72.0	75.3	79.7	80.0	78.8	80.0	75.8	74.0	71.3	(20)
	2%	DB	75.1	78.4	79.8	82.9	86.4	90.5	90.7	90.2	87.1	84.1	79.8	77.1	(21)
		MCWB	68.3	68.8	67.6	71.1	74.6	79.3	79.2	79.3	77.7	75.9	73.1	69.9	(22)
	5%	DB	71.5	74.7	76.3	80.0	83.2	87.9	88.6	88.3	85.7	82.3	77.2	74.2	(23)
		MCWB	65.7	68.6	67.5	71.3	75.0	78.8	79.4	79.5	77.7	75.1	71.9	68.3	(24)
	10%	DB	68.5	71.2	73.3	78.0	81.5	86.1	86.8	86.8	84.5	80.8	75.0	71.4	(25)
		MCWB	64.4	66.3	66.0	70.4	74.0	78.5	79.3	79.5	77.3	73.9	69.1	67.0	(26)
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	73.0	76.0	73.4	78.5	83.7	88.4	89.2	88.0	86.5	79.2	77.1	72.9	(27)
		MCDB	74.8	76.5	75.8	78.8	86.7	88.6	89.2	88.2	87.0	83.1	80.1	78.4	(28)
	2%	WB	69.0	71.0	70.5	75.1	78.2	84.1	85.2	84.8	82.3	77.8	75.3	71.0	(29)
		MCDB	72.9	75.4	75.8	79.3	81.5	84.7	85.5	84.9	82.8	82.2	78.8	75.4	(30)
	5%	WB	67.3	69.3	69.0	73.3	76.2	80.4	80.9	81.2	80.0	76.6	72.9	69.4	(31)
		MCDB	71.0	73.3	74.1	77.4	80.5	84.6	84.8	84.9	82.9	80.9	75.9	72.5	(32)
	10%	WB	65.3	67.7	67.5	71.7	75.0	78.7	79.4	80.0	78.4	75.3	70.5	68.0	(33)
		MCDB	68.2	70.8	72.2	76.1	79.7	84.7	85.4	84.9	82.7	79.2	73.7	71.1	(34)
(35) Mean Daily Temperature Range	5% DB	MDBR	16.8	16.4	16.9	15.5	13.5	14.3	14.0	13.0	11.2	13.3	14.0	16.0	(35)
		MCDBR	18.6	18.1	20.5	18.1	16.3	17.1	16.6	15.6	13.5	13.0	14.5	17.4	(36)
		MCWBR	12.0	10.6	10.7	9.6	8.0	8.5	8.1	7.4	6.5	6.6	8.5	11.0	(37)
	5% WB	MCDBR	16.7	16.1	17.2	15.5	13.7	15.4	15.0	13.6	11.3	11.6	11.0	15.6	(38)
		MCWBR	11.6	10.9	10.8	9.9	8.2	11.3	10.9	9.7	7.4	6.1	6.7	10.7	(39)
(40) Clear-Sky Solar Irradiance	taub		0.339	0.352	0.371	0.395	0.431	0.464	0.491	0.477	0.426	0.397	0.361	0.346	(40)
	taud		2.540	2.511	2.458	2.370	2.316	2.289	2.219	2.267	2.401	2.453	2.499	2.541	(41)
	Ebn at Noon		285	290	291	285	274	263	256	259	270	271	274	277	(42)
	Edh at Noon		28	31	35	39	42	43	45	43	36	32	29	27	(43)
(44) All-Sky Solar Radiation	RadAvg		1013	1220	1590	1937	2040	1895	1876	1767	1534	1354	1092	924	(44)
	RadStd		76	117	134	115	134	160	113	118	122	106	64	79	(45)

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (35 neighbors)	+0.79	N/A	N/A	N/A	N/A	N/A	-14	-104	+288	+211

Nomenclature: See separate page