

OYSTER LANDING, SC, USA

WMO: 998005

Lat: 33.3494N

Lon: 79.1889W

Elev: 13

StdP: 14.69

Time Zone: -5.00 (NAE)

Period: 07-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	26.7	30.2	6.9	7.9	30.2	13.7	11.0	34.7	22.3	60.6	19.0	57.0	5.8	320	0.415

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	11.2	91.1	78.3	89.2	78.3	87.1	77.7	81.1	86.9	80.2	85.6	79.4	84.5	9.5	250

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
79.7	154.2	84.5	78.6	148.3	83.4	77.9	144.8	82.7	44.6	86.9	43.6	85.7	42.8	84.5	84.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
(a)	(b)	(c)	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
20.3	18.0	16.2	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
			22.6	95.2	4.1	2.0	19.7	96.7	17.2	97.9	14.9	99.0	11.9	100.5
			19.3	83.0	3.8	1.2	16.6	83.8	14.3	84.5	12.2	85.2	9.4	86.0
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	65.0	47.2	50.9	55.1	64.3	72.0	78.7	80.5	79.6	75.3	66.4	56.0	53.0	(6)
(7)		DBStd	13.55	9.73	9.02	8.36	6.36	5.54	4.03	3.07	3.22	4.29	6.85	8.00	9.26	(7)
(8)		HDD50	418	173	91	47	1	0	0	0	0	1	32	73	(8)	
(9)		HDD65	2108	554	399	320	88	12	0	0	1	67	284	383	(9)	
(10)		CDD50	5892	86	116	205	430	684	862	944	916	760	510	212	167	(10)
(11)		CDD65	2105	1	5	12	66	230	412	479	451	311	111	15	12	(11)
(12)		CDH74	17587	2	9	43	193	1263	3865	4946	4378	2356	491	24	17	(12)
(13)		CDH80	4598	0	0	6	10	250	1125	1516	1213	433	45	0	0	(13)
(14)	Wind	WSAvg	7.5	6.8	7.6	8.3	8.8	8.8	7.9	7.7	6.6	7.3	7.1	6.9	6.5	(14)
(15)	Precipitation	PrecAvg	55.5	4.2	3.5	4.3	2.7	4.0	5.9	7.0	7.0	5.9	4.3	2.8	3.6	(15)
(16)		PrecMax	74.3	10.7	12.5	12.8	8.0	9.5	12.0	15.7	19.5	17.3	13.1	11.7	10.4	(16)
(17)		PrecMin	36.6	0.4	0.6	0.8	0.0	0.6	1.4	0.1	1.0	0.6	0.0	0.0	0.7	(17)
(18)		PrecStd	10.5	2.3	2.4	2.4	2.0	2.5	2.5	3.4	4.5	4.4	3.7	2.3	2.1	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	72.8	75.2	79.6	81.4	91.4	94.0	93.6	92.8	88.7	84.2	77.3	76.5	(19)
(20)		0.4%	MCWB	66.0	65.8	62.7	68.1	74.0	77.9	78.5	79.2	76.9	74.6	69.7	70.2	(20)
(21)		2%	DB	68.1	71.2	74.0	78.4	85.8	90.6	90.7	90.0	85.9	80.9	73.5	73.3	(21)
(22)		2%	MCWB	63.0	63.5	63.5	68.4	73.6	77.8	79.4	78.7	77.0	72.8	67.3	68.5	(22)
(23)		5%	DB	64.9	67.8	70.7	76.5	82.2	88.3	88.8	87.5	84.1	78.9	70.9	70.2	(23)
(24)		5%	MCWB	61.0	62.4	62.9	67.7	72.6	77.5	79.1	78.3	76.1	72.2	66.7	67.4	(24)
(25)		10%	DB	61.4	64.8	67.6	74.1	79.9	86.0	86.7	85.4	82.5	76.9	68.4	67.2	(25)
(26)		10%	MCWB	57.7	60.5	62.0	66.6	72.4	77.0	78.4	77.9	75.6	71.1	64.3	64.7	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	67.9	68.3	68.7	73.8	78.5	81.7	82.9	82.3	80.2	78.0	72.3	73.2	(27)
(28)		0.4%	MCDWB	70.7	72.6	73.4	77.0	83.5	89.5	88.7	87.9	84.2	81.7	75.0	74.7	(28)
(29)		2%	WB	65.0	66.4	66.6	71.6	76.0	80.1	81.4	80.8	79.0	76.2	70.0	70.6	(29)
(30)		2%	MCDWB	67.5	69.9	70.7	75.3	81.1	86.9	87.1	86.0	82.8	79.2	71.9	71.9	(30)
(31)		5%	WB	62.4	64.2	65.0	70.2	74.7	79.1	80.3	79.9	78.1	74.5	67.9	67.8	(31)
(32)		5%	MCDWB	64.4	66.8	68.9	73.8	79.6	85.2	85.7	84.9	81.9	77.4	70.1	69.7	(32)
(33)		10%	WB	58.9	61.4	62.9	68.8	73.4	78.1	79.4	79.0	77.2	72.5	65.1	64.8	(33)
(34)		10%	MCDWB	60.7	64.1	66.7	72.4	78.3	83.7	84.6	83.7	81.1	75.4	68.1	67.4	(34)
(35)	Mean Daily Temperature Range		MDBR	15.8	15.7	15.5	14.0	11.9	12.0	11.2	10.5	11.2	14.1	15.7	15.7	(35)
(36)		5% DB	MCDBR	18.5	18.2	18.8	15.8	15.2	14.9	14.1	13.3	12.2	14.6	16.0	16.4	(36)
(37)			MCWBR	14.0	12.3	11.1	8.3	7.0	6.7	6.4	5.8	5.6	8.1	11.1	12.1	(37)
(38)			MCDBR	15.8	16.3	15.6	12.5	12.4	13.7	13.0	11.8	10.0	11.6	14.1	15.1	(38)
(39)		5% WB	MCWBR	14.8	12.9	11.3	8.1	6.5	6.8	6.5	5.8	5.3	8.2	11.8	12.2	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.330	0.338	0.367	0.401	0.467	0.485	0.531	0.506	0.433	0.393	0.351	0.332	(40)	
(41)		taud	2.524	2.503	2.442	2.325	2.196	2.193	2.080	2.145	2.344	2.427	2.503	2.549	(41)	
(42)		Ebn at Noon	281	291	289	282	263	257	245	249	264	267	271	274	(42)	
(43)		Edh at Noon	27	30	35	40	46	47	52	48	38	32	27	25	(43)	
(44)	All-Sky Solar Radiation	RadAvg	878	1088	1459	1866	2021	2067	1969	1769	1510	1279	979	784	(44)	
(45)		RadStd	55	110	133	127	140	140	121	99	120	137	73	61	(45)	

Historical Trends

		Heating		Cooling			Degree-Days					
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(46)
(47)	Regional (43 neighbors)	+0.99	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+346	+245	(47)

Nomenclature: See separate page