

STORM WATER POLLUTION PREVENTION PLAN (SWPPP)

Harrison Avenue Mixed-Use Development

WDID No.: 5S36C401234

Risk Level: Level 2

QSP of Record: Maria Delgado, QSD/QSP Cert. No. 27841

Total Disturbed Area: 4.7 acres

Section 5 — Best Management Practices Schedule

The following BMPs shall be installed and maintained for the duration of construction in accordance with the CGP 2022 (Order WQ 2022-0057-DWQ).

BMP Code	BMP Name	Category	Required Locations	Inspection Frequency	Maintenance Threshold
EC-1	Scheduling	Erosion Control	Entire site	Weekly	Revise schedule when rain forecast exceeds 50%
EC-7	Geotextiles & Mats	Erosion Control	North slope; East embankment	Weekly, Pre-Storm	Replace when fabric is torn or displaced more than 6 inches
SE-1	Silt Fence	Sediment Control	North perimeter; West property line	Weekly, Post-Storm	Repair when accumulated sediment reaches 1/3 of fence height
SE-5	Fiber Rolls	Sediment Control	South slope contours at 20 ft intervals	Weekly	Replace when sediment reaches 1/2 roll height or roll is displaced
SE-10	Storm Drain Inlet Protection	Sediment Control	All 4 on-site inlets; Main St inlet	Weekly, Pre-Storm, Post-Storm	Clean when sediment accumulation reaches 1/3 of device capacity
TC-1	Stabilized Construction Entrance	Tracking Control	Main gate on Harrison Ave	Weekly	Add rock when voids fill with sediment or tracking is observed offsite
WE-1	Wind Erosion Control	Wind Erosion	Exposed stockpiles; haul roads	Weekly	Apply water when visible dust leaves the site boundary
WM-1	Material Delivery and Storage	Materials Management	Laydown yard, NE corner	Weekly	Cover and berm within 24 hours of delivery
WM-4	Spill Prevention and Control	Materials Management	Fueling area; equipment yard	Weekly	Deploy spill kit immediately; report spills over 5 gallons
NS-1	Water Conservation Practices	Non-Storm Water	All active work areas	Weekly	Repair leaking equipment within 48 hours of discovery

Section 6 — Spill Response

Spill kits shall be maintained at the fueling area and the equipment yard. Any spill exceeding 5 gallons shall be reported to the QSP immediately and to the State Water Board within 24 hours.