STANDARD OPERATING PROCEDURE: PUMP-402
Document ID: SOP-PUMP-402-REV3
Equipment: Industrial Centrifugal Feed Pump

1. Lubrication Protocol:
- Grease levels must be inspected every 120 operating hours.
- Use only synthetic ISO VG 68 lubricant for bearing housings.
- Avoid overfilling lubricant reservoir above the max sight-glass level.

2. Vibration and Temperature Thresholds:
- Normal operating vibration: < 3.5 mm/s RMS.
- Warning vibration threshold: 4.5 mm/s RMS.
- Maximum allowable RMS vibration before trip is 4.5 mm/s. If vibration exceeds 5.0 mm/s, immediately trip the e
- Drive end bearing temperature must not exceed 75°C under continuous load.