AIVOA PHARMACEUTICALS MANUFACTURING CORP.
GLOBAL QUALITY OPERATIONS & COMPLIANCE DIVISION

PHARMACEUTICAL API QUALITY DEVIATION & INVESTIGATION REPORT

Deviation Number:	DEV-2026-0914	**Classification:**	Major / Critical Quality Attribute (CQA)
Product / API Name:	Losartan Potassium API (USP Grade)	**Batch / Lot Number:**	LSP-2026-042
Manufacturing Stage:	Stage 5: Final Rotary Vacuum Paddle Drying	**Equipment Tag:**	Paddle Dryer RVPD-01 / Condenser COND-02
Date of Occurrence:	2026-10-21 04:30 UTC	**Date of Discovery:**	2026-10-22 11:00 UTC
Material / Lot ID:	Dichloromethane Pure RAW-DCM-882	**Reporting Unit:**	QC Organic Volatile Impurities Lab

1. OBSERVED DEVIATION & ANALYTICAL TEST RESULTS

Test Parameter	Regulatory Specification	Observed Lab Result	Test Methodology / Instrument
Residual Methylene Chloride (DCM)	**NMT 600 ppm (ICH Q3C Class 2)**	**840 ppm [OOS]**	Headspace Gas Chromatography GC-FID-04
Residual Acetone	NMT 5000 ppm	1200 ppm	Headspace GC-FID
Assay (Potassium Basis)	98.5% - 101.5%	99.8%	Potentiometric Titration
Heavy Metals	NMT 10 ppm	< 5 ppm	ICP-OES

2. INCIDENT CHRONOLOGY & FORENSIC NARRATIVE

Residual solvent testing by headspace GC-FID on Losartan Potassium batch LSP-2026-042 showed dichloromethane at 840 ppm, exceeding the ICH Q3C threshold of 600 ppm. Investigation into RVPD-01 identified that secondary vacuum condenser glycol chiller tripped offline at 04:30 UTC due to high head pressure. Exhaust gas condensation efficiency collapsed from 96% to 42%, preventing complete desolvation.

3. IMMEDIATE CONTAINMENT ACTIONS TAKEN

1. Batch LSP-2026-042 (850 kg) quarantined in double poly-lined drums.
2. Chiller unit CHL-02 compressor reset and scheduled for immediate freon leak inspection.
3. Re-drying protocol feasibility assessment initiated by Process Tech Transfer.

Prepared by:	D. Chen (QC Specialist)	2026-10-22
Verified by:	K. Kowalski (Plant Ops)	2026-10-22
QA Approval:	Dr. E. Gomez (Quality Assurance)	**Status: PENDING ROOT CAUSE ANALYSIS**