

Fuzzy Logic and PID Implementation for Maintains PH Value on Hydroponics Assistant Based on IoT

Eki Kesuma Muhammad* and M. Nurkamal Fauzan

Applied Bachelor Program of Informatics Engineering

Jalan Sariasih No.54, Sarijadi, Sukasari, Kota Bandung, Jawa Barat 40151

*Eki Kesuma, e-mail: kesumaeki1@gmail.com

Abstract

Hydroponics is a method of planting crops through a medium of water that can live indoors or outdoors, hydroponics plants using NFT techniques (Nutrient Film Technique), where water and nutrients can circulate through plant roots. PH is the measurement of nutrient solution in acid or base state. Water pH can affect plant growth rates in hydroponic cultivation. PH cannot survive the stable value required for plant growth. In the previous study PH with value 8 make the plant dead. This research aims to design PH control using acid and base buffer solution. The PID method is the feedback mechanism control and minimizes the error value as setpoint and Fuzzy Logic used to maintain PH at values between 5.6 - 5.7. This model is used for PH in water to survive on good grades for plants. Observations show high PH values can damage plant growth. This research is used to maintain PH at the value of 5.6-5.7 for plant growth using PID and Fuzzy Logic method.

Keywords: NFT, Hidroponics, PID, Fuzzy Logic, and PH

Copyright © 2013 Universitas Ahmad Dahlan. All rights reserved.

1. Introduction

The global population is estimated at 9 billion by 2050, mostly urban dwellers, requiring an increase in agricultural productivity by 70%.[1] Villagers moving from rural to sustainable cities are expected to encourage the expansion of urban landscapes and accelerate the loss of cultivated land around the city. Coupled with land degradation and loss of soil fertility.[2] The rate of population growth in the city of Bandung according to the Central Bureau of Statistics is currently 0.37%-0.71% per year, in 2016 the population reached 2,490,622 Souls. Therefore the agricultural land in the city of Bandung decreased, from data on the number of agricultural businesses in Bandung has decreased to 34,803.00 Ha by 2015.[3] While agriculture is considered an important part of life for human beings because it is a fundamental source Of food, other raw materials to meet the needs.[4] Agriculture provides the most important commodities needed to meet the needs. A number of vegetables, fruits, nuts and spices all continue to be cultivated with a variety of techniques.[5] Hydroponic techniques have the type to overcome land problems in urban areas, one of which is NFT (Nutrient Film Techniques) that can be arranged vertically.[6] Hydroponics is a widely used and often used the technique for growing plants without soil, providing considerable control over the elemental environment around roots,[7] and is a plant growth system that provides more precise control over composition growth media.[8] Ease of system setup, cost of system growth and flexibility to characterize and crop material harvests continue to be improved in hydroponic systems.[9] Hydroponics uses nutrients as a solution that provides all the essential nutrients for plant development. Hydroponics can be controlled by utilizing the Internet of Things (IoT) or known by machines to machines referring to various devices (things) such as sensors, actuators and other devices.[10] This tool can generate, receive, convey information, through wired or wireless communications between the same or different devices of information to the internet.[11] In the IoT-based hydroponic development using PH, sensors are used to read the degree of acidity in water.[12]

The pH values are some very important chemical parameters.[13] Plants lose the ability to absorb different nutrients when the pH has different values. Plants have a certain pH that is optimal for them, generally, Although most plants prefer slightly acid growing around the environment. PH control is an important process because a small change of input gives a big change in output.[14] At the time of testing the PH sensor on the hydroponic plant the PH value reached 8 causing the plant to die and Research of Gent, Martin pH with a value below 4 has a negative effect on the plant [15] while according to research M Agus showed that the exact PH value for the plant values of 5.7-5.9, [16] and in Henrique's control the pH to an acceptable range of 5.5-6.5.[17]

So the purpose of this paper is to maintain the plant PH at the value of 5.6-5.7 using the PID method to obtain the value of 5.6-5.7 to maintain the PH, [18] and the Fuzzy method is used for the delay of giving acidic or alkaline solutions to water in hydroponics.[19] The results of the source code are uploaded to GitHub to allow users to interact or collaborate in code reviews. [20]

2. Related Works

Research of Oluwayesi Proportional-Integral-Plus (PIP) controller for optimal results based on the State-Model Dependent Parameter (SDP) was developed to control the nonlinear and variation of time that greatly varies the process of neutralization pH Since the pH invariant process is not available.[21] The pH control process involves a prototype model in which acid and base streams are mixed into a Continuous Stirring Reactor.[22] pH requires state measurement for plant implementation.[23] Measurement of pH control is very useful in different applications such as agriculture, food processing, biochemical processes and industrial applications. [24] The control objective is to regulate the pH of the outward neutral solution, by manipulating the flow of the basic solution, (NaOH), mixed with the acid solution, (HNO₃), compensating for the possibility of changes in the buffer stream, (NaHCO₃), which is considered an unmeasurable disturbance.[25] Strong neutralized neutralization control process simulation has been performed, and good control performance is achieved.[26] The ph-process system was developed adequately in terms of the supposed application of designing a better form of controller. the general method for obtaining dynamic equations for the neutralization process of PH in a continuous stirred tank, some point appears in developing neutralization of PH.[27] In maintaining the pH size constantly with the default rate on industrial processes. There is a difference in classification for the pH process. As we know the acid is divided into two groups, weak or strong, so a categorization based on the weakness or strength of the acid has been used and the other one is on the output current.[28] It is important to treat these chemical wastes to acceptable pH levels, i.e., the ideal PH is in the number 7. We propose pH 5-11 as the optimum pH range for the processing, reuse, and disposal of ash samples.[29] At the plant the neutralizing process of pH is used to neutralize chemical waste products that may arise as a result of some manufacturing process before releasing them to the environment. This is primarily to protect the environment by making safe-running water for marine and agricultural applications, and by avoiding damage to corrosion-related infrastructure.[30] For direct measurements in different literature, models have been presented to illustrate the dynamic behaviour of ph processes with batch type models.[31] A PH neutralization is required to exhibit highly nonlinear behaviour and its control is challenging in the hydroponic process and can not be controlled effectively with a conventional PI controller. [32] The heavy nonlinear presence in the neutralization process of pH makes the problem of pH control difficult and challenging. Furthermore, the optimum control is very nonlinear. The system requires setting up various parameters with appropriate evolutionary algorithms (EA). This paper presents an unlimited, continuous and single genetic algorithm (GA).[33] From the idea of S. Tu PH (4.5 - 8.0) is used to understand individual and interactive effects. plants and P and As uptake are influenced by these factors. Phosphorus is inhibited As the uptake at all for the Fern crop has a PH value of 5.87.[34] Adjustment to PH was performed using 1 mol / L KOH or 1 mol / L HNO₃. [35]

The fuzzy system in general basically consists of four components: membership function (fuzzification), fuzzy rule base, defuzzification and fuzzy output. In fuzzification, numerical input and output variables are converted into linguistic or adjective terms, and the corresponding degree of one or more of several membership functions is determined.[36] Fuzzy Logic is used to control

the process of pH (Non-linear process). Fuzzy refers to the fact that the logic involved can deal with concepts partially true.[37] In the pH process, the pH sensor is immersed in water.[37] In previous research the fuzzy system was used to model and control complex nonlinear systems for their excellent ability to approximate nonlinear systems.[38] Fuzzy PID controller tunes PID three parameters with a fuzzy controller. Note the oil temperature error e and the error change rate PH as the input variable, and K_p (proportional gain correction), K_i (integral gain correction), K_d (gain correction derivative), which adjusts the parameter value of PID, as the output variable. Thus the overall fuzzy controller is two input systems and three outputs.[39] On the other hand, when applied to field-adjusted PIDs, which are the result of standard sites.[40] Fuzzy Logic Controller allows designers to design and build controllers by forming statements of IF-THEN in the form of statements. The Fuzzy Logic Controller structure contains four main sections as follows: Fuzzification, inference mechanisms, ground rules and defuzzification, in which the fuzzification section is used to convert real input to fuzzy input.[41] A standard fuzzy PID controller, which is formed using a PID fuzzy controller with an integrator and an addition unit at the output.[42] Many PID controllers based on nonlinear optimization are also proposed for various applications.[43] Proposed modified genetic algorithm for optimizing parameters of multi-objective PID controller and Testing it in revolving pendulum system.[44] To test the performance of fuzzy controllers such as PID, both simulations and experiments of various aqueous acid solutions showing buffer conditions comprising acetic acid and propionate neutralized in a single CSTR with sodium hydroxide having molar concentration $[\text{NaOH}] = 0.2 \text{ Mol / L}$. [45] For that process with large delay, nonlinearity, etc, it's not easy for conventional PID to achieve the desired performance. The Fuzzy Controller adjustment does not rely on an accurate mathematical model and has a major advantage in solving uncertainty.[46] To build a digital control system model with a fuzzy PID controller in the SIMULINK modelling package, we will transfer from the Sources sub-category to the two-block model window. Constant and one Step block, generating the unit step function; Mathematical Operations - Sum comparison blocks and two Gain blocks.[18] Fuzzy Logic is used to control the process of pH (Non-linear process). The term fuzzy cannot be expressed as "true" or "false" but as "partially true".[19] The input of the fuzzy PID controller is the error e and the pH level change error, after the fuzzy, output, K_p , and K_d processing that make the PID controller adjust its own parameters according to the error and error rate different from the system.[47] [48]

In the previous study PH with value 8 make the plant dead. This research aims to design PH control using acid and base buffer solution. Methods in journals that prior to only use one method to maintain the value of PH is the method of PID. This research combines two methods namely PID method which is control mechanism of feedback and minimizes error value as setpoint so that PH can survive at value 5,6 - 5,7 and Fuzzy Logic which is used to give time delay on tool not to do giving buffer solution repeatedly. This model is used for PH in water to survive on good grades for plants. Observations show high PH values can damage plant growth. This research is used to maintain PH at the value of 5.6-5.7 for plant growth using PID and Fuzzy Logic method.

3. Research Method

PID control has a simple structure, tuning parameters, and easier operation, but for controls cannot be better. The neutralization process PH has nonlinear, time lag, and other features to adjust the PID. PID control.[44] Research of Zhang, the control algorithm chosen for optimal PH is the PID controller.[25] We can guarantee the system to maintain the stability of PH. The PID control algorithm can be expressed as follows:[42]

$$u(t) = K_p + \left(e(t) + \frac{1}{T_i} \int e(t)dt + T_d \frac{de(t)}{dt} \right)$$

Atau

$$u(t) = K_p + \left(e(t) + K_i \int e(t)dt + K_d \frac{de(t)}{dt} \right)$$

$u(t)$ = signal output PID control

Kp= konstanta proporsional

Ti= Time integral

Td= Time derivative

Ki= Constanta integral

Kd= Constanta derivative

e(t) = Signal error

Thus, the PID control override function (in domain s) can be expressed as follows:[18]

$$G_c(s) = K_p + \frac{K_i}{s} + K_d(s)$$

So that the PH value of water can take a stable state. From the system, the acidity of the hydroponics can be shown as formula :

$$G_1(t)N_1 - [G_1(t) + G_2(t)]m_a = V \frac{dm_a}{dt} \quad (1)$$

The alkaline of the hydroponics can be shown as formula :

$$G_2(t)N_2 - [G_1(t) + G_2(t)]m_b = V \frac{dm_b}{dt} \quad (2)$$

According to the formula (1) and (2), the PH value of the dynamic control model can be expressed as formula :

$$G_1(t)N_1 - V \frac{dm_a}{dt} = [G_1(t) + u(t)]m_a \quad (3)$$

$$2(t)N_2 - V \frac{dm_b}{dt} = [G_1(t) + u(t)]m_b$$

Make the

$$y = m_a + m_b$$

, the PH value neutralization control model can be simplified as formula :

$$V \frac{dy}{dt} = (N_1 - y)G_1(t) + (N_2 + y)G_2(t) \quad (4)$$

the model may be approached as first orders inertia. The PH value of the neutralization control process is carried out in the aeration tank, while the aeration tank in the waste treatment process can enter the next processing stage.[43]




Figure 1 Membership Function of PH

Figure 1. Fuzzy Logic For PH

Fuzzy Logic is used to control the process of pH (Non-linear process). The term "fuzzy" refers to the fact that the logic involved can deal with concepts that can not be expressed as "true" or "false" but as "partially true". In the pH process, the pH sensor is immersed in a solution or a liquid whose pH must be measured. The Output of the pH sensor is in terms of Voltage (0-100

mV). This voltage is calibrated in terms of pH. The voltage of the pH sensor is given as input to the fuzzy controller. An appropriate membership function is selected, and the rule is formed within it. Membership functions are classified into values according to the process.[19] The rule of implication used in the fuzzy rule is IF error PH 'x mS / cm' and volume 'y litre' THEN activation pump 'z seconds. The proper pump activation time is expected to be the output that can sustain the PH of the acid and alkaline.

References

- [1] D. Touliatos, I. C. Dodd, and M. McAinsh, "Vertical farming increases lettuce yield per unit area compared to conventional horizontal hydroponics," *Food and energy security*, vol. 5, no. 3, pp. 184–191, 2016.
- [2] R. Gotor, P. Ashokkumar, M. Hecht, K. Keil, and K. Rurack, "Optical ph sensor covering the range from ph 0–14 compatible with mobile-device readout and based on a set of rationally designed indicator dyes," *Analytical chemistry*, vol. 89, no. 16, pp. 8437–8444, 2017.
- [3] BPS, "Statistik indonesia 2017 dalam infografis," 2017.
- [4] G. J. U. Ossa, C. G. Montoya, and M. A. V. Velázquez, "Control and monitoring of a stevia plantation in a hydroponic system," in *2017 IEEE 3rd Colombian Conference on Automatic Control (CCAC)*, Oct 2017, pp. 1–5.
- [5] R. Nalwade and T. Mote, "Hydroponics farming," in *2017 International Conference on Trends in Electronics and Informatics (ICEI)*, May 2017, pp. 645–650.
- [6] S. Umamaheswari, A. Preethi, E. Pravin, and R. Dhanusha, "Integrating scheduled hydroponic system," in *2016 IEEE International Conference on Advances in Computer Applications (ICACA)*, Oct 2016, pp. 333–337.
- [7] P. N. Crisnapati, I. N. K. Wardana, I. K. A. A. Aryanto, and A. Hermawan, "Hommons: Hydroponic management and monitoring system for an iot based nft farm using web technology," in *2017 5th International Conference on Cyber and IT Service Management (CITSM)*, Aug 2017, pp. 1–6.
- [8] J. Pitakphongmetha, N. Boonnam, S. Wongkoon, T. Horanont, D. Somkiadcharoen, and J. Prapakornpilai, "Internet of things for planting in smart farm hydroponics style," in *2016 International Computer Science and Engineering Conference (ICSEC)*, Dec 2016, pp. 1–5.
- [9] A. Pramuanjaroenkij, N. Dabut, S. Sutti, and A. Sanboon, "The study of turbulent nutrient solution flows in difference hydroponics system arrangements," in *Applied Mechanics and Materials*, vol. 866. Trans Tech Publ, 2017, pp. 88–91.
- [10] P. C. P. D. Silva and P. C. A. D. Silva, "Ipanera: An industry 4.0 based architecture for distributed soil-less food production systems," in *2016 Manufacturing Industrial Engineering Symposium (MIES)*, Oct 2016, pp. 1–5.
- [11] M. A. Triawan, H. Hindersah, D. Yolanda, and F. Hadiatna, "Internet of things using publish and subscribe method cloud-based application to nft-based hydroponic system," in *2016 6th International Conference on System Engineering and Technology (ICSET)*, Oct 2016, pp. 98–104.
- [12] R. F. B. Guimarães, R. do Nascimento, D. F. de Melo, J. G. Ramos, M. de Oliveira Pereira, J. A. F. Cardoso, and S. C. de Lima, "Production of hydroponic lettuce under different salt levels of nutritive solution," *Journal of Agricultural Science*, vol. 9, no. 11, p. 242, 2017.
- [13] D. S. Domingues, H. W. Takahashi, C. A. Camara, and S. L. Nixdorf, "Automated system developed to control ph and concentration of nutrient solution evaluated in hydroponic lettuce production," *Computers and Electronics in Agriculture*, vol. 84, pp. 53 – 61, 2012. [Online]. Available: <http://www.sciencedirect.com/science/article/pii/S0168169912000361>
- [14] L. Yang, A. Giannis, V. W.-C. Chang, B. Liu, J. Zhang, and J.-Y. Wang, "Application of hydroponic systems for the treatment of source-separated human urine," *Ecological Engineering*, vol. 81, pp. 182 – 191, 2015. [Online]. Available: <http://www.sciencedirect.com/science/article/pii/S0925857415001238>
- [15] M. P. Gent, "Factors affecting relative growth rate of lettuce and spinach in hydroponics in a greenhouse," *HortScience*, vol. 52, no. 12, pp. 1742–1747, 2017.

- [16] S. M. Schmöckel, D. J. Lightfoot, R. Razali, M. Tester, and D. E. Jarvis, "Identification of putative transmembrane proteins involved in salinity tolerance in chenopodium quinoa by integrating physiological data, rnaseq, and snp analyses," *Frontiers in plant science*, vol. 8, p. 1023, 2017.
- [17] H. J. A. Sánchez, "Wood ash as a nutrient supplement for cucumis sativus in an anthroponics system," 2016.
- [18] Y. Kudinov, V. Kolesnikov, F. Pashchenko, A. Pashchenko, and L. Papic, "Optimization of fuzzy pid controller's parameters," *Procedia Computer Science*, vol. 103, pp. 618 – 622, 2017, xII International Symposium Intelligent Systems 2016, INTELS 2016, 5-7 October 2016, Moscow, Russia. [Online]. Available: <http://www.sciencedirect.com/science/article/pii/S187705091730087X>
- [19] M. N. R. Ibrahim, M. Solahudin, and S. Widodo, "Control system for nutrient solution of nutrient film technique using fuzzy logic," *TELKOMNIKA (Telecommunication Computing Electronics and Control)*, vol. 13, no. 4, pp. 1281–1288, 2015.
- [20] A. Zakiah and M. N. Fauzan, "Collaborative learning model of software engineering using github for informatics student," in *2016 4th International Conference on Cyber and IT Service Management*, April 2016, pp. 1–5.
- [21] O. A. Ogun, M. U. Festus, and I. J. Inyang, "Optimal pip control of a ph neutralization process based on state-dependent parameter model," *IFAC-PapersOnLine*, vol. 50, no. 2, pp. 37 – 42, 2017, control Conference Africa CCA 2017. [Online]. Available: <http://www.sciencedirect.com/science/article/pii/S2405896317335383>
- [22] S. Harivardhagini and A. Raghuram, "Variable structure control of ph neutralization of a prototype waste water treatment plant using labview," in *2015 IEEE Conference on Systems, Process and Control (ICSPPC)*, Dec 2015, pp. 79–84.
- [23] A. Nejati, M. Shahrokhi, and A. Mehrabani, "Comparison between backstepping and input-output linearization techniques for ph process control," *Journal of Process Control*, vol. 22, no. 1, pp. 263 – 271, 2012. [Online]. Available: <http://www.sciencedirect.com/science/article/pii/S0959152411001703>
- [24] N. Akshay and D. Subbulekshmi, "Online auto selection of tuning methods and auto tuning pi controller in fopdt real time process-ph neutralization," *Energy Procedia*, vol. 117, pp. 1109 – 1116, 2017, first International Conference on Power Engineering Computing and CONTROL (PECCON-2017) 2nd -4th March .2017. Organized by School of Electrical Engineering, VIT University, Chennai, Tamil Nadu, India. [Online]. Available: <http://www.sciencedirect.com/science/article/pii/S1876610217324761>
- [25] W. I. Alama and I. A. Tabacchi, "Wiener predictive control for a ph neutralization plant," in *2017 CHILEAN Conference on Electrical, Electronics Engineering, Information and Communication Technologies (CHILECON)*, Oct 2017, pp. 1–7.
- [26] Z. Zou, D. Zhao, X. Liu, Y. Guo, C. Guan, W. Feng, and N. Guo, "Pole-placement self-tuning control of nonlinear hammerstein system and its application to ph process control," *Chinese Journal of Chemical Engineering*, vol. 23, no. 8, pp. 1364 – 1368, 2015. [Online]. Available: <http://www.sciencedirect.com/science/article/pii/S1004954115000853>
- [27] S. S. Ram, D. D. Kumar, B. Meenakshipriya, and K. Sundaravadivu, "Designing and comparison of controllers based on optimization techniques for ph neutralization process," in *2016 International Conference on Information Communication and Embedded Systems (ICICES)*, Feb 2016, pp. 1–5.
- [28] M. H. Dolatabadi, M. N. Monfared, and A. Fakharian, "Robust h-infinity control for the ph neutralization process based on fuzzy models," in *2013 13th Iranian Conference on Fuzzy Systems (IFSC)*, Aug 2013, pp. 1–6.
- [29] S. Tu and L. Ma, "Interactive effects of ph, arsenic and phosphorus on uptake of as and p and growth of the arsenic hyperaccumulator pteris vittata l. under hydroponic conditions," *Environmental and Experimental Botany*, vol. 50, no. 3, pp. 243 – 251, 2003. [Online]. Available: <http://www.sciencedirect.com/science/article/pii/S0098847203000406>
- [30] K. Bingi, R. Ibrahim, M. N. Karsiti, T. D. Chung, and S. M. Hassan, "Optimal pid control

- of ph neutralization plant,” in *2016 2nd IEEE International Symposium on Robotics and Manufacturing Automation (ROMA)*, Sept 2016, pp. 1–6.
- [31] R. Azarmi, M. Tavakoli-Kakhki, H. MonirVaghefi, D. Shaghaghi, and A. Fatehi, “Fractional order control of ph neutralization process based on fuzzy inverse model,” in *2015 23rd Iranian Conference on Electrical Engineering*, May 2015, pp. 817–822.
- [32] M. Ahmadi and M. Haeri, “An integrated performance and robust stability based multi-model control of nonlinear systems: A ph neutralization reactor,” in *2017 Iranian Conference on Electrical Engineering (ICEE)*, May 2017, pp. 679–684.
- [33] P. K. Singh, S. Bhanot, and H. K. Mohanta, “Genetic optimization based adaptive fuzzy logic control of a ph neutralization process,” *International Journal of Control and Automation*, vol. 7, no. 11, pp. 219–234, 2014.
- [34] Y. Yakubu, J. Zhou, D. Ping, Z. Shu, and Y. Chen, “Effects of ph dynamics on solidification/stabilization of municipal solid waste incineration fly ash,” *Journal of Environmental Management*, vol. 207, pp. 243 – 248, 2018. [Online]. Available: <http://www.sciencedirect.com/science/article/pii/S0301479717311179>
- [35] A. Liopa-Tsakalidi, P. Barouchas, and G. Salahas, “Response of zucchini to the electrical conductivity of the nutrient solution in hydroponic cultivation,” *Agriculture and Agricultural Science Procedia*, vol. 4, pp. 459 – 462, 2015, efficient irrigation management and its effects in urban and rural landscapes. [Online]. Available: <http://www.sciencedirect.com/science/article/pii/S2210784315001163>
- [36] S. Suthar, R. Verma, S. Deep, and K. Kumar, “Optimization of conditions (ph and temperature) for lemna gibba production using fuzzy model coupled with mamdani’s method,” *Ecological Engineering*, vol. 83, pp. 452 – 455, 2015. [Online]. Available: <http://www.sciencedirect.com/science/article/pii/S0925857415301087>
- [37] R. Suchithra, V. Sruthilaya, V. Sneha, R. Shanmathi, and P. Navaseelan, “ph controller for water treatment using fuzzy logic,” in *2016 IEEE Technological Innovations in ICT for Agriculture and Rural Development (TIAR)*, July 2016, pp. 200–204.
- [38] X. chen, A. Xue, D. Peng, and Y. Guo, “Modeling of ph neutralization process using fuzzy recurrent neural network and dna based nsga-ii,” *Journal of the Franklin Institute*, vol. 351, no. 7, pp. 3847 – 3864, 2014. [Online]. Available: <http://www.sciencedirect.com/science/article/pii/S0016003213001282>
- [39] H. Huang, S. Zhang, Z. Yang, Y. Tian, X. Zhao, Z. Yuan, S. Hao, J. Leng, and Y. Wei, “Modified smith fuzzy pid temperature control in an oil-replenishing device for deep-sea hydraulic system,” *Ocean Engineering*, vol. 149, pp. 14 – 22, 2018. [Online]. Available: <http://www.sciencedirect.com/science/article/pii/S0029801817307217>
- [40] S. Dettori, V. Iannino, V. Colla, and A. Signorini, “An adaptive fuzzy logic-based approach to pid control of steam turbines in solar applications,” *Applied Energy*, 2017. [Online]. Available: <http://www.sciencedirect.com/science/article/pii/S0306261917311613>
- [41] A. M. Zaki, M. El-Bardini, F. Soliman, and M. M. Sharaf, “Embedded two level direct adaptive fuzzy controller for dc motor speed control,” *Ain Shams Engineering Journal*, 2015. [Online]. Available: <http://www.sciencedirect.com/science/article/pii/S2090447915001653>
- [42] O. Karasakal, M. Guzelkaya, I. Eksin, E. Yesil, and T. Kumbasar, “Online tuning of fuzzy pid controllers via rule weighing based on normalized acceleration,” *Engineering Applications of Artificial Intelligence*, vol. 26, no. 1, pp. 184 – 197, 2013. [Online]. Available: <http://www.sciencedirect.com/science/article/pii/S0952197612001480>
- [43] X. Liu, Q. Ma, W. Yu, and K. Liu, “Research on the ph value neutralization control strategy of sewage treatment based on the expert pid algorithm,” in *2017 Chinese Automation Congress (CAC)*, Oct 2017, pp. 1812–1815.
- [44] R. Zhang, S. Wu, R. Lu, and F. Gao, “Predictive control optimization based pid control for temperature in an industrial surfactant reactor,” *Chemometrics and Intelligent Laboratory Systems*, vol. 135, pp. 48 – 62, 2014. [Online]. Available: <http://www.sciencedirect.com/science/article/pii/S0169743914000690>
- [45] M. Heredia-Molinero, J. Sánchez-Prieto, J. Briongos, and M. Palancar, “Feedback

- pid-like fuzzy controller for ph regulatory control near the equivalence point,” *Journal of Process Control*, vol. 24, no. 7, pp. 1023 – 1037, 2014. [Online]. Available: <http://www.sciencedirect.com/science/article/pii/S0959152414001437>
- [46] Y. Wang, Q. Jin, and R. Zhang, “Improved fuzzy pid controller design using predictive functional control structure,” *ISA Transactions*, vol. 71, pp. 354 – 363, 2017. [Online]. Available: <http://www.sciencedirect.com/science/article/pii/S0019057817305542>
- [47] Z. Z. Xu, G. Z. Cao, S. D. Huang, and H. X. Zheng, “Sliding mode control of the planar switched reluctance motor for interference suppression,” in *2016 IEEE 11th Conference on Industrial Electronics and Applications (ICIEA)*, June 2016, pp. 2130–2134.
- [48] X. D. Fu, G. Z. Cao, S. D. Huang, and C. Wu, “Fuzzy pid control of the planar switched reluctance motor for precision positioning,” in *2017 7th International Conference on Power Electronics Systems and Applications - Smart Mobility, Power Transfer Security (PESA)*, Dec 2017, pp. 1–4.