













Quality Inspection Report (Inprocess Inspection)













Report No	QIRI20251764	Select the Appropriate Inspection Stage / Process
Date	15-04-2025	Inspection of Cut length Wire
Production Order	PR025-0110	
Item Code	0.838 CL Wire (RAAJRATNA)	
Product Description	Dia 0.838 mm Cut Length Wire 75 mm	
DHR No	20250836	
Batch No	WC0031/2025	
Reference Drawing	NA	

Sl.N o.	Parameter	Requirement	Instrument Used	Setup Approval (Actual Readings/Observation)										Result (Complied / Not Complied)	Remarks
				1	2	3	4	5	6	7	8	9	10		
1	Diameter	0.838 ± 0.005mm	DM	0.844	0.844	0.843	0.843	0.844	0.843	0.843	0.844	0.843	0.844	Complied	
2	Length of cut Wires	75 ± 0.50 mm	DVC	74.51	74.57	74.55	74.57	74.62	74.77	74.55	74.71	74.77	74.62	Complied	
3	Straightness	Straight	Rolling Method	OK	OK	OK	OK	OK	OK	OK	OK	OK	OK	Complied	2
4	Defects Free	Free from rust, burr, Damage.	Microscope	OK	OK	OK	OK	OK	OK	OK	OK	OK	OK	Complied	
Inspected By (Name)		LAKSHMI						Signature (with date)				 15-04-2025			

Quality Inspection Report (Inprocess Inspection)

Sl.N o.	Parameter	Date and Time	Instrument Used	Inprocess Samples Inspection (Put "✓" - Complied and "X" - Not Complied)										Inspected by (Signature)	Remarks
				1	2	3	4	5	6	7	8	9	10		
1 2 3 4	Diameter Cutting Length Straightness Defects free	15-04-2025 11:00 AM	DMM DVC Rolling Method Microscope	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓		NA
		✓		✓	✓	✓	✓	✓	✓	✓	✓	✓	✓		
		✓		✓	✓	✓	✓	✓	✓	✓	✓	✓	✓		
		12:00 PM		✓	✓	✓	✓	✓	✓	✓	✓	✓	✓		
		✓		✓	✓	✓	✓	✓	✓	✓	✓	✓	✓		
		✓		✓	✓	✓	✓	✓	✓	✓	✓	✓	✓		
		01:00 PM		✓	✓	✓	✓	✓	✓	✓	✓	✓	✓		
		✓		✓	✓	✓	✓	✓	✓	✓	✓	✓	✓		
		✓		✓	✓	✓	✓	✓	✓	✓	✓	✓	✓		
		02:00 PM		✓	✓	✓	✓	✓	✓	✓	✓	✓	✓		
		✓		✓	✓	✓	✓	✓	✓	✓	✓	✓	✓		
		✓		✓	✓	✓	✓	✓	✓	✓	✓	✓	✓		
		03:00 PM		✓	✓	✓	✓	✓	✓	✓	✓	✓	✓		
		✓		✓	✓	✓	✓	✓	✓	✓	✓	✓	✓		
		✓		✓	✓	✓	✓	✓	✓	✓	✓	✓	✓		
		04:00 PM		✓	✓	✓	✓	✓	✓	✓	✓	✓	✓		
✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓					
05:00 PM	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓					
Sample Inspected Quantity				Accepted Batch Quantity								Remarks			
Defects Observed (Type)															
Post Quality Inspection Result				Inspected By (Name)		LAKSHMI		Approved By (Name)		MURIGESHAPPA R					
<input checked="" type="checkbox"/> Batch conform to the requirement and approved				Signature				Signature							
<input type="checkbox"/> Batch do not conform to the requirement and not approved				with date		15-04-2025		with date		15-04-2025					
Note: Annexure to be provided for additional test report (if required)															

Quality Inspection Report (Inprocess Inspection)

Sl.No.	Parameter	Date and Time	Instrument Used	Inprocess Samples Inspection (Put "✓" - Complied and "X" - Not Complied)										Inspected by (Signature)	Remarks
				1	2	3	4	5	6	7	8	9	10		
1	Diameter Cutting Length Straightness Defects free	15-04-2025 06:00 PM	DMM DVC Rolling Method Microscope	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓		NA
				✓	✓	✓	✓	✓	✓	✓	✓	✓	✓		
		16-04-2025 9:40 AM		✓	✓	✓	✓	✓	✓	✓	✓	✓	✓		
				✓	✓	✓	✓	✓	✓	✓	✓	✓	✓		
		10:40 AM		✓	✓	✓	✓	✓	✓	✓	✓	✓	✓		
				✓	✓	✓	✓	✓	✓	✓	✓	✓	✓		
				✓	✓	✓	✓	✓	✓	✓	✓	✓	✓		
		11:40 AM		✓	✓	✓	✓	✓	✓	✓	✓	✓	✓		
				✓	✓	✓	✓	✓	✓	✓	✓	✓	✓		
				✓	✓	✓	✓	✓	✓	✓	✓	✓	✓		
				NA											
Sample Inspected Quantity		315 PCs.		Accepted Batch Quantity		29910 PCS.		Remarks							
Defects Observed (Type)															
Post Quality Inspection Result				Inspected By (Name)		LAKSHMI		Approved By (Name)		MURIGESHAPPA R					
<input checked="" type="checkbox"/> Batch conform to the requirement and approved				Signature				Signature							
<input type="checkbox"/> Batch do not conform to the requirement and not approved				with date		16-04-2025		with date		16-04-2025					
Note: Annexure to be provided for additional test report (if required)															