





Quality Inspection Report (Inprocess Inspection)




Report No	QIRI20253402	Select the Appropriate Inspection Stage / Process
Date	29-06-2025	Inspection of Cut length Wire
Production Order	PRO25-0819	
Item Code	Ø 0.90 WIRE	
Product Description	Dia 0.90 mm Cut Length Wire 75 mm (RAAJRATNA)	
DHR No	20251558	
Batch No	WC0059/2025	
Reference Drawing	NA	

Sl.N o.	Parameter	Requirement	Instrument Used	Setup Approval (Actual Readings/Observation)										Result (Complied / Not Complied)	Remarks
				1	2	3	4	5	6	7	8	9	10		
1	Diameter	0.90 ± 0.005 mm	DM	0.905	0.904	0.905	0.905	0.905	0.905	0.904	0.904	0.905	0.905	Complied	2
2	Length of cut Wires	75 ± 0.50 mm	DVC	74.70	74.65	74.63	74.64	74.65	74.74	74.64	74.65	74.66	74.71	Complied	
3	Straightness	Straight	Rolling Method	OK	OK	OK	OK	OK	OK	OK	OK	OK	OK	Complied	
4	Defects Free	Free from rust, burr, Damage.	Microscope	OK	OK	OK	OK	OK	OK	OK	OK	OK	OK	Complied	
Inspected By (Name)		LAKSHMI					Signature (with date)					 29-06-2025			




Quality Inspection Report (Inprocess Inspection)

Sl. No.	Parameter	Date and Time	Instrument Used	Inprocess Samples Inspection (Put "v" - Complied and "X" - Not Complied)										Inspected by (Signature)	Remarks
				1	2	3	4	5	6	7	8	9	10		
1 2 3 4	Diameter Cutting Length Straightness Defects free	29-06-2025 09:40 AM	DMM DVC Rolling Method Microscope	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓		N/A
		10:40 AM		✓	✓	✓	✓	✓	✓	✓	✓	✓	✓		
		11:40 AM		✓	✓	✓	✓	✓	✓	✓	✓	✓	✓		
		12:40 PM		✓	✓	✓	✓	✓	✓	✓	✓	✓	✓		
		01:40 PM		✓	✓	✓	✓	✓	✓	✓	✓	✓	✓		
		02:40 PM		✓	✓	✓	✓	✓	✓	✓	✓	✓	✓		
		03:40 PM		✓	✓	✓	✓	✓	✓	✓	✓	✓	✓		
		04:40 PM		✓	✓	✓	✓	✓	✓	✓	✓	✓	✓		
		05:20 PM		✓	✓	✓	✓	✓	✓	✓	✓	✓	✓		
		06:00 PM		✓	✓	✓	✓	✓	✓	✓	✓	✓	✓		
		30-06-2025 09:40 AM		✓	✓	✓	✓	✓	✓	✓	✓	✓	✓		
		10:40 AM		✓	✓	✓	✓	✓	✓	✓	✓	✓	✓		
		11:40 AM		✓	✓	✓	✓	✓	✓	✓	✓	✓	✓		
		12:40 PM		✓	✓	✓	✓	✓	✓	✓	✓	✓	✓		
		01:40 PM		✓	✓	✓	✓	✓	✓	✓	✓	✓	✓		
		02:40 PM		✓	✓	✓	✓	✓	✓	✓	✓	✓	✓		
		03:40 PM		✓	✓	✓	✓	✓	✓	✓	✓	✓	✓		
		04:40 PM		✓	✓	✓	✓	✓	✓	✓	✓	✓	✓		
		05:40 PM		✓	✓	✓	✓	✓	✓	✓	✓	✓	✓		
		Sample Inspected Quantity		✓	Accepted Batch Quantity		✓		Remarks		✓				
Defects Observed (Type)		✓													
Post Quality Inspection Result				Inspected By (Name)		LAKSHMI		Approved By (Name)		MURIGESHAPPA R					
<input checked="" type="checkbox"/> Batch conform to the requirement and approved <input type="checkbox"/> Batch do not conform to the requirement and not approved				Signature				Signature							
				with date		30-06-2025		with date		30-06-2025					
Note: Annexure to be provided for additional test report (if required)															

Quality Inspection Report (Inprocess Inspection)

Sl.N o.	Parameter	Date and Time	Instrument Used	Inprocess Samples Inspection (Put "v" - Complied and "X" - Not Complied)										Inspected by (Signature)	Remarks
				1	2	3	4	5	6	7	8	9	10		
1 2 3 4	Diameter Cutting Length Straightness Defects free	01-07-2025 09:30 AM	DMM DVC Rolling Method Microscope	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓		N/A
				✓	✓	✓	✓	✓	✓	✓	✓	✓	✓		
		10:30 AM		✓	✓	✓	✓	✓	✓	✓	✓	✓	✓		
				✓	✓	✓	✓	✓	✓	✓	✓	✓	✓		
		11:30 AM		✓	✓	✓	✓	✓	✓	✓	✓	✓	✓		
				✓	✓	✓	✓	✓	✓	✓	✓	✓	✓		
		12:30 PM		✓	✓	✓	✓	✓	✓	✓	✓	✓	✓		
				✓	✓	✓	✓	✓	✓	✓	✓	✓	✓		
		01:30 PM		✓	✓	✓	✓	✓	✓	✓	✓	✓	✓		
				✓	✓	✓	✓	✓	✓	✓	✓	✓	✓		
		02:30 PM		✓	✓	✓	✓	✓	✓	✓	✓	✓	✓		
				✓	✓	✓	✓	✓	✓	✓	✓	✓	✓		
		03:30 PM		✓	✓	✓	✓	✓	✓	✓	✓	✓	✓		
				✓	✓	✓	✓	✓	✓	✓	✓	✓	✓		
04:20 PM	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓					
	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓					
05:10 PM	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓					
	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓					
	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓					
05:50 PM	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓					
	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓					
Sample Inspected Quantity		Accepted Batch Quantity		Remarks											
Defects Observed (Type)															
Post Quality Inspection Result				Inspected By (Name)		LAKSHMI		Approved By (Name)		MURIGESHAPPA R					
<input checked="" type="checkbox"/> Batch conform to the requirement and approved				Signature				Signature							
<input type="checkbox"/> Batch do not conform to the requirement and not approved				with date		01-07-2025		with date		01-07-2025					
Note: Annexure to be provided for additional test report (if required)															

Quality Inspection Report (Inprocess Inspection)

Sl. No.	Parameter	Date and Time	Instrument Used	Inprocess Samples Inspection (Put "v" - Complied and "X" - Not Complied)										Inspected by (Signature)	Remarks
				1	2	3	4	5	6	7	8	9	10		
1 2 3 4	Diameter Cutting Length Straightness Defects free	02-07-2025 09:35 AM	DMM DVC Rolling Method Microscope	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓		4 2
				✓	✓	✓	✓	✓	✓	✓	✓	✓	✓		
		10:30 AM		✓	✓	✓	✓	✓	✓	✓	✓	✓	✓		
				✓	✓	✓	✓	✓	✓	✓	✓	✓	✓		
		11:30 AM		✓	✓	✓	✓	✓	✓	✓	✓	✓	✓		
				✓	✓	✓	✓	✓	✓	✓	✓	✓	✓		
		12:30 PM		✓	✓	✓	✓	✓	✓	✓	✓	✓	✓		
				✓	✓	✓	✓	✓	✓	✓	✓	✓	✓		
				✓	✓	✓	✓	✓	✓	✓	✓	✓	✓		
		01:00 PM		✓	✓	✓	✓	✓	✓	✓	✓	✓	✓		
Sample Inspected Quantity		500 PCS.	Accepted Batch Quantity		65500 PCS.		Remarks								
Defects Observed (Type)															
Post Quality Inspection Result				Inspected By (Name)		LAKSHMI		Approved By (Name)		MURIGESHAPPA R					
<input checked="" type="checkbox"/> Batch conform to the requirement and approved				Signature		 02-07-2025		Signature		 02-07-2025					
<input type="checkbox"/> Batch do not conform to the requirement and not approved				with date				with date							
Note: Annexure to be provided for additional test report (if required)															