



Quality Inspection Report (Inprocess Inspection)






















Report No	QIRI20250060	Select the Appropriate Inspection Stage / Process
Date	03-01-2025	Inspection of Cut length Wire
Production Order	PR024-2280	NA
Item Code	0.94 CL Wire	
Product Description	Dia 0.94 mm Cut Length Wire 75 mm (Haynes)	
DHR No	20250109	
Batch No	WC0001/2025	
Reference Drawing	NA	

Sl.N o.	Parameter	Requirement	Instrument Used	Setup Approval (Actual Readings/Observation)										Result (Complied / Not Complied)	Remarks
				1	2	3	4	5	6	7	8	9	10		
1	Diameter	0.94 ± 0.005 mm	DM	0.940	0.941	0.939	0.941	0.942	0.940	0.940	0.939	0.938	0.938	Complied	
2	Length of cut Wires	75 ± 0.50 mm	DVC	75.05	74.95	74.98	75.05	74.98	75.06	74.97	74.97	75.13	75.10	Complied	
3	Straightness	Straight	Rolling Method	OK	OK	OK	OK	OK	OK	OK	OK	OK	OK	Complied	#2
4	Defects Free	Free from rust, burr, Damage.	Microscope	OK	OK	OK	OK	OK	OK	OK	OK	OK	OK	Complied	
Inspected By (Name)				MANJUNATHA						Signature (with date)				03-01-2025	




Quality Inspection Report (Inprocess Inspection)

Sl.N o.	Parameter	Date and Time	Instrument Used	Inprocess Samples Inspection (Put "✓" - Complied and "X" - Not Complied)										Inspected by (Signature)	Remarks
				1	2	3	4	5	6	7	8	9	10		
1 2 3 4	Diameter Cutting Length Straightness Defects free	03-01-2025	DMM DVC Rolling Method Microscope	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	NA
				✓	✓	✓	✓	✓	✓	✓	✓	✓	✓		
		11:00 AM		✓	✓	✓	✓	✓	✓	✓	✓	✓	✓		
				✓	✓	✓	✓	✓	✓	✓	✓	✓	✓		
		12:00 PM		✓	✓	✓	✓	✓	✓	✓	✓	✓	✓		
				✓	✓	✓	✓	✓	✓	✓	✓	✓	✓		
		01:00 PM		✓	✓	✓	✓	✓	✓	✓	✓	✓	✓		
				✓	✓	✓	✓	✓	✓	✓	✓	✓	✓		
				✓	✓	✓	✓	✓	✓	✓	✓	✓	✓		
		02:00 PM		✓	✓	✓	✓	✓	✓	✓	✓	✓	✓		
				✓	✓	✓	✓	✓	✓	✓	✓	✓	✓		
				✓	✓	✓	✓	✓	✓	✓	✓	✓	✓		
		03:00 PM		✓	✓	✓	✓	✓	✓	✓	✓	✓	✓		
				✓	✓	✓	✓	✓	✓	✓	✓	✓	✓		
				✓	✓	✓	✓	✓	✓	✓	✓	✓	✓		
		04:40 PM		✓	✓	✓	✓	✓	✓	✓	✓	✓	✓		
	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓					
5:30 PM	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓					
	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓					
04-01-2025	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓					
09:40 AM	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓					
Sample Inspected Quantity		Accepted Batch Quantity		Remarks											
Defects Observed (Type)															
Post Quality Inspection Result				Inspected By (Name)		MANJUNATHA		Approved By (Name)		MURIGESHAPPA R					
<input checked="" type="checkbox"/> Batch conform to the requirement and approved				Signature				Signature							
<input type="checkbox"/> Batch do not conform to the requirement and not approved				with date		03-01-2025		with date		03-01-2025					
Note: Annexure to be provided for additional test report (if required)															

Quality Inspection Report (Inprocess Inspection)

Sl. No.	Parameter	Date and Time	Instrument Used	Inprocess Samples Inspection (Put "✓" - Complied and "X" - Not Complied)										Inspected by (Signature)	Remarks
				1	2	3	4	5	6	7	8	9	10		
1 2 3 4	Diameter Cutting Length Straightness Defects free	10:40 AM	DMM DVC Rolling Method Microscope	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓		2
				✓	✓	✓	✓	✓	✓	✓	✓	✓	✓		
		11:40 AM		✓	✓	✓	✓	✓	✓	✓	✓	✓	✓		
				✓	✓	✓	✓	✓	✓	✓	✓	✓	✓		
		12:40 PM		✓	✓	✓	✓	✓	✓	✓	✓	✓	✓		
				✓	✓	✓	✓	✓	✓	✓	✓	✓	✓		
		01:40 PM		✓	✓	✓	✓	✓	✓	✓	✓	✓	✓		
				✓	✓	✓	✓	✓	✓	✓	✓	✓	✓		
				✓	✓	✓	✓	✓	✓	✓	✓	✓	✓		
				✓	✓	✓	✓	✓	✓	✓	✓	✓	✓		
		02:40 PM		✓	✓	✓	✓	✓	✓	✓	✓	✓	✓		
				✓	✓	✓	✓	✓	✓	✓	✓	✓	✓		
		03:40 PM		✓	✓	✓	✓	✓	✓	✓	✓	✓	✓		
				✓	✓	✓	✓	✓	✓	✓	✓	✓	✓		
		04:40 PM		✓	✓	✓	✓	✓	✓	✓	✓	✓	✓		
				✓	✓	✓	✓	✓	✓	✓	✓	✓	✓		
06:00 PM		✓	✓	✓	✓	✓	✓	✓	✓	✓	✓				
06-01-2025		✓	✓	✓	✓	✓	✓	✓	✓	✓	✓				
9:40 AM		✓	✓	✓	✓	✓	✓	✓	✓	✓	✓				
Sample Inspected Quantity		Accepted Batch Quantity		Remarks											
Defects Observed (Type)															
Post Quality Inspection Result				Inspected By (Name)		MANJUNATHA		Approved By (Name)		MURIGESHAPPA R					
<input checked="" type="checkbox"/> Batch conform to the requirement and approved				Signature				Signature							
<input type="checkbox"/> Batch do not conform to the requirement and not approved				with date		06-01-2025		with date		06-01-2025					
Note: Annexure to be provided for additional test report (if required)															

Quality Inspection Report (Inprocess Inspection)

Sl.N o.	Parameter	Date and Time	Instrument Used	Inprocess Samples Inspection (Put "v" - Complied and "X" - Not Complied)										Inspected by (Signature)	Remarks
				1	2	3	4	5	6	7	8	9	10		
1 2 3 4	Diameter Cutting Length Straightness Defects free	10:40 AM	DMM DVC Rolling Method Microscope	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓		NA
				✓	✓	✓	✓	✓	✓	✓	✓	✓			
		11:40 AM		✓	✓	✓	✓	✓	✓	✓	✓	✓			
				✓	✓	✓	✓	✓	✓	✓	✓	✓			
		12:40 PM		✓	✓	✓	✓	✓	✓	✓	✓	✓			
				✓	✓	✓	✓	✓	✓	✓	✓	✓			
		01:40 PM		✓	✓	✓	✓	✓	✓	✓	✓	✓			
				✓	✓	✓	✓	✓	✓	✓	✓	✓			
		02:40 PM		✓	✓	✓	✓	✓	✓	✓	✓	✓			
		04:00 PM		✓	✓	✓	✓	✓	✓	✓	✓	✓			
				NA											
Sample Inspected Quantity		500 PCS	Accepted Batch Quantity		53940 PCS.					Remarks					
Defects Observed (Type)															
Post Quality Inspection Result				Inspected By (Name)		MANJUNATHA		Approved By (Name)		MURIGESHAPPA R					
<input checked="" type="checkbox"/> Batch conform to the requirement and approved				Signature				Signature							
<input type="checkbox"/> Batch do not conform to the requirement and not approved				with date		06-01-2025		with date							
Note: Annexure to be provided for additional test report (if required)															