





Quality Inspection Report (Inprocess Inspection)





Report No	QIRI20250428	Select the Appropriate Inspection Stage / Process
Date	21-01-2025	Inspection of Cut length Wire
Production Order	PR024-2449	
Item Code	Ø 0.90 CL Wire (RAJARATHNA)	
Product Description	Dia 0.90 mm Cut Length Wire 75 mm (RAJARATHNA)	
DHR No	20250206	
Batch No	WC0007/2025	
Reference Drawing	NA	

Sl.N o.	Parameter	Requirement	Instrument Used	Setup Approval (Actual Readings/Observation)										Result (Complied / Not Complied)	Remarks
				1	2	3	4	5	6	7	8	9	10		
1	Diameter	0.90 ± 0.005 mm	DM	0.905	0.904	0.903	0.905	0.904	0.903	0.903	0.904	0.903	0.903	Complied	
2	Length of cut Wires	75 ± 0.50 mm	DVC	74.79	74.66	74.79	74.77	74.62	74.75	74.69	74.77	74.79	74.65	Complied	
3	Straightness	Straight	Rolling Method	OK	OK	OK	OK	OK	OK	OK	OK	OK	OK	Complied	OK
4	Defects Free	Free from rust, burr, Damage.	Microscope	OK	OK	OK	OK	OK	OK	OK	OK	OK	OK	Complied	
Inspected By (Name)		LAKSHMI.							Signature (with date)						
									 21-01-2025						

Quality Inspection Report (Inprocess Inspection)

Sl. No.	Parameter	Date and Time	Instrument Used	Inprocess Samples Inspection (Put "v" - Complied and "X" - Not Complied)										Inspected by (Signature)	Remarks
				1	2	3	4	5	6	7	8	9	10		
1 2 3 4	Diameter Cutting Length Straightness Defects free	21-01-2025	DMM DVC Rolling Method Microscope	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓		
				✓	✓	✓	✓	✓	✓	✓	✓	✓			
				✓	✓	✓	✓	✓	✓	✓	✓	✓			
		09:50 AM		✓	✓	✓	✓	✓	✓	✓	✓	✓			
				✓	✓	✓	✓	✓	✓	✓	✓	✓			
				✓	✓	✓	✓	✓	✓	✓	✓	✓			
				✓	✓	✓	✓	✓	✓	✓	✓	✓			
				✓	✓	✓	✓	✓	✓	✓	✓	✓			
				✓	✓	✓	✓	✓	✓	✓	✓	✓			
		10:50 AM		✓	✓	✓	✓	✓	✓	✓	✓	✓			
				✓	✓	✓	✓	✓	✓	✓	✓	✓			
				✓	✓	✓	✓	✓	✓	✓	✓	✓			
				✓	✓	✓	✓	✓	✓	✓	✓	✓			
				✓	✓	✓	✓	✓	✓	✓	✓	✓			
		11:50 AM		✓	✓	✓	✓	✓	✓	✓	✓	✓			
				✓	✓	✓	✓	✓	✓	✓	✓	✓			
	✓	✓	✓	✓	✓	✓	✓	✓	✓						
	✓	✓	✓	✓	✓	✓	✓	✓	✓						
12:50 PM	✓	✓	✓	✓	✓	✓	✓	✓	✓						
	✓	✓	✓	✓	✓	✓	✓	✓	✓						
Sample Inspected Quantity		—		Accepted Batch Quantity		—		Remarks		—					
Defects Observed (Type)		—													
Post Quality Inspection Result				Inspected By (Name)		LAKSHMI.		Approved By (Name)		MURIGESHAPPA R					
<input checked="" type="checkbox"/> Batch conform to the requirement and approved				Signature				Signature							
<input type="checkbox"/> Batch do not conform to the requirement and not approved				with date		21-01-2025		with date		21-01-2025					
Note: Annexure to be provided for additional test report (if required)															

Quality Inspection Report (Inprocess Inspection)

Sl. No.	Parameter	Date and Time	Instrument Used	Inprocess Samples Inspection (Put "v" - Complied and "X" - Not Complied)										Inspected by (Signature)	Remarks
				1	2	3	4	5	6	7	8	9	10		
1 2 3 4	Diameter Cutting Length Straightness Defects free	21-01-2025	DMM DVC Rolling Method Microscope	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓		
				✓	✓	✓	✓	✓	✓	✓	✓	✓			
		01:50 PM		✓	✓	✓	✓	✓	✓	✓	✓	✓			
				✓	✓	✓	✓	✓	✓	✓	✓	✓			
				✓	✓	✓	✓	✓	✓	✓	✓	✓			
		02:50 PM		✓	✓	✓	✓	✓	✓	✓	✓	✓			
				✓	✓	✓	✓	✓	✓	✓	✓	✓			
				✓	✓	✓	✓	✓	✓	✓	✓	✓			
				✓	✓	✓	✓	✓	✓	✓	✓	✓			
				✓	✓	✓	✓	✓	✓	✓	✓	✓			
															
Sample Inspected Quantity		315 pcs.	Accepted Batch Quantity		12900 pcs.		Remarks								
Defects Observed (Type)															
Post Quality Inspection Result				Inspected By (Name)		LAKSHMI.		Approved By (Name)		MURIGESHAPPA R					
<input checked="" type="checkbox"/> Batch conform to the requirement and approved				Signature				Signature							
<input type="checkbox"/> Batch do not conform to the requirement and not approved				with date		21-01-2025		with date		21-01-2025					
Note: Annexure to be provided for additional test report (if required)															