







Quality Inspection Report (Inprocess Inspection)








Report No	QIRI20251104	Select the Appropriate Inspection Stage / Process
Date	28.02.2025	Inspection of Cut length Wire
Production Order	PR024-2782	
Item Code	0.838 CL Wire (HAYNES)	
Product Description	Dia 0.838 mm Cut Length Wire 75 mm (HAYNES)	
DHR No	20250543	
Batch No	WC0022/2024	
Reference Drawing	NA	

Sl.N o.	Parameter	Requirement	Instrument Used	Setup Approval (Actual Readings/Observation)										Result (Complied / Not Complied)	Remarks
				1	2	3	4	5	6	7	8	9	10		
1	Diameter	0.838 ± 0.005mm	DM	0.843	0.843	0.842	0.843	0.842	0.843	0.842	0.843	0.842	0.843	Complied	
2	Length of cut Wires	75 ± 0.50 mm	DVC	74.76	74.53	74.56	74.55	74.67	74.60	74.73	74.56	74.72	74.53	Complied	
3	Straightness	Straight	Rolling Method	OK	OK	OK	OK	OK	OK	OK	OK	OK	OK	Complied	
4	Defects Free	Free from rust, burr, Damage.	Microscope	OK	OK	OK	OK	OK	OK	OK	OK	OK	OK	Complied	
Inspected By (Name)		LAKSHMI.					Signature (with date)								




Quality Inspection Report (Inprocess Inspection)

Sl.N o.	Parameter	Date and Time	Instrument Used	Inprocess Samples Inspection (Put "v" - Complied and "X" - Not Complied)										Inspected by (Signature)	Remarks
				1	2	3	4	5	6	7	8	9	10		
1 2 3 4	Diameter Cutting Length Straightness Defects free	29-02-2025 1:00 PM	DMM DVC Rolling Method Microscope	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓		
				✓	✓	✓	✓	✓	✓	✓	✓	✓	✓		
				✓	✓	✓	✓	✓	✓	✓	✓	✓	✓		
				✓	✓	✓	✓	✓	✓	✓	✓	✓	✓		
		02:00 PM		✓	✓	✓	✓	✓	✓	✓	✓	✓	✓		
				✓	✓	✓	✓	✓	✓	✓	✓	✓	✓		
				✓	✓	✓	✓	✓	✓	✓	✓	✓	✓		
				✓	✓	✓	✓	✓	✓	✓	✓	✓	✓		
		03:00 PM		✓	✓	✓	✓	✓	✓	✓	✓	✓	✓		
				✓	✓	✓	✓	✓	✓	✓	✓	✓	✓		
				✓	✓	✓	✓	✓	✓	✓	✓	✓	✓		
				✓	✓	✓	✓	✓	✓	✓	✓	✓	✓		
				✓	✓	✓	✓	✓	✓	✓	✓	✓	✓		
		04:00 PM		✓	✓	✓	✓	✓	✓	✓	✓	✓	✓		
				✓	✓	✓	✓	✓	✓	✓	✓	✓	✓		
				✓	✓	✓	✓	✓	✓	✓	✓	✓	✓		
				✓	✓	✓	✓	✓	✓	✓	✓	✓	✓		
		05:00 PM		✓	✓	✓	✓	✓	✓	✓	✓	✓	✓		
				✓	✓	✓	✓	✓	✓	✓	✓	✓	✓		
				✓	✓	✓	✓	✓	✓	✓	✓	✓	✓		
3-02-2025 9:40 AM	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓					
Sample Inspected Quantity		Accepted Batch Quantity		Remarks											
Defects Observed (Type)															
Post Quality Inspection Result				Inspected By (Name)		LAKSHMI.		Approved By (Name)		MURIGESHAPPA R					
<input checked="" type="checkbox"/> Batch conform to the requirement and approved				Signature				Signature							
<input type="checkbox"/> Batch do not conform to the requirement and not approved				with date		03-03-2025		with date		03-03-2025					
Note: Annexure to be provided for additional test report (if required)															

Quality Inspection Report (Inprocess Inspection)

Sl. No.	Parameter	Date and Time	Instrument Used	Inprocess Samples Inspection (Put "v" - Complied and "X" - Not Complied)										Inspected by (Signature)	Remarks
				1	2	3	4	5	6	7	8	9	10		
1 2 3 4	Diameter Cutting Length Straightness Defects free	03-03-2025 10:40 AM	DMM DVC Rolling Method Microscope	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓		24
				✓	✓	✓	✓	✓	✓	✓	✓	✓	✓		
		11:40 AM		✓	✓	✓	✓	✓	✓	✓	✓	✓	✓		
				✓	✓	✓	✓	✓	✓	✓	✓	✓	✓		
		12:40 PM		✓	✓	✓	✓	✓	✓	✓	✓	✓	✓		
				✓	✓	✓	✓	✓	✓	✓	✓	✓	✓		
		01:40 PM		✓	✓	✓	✓	✓	✓	✓	✓	✓	✓		
				✓	✓	✓	✓	✓	✓	✓	✓	✓	✓		
		02:40 PM		✓	✓	✓	✓	✓	✓	✓	✓	✓	✓		
				✓	✓	✓	✓	✓	✓	✓	✓	✓	✓		
		03:40 PM		✓	✓	✓	✓	✓	✓	✓	✓	✓	✓		
				✓	✓	✓	✓	✓	✓	✓	✓	✓	✓		
		04:40 PM		✓	✓	✓	✓	✓	✓	✓	✓	✓	✓		
				✓	✓	✓	✓	✓	✓	✓	✓	✓	✓		
		05:40 PM		✓	✓	✓	✓	✓	✓	✓	✓	✓	✓		
				✓	✓	✓	✓	✓	✓	✓	✓	✓	✓		
		04-03-2025 9:40 AM		✓	✓	✓	✓	✓	✓	✓	✓	✓	✓		
				✓	✓	✓	✓	✓	✓	✓	✓	✓	✓		
				✓	✓	✓	✓	✓	✓	✓	✓	✓	✓		
		10:40 AM		✓	✓	✓	✓	✓	✓	✓	✓	✓	✓		
Sample Inspected Quantity		—		Accepted Batch Quantity				—				Remarks		—	
Defects Observed (Type)		—													
Post Quality Inspection Result				Inspected By (Name)		LAKSHMI.		Approved By (Name)		MURIGESHAPPA R					
✓ Batch conform to the requirement and approved				Signature				Signature							
□ Batch do not conform to the requirement and not approved				with date		04-03-2025		with date		04-03-2025					
Note: Annexure to be provided for additional test report (if required)															

Quality Inspection Report (Inprocess Inspection)

Sl. No.	Parameter	Date and Time	Instrument Used	Inprocess Samples Inspection (Put "v" - Complied and "X" - Not Complied)										Inspected by (Signature)	Remarks
				1	2	3	4	5	6	7	8	9	10		
1 2 3 4	Diameter Cutting Length Straightness Defects free	04-03-2025 11:40 AM	DMM DVC Rolling Method Microscope	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓		NA
		12:40 PM		✓	✓	✓	✓	✓	✓	✓	✓	✓	✓		
		01:40 PM		✓	✓	✓	✓	✓	✓	✓	✓	✓	✓		
		02:40 PM		✓	✓	✓	✓	✓	✓	✓	✓	✓	✓		
		03:40 PM		✓	✓	✓	✓	✓	✓	✓	✓	✓	✓		
		04:40 PM		✓	✓	✓	✓	✓	✓	✓	✓	✓	✓		
		05:45 PM		✓	✓	✓	✓	✓	✓	✓	✓	✓	✓		
Sample Inspected Quantity		500 PCS.	Accepted Batch Quantity		54050 PCS.		Remarks								
Defects Observed (Type)		—													
Post Quality Inspection Result				Inspected By (Name)		LAKSHMI.		Approved By (Name)		MURIGESHAPPA R					
<input checked="" type="checkbox"/> Batch conform to the requirement and approved				Signature				Signature with date							
<input type="checkbox"/> Batch do not conform to the requirement and not approved				with date		04-03-2025									
Note: Annexure to be provided for additional test report (if required)															