


## Quality Inspection Report (Inprocess Inspection)

Report No	QIRI20253564	Select the Appropriate Inspection Stage / Process
Date	10-07-2025	Inspection of Cut length Wire
Production Order	PRO25-0906	
Item Code	Ø 0.90 WIRE	
Product Description	Dia 0.90 mm Cut Length Wire 90 mm (RAAJRATNA)	
DHR No	20251665	
Batch No	WC0064/2025	
Reference Drawing	NA	




Sl.N o.	Parameter	Requirement	Instrument Used	Setup Approval (Actual Readings/Observation)										Result (Complied / Not Complied)	Remarks
				1	2	3	4	5	6	7	8	9	10		
1	Diameter	0.90 ± 0.005 mm	DM	0.904	0.904	0.905	0.904	0.905	0.905	0.904	0.904	0.904	0.905	Complied	
2	Length of cut Wires	90 ± 0.50 mm	DVC	89.52	89.62	89.57	89.55	89.62	89.66	89.54	89.69	89.70	89.62	Complied	
3	Straightness	Straight	Rolling Method	OK	OK	OK	OK	OK	OK	OK	OK	OK	OK	Complied	5 2
4	Defects Free	Free from rust, burr, Damage.	Microscope	OK	OK	OK	OK	OK	OK	OK	OK	OK	OK	Complied	
Inspected By (Name)		LAKSHMI							Signature (with date )		 10-07-2025.				

## Quality Inspection Report (Inprocess Inspection)

Sl. No.	Parameter	Date and Time	Instrument Used	Inprocess Samples Inspection (Put "V" - Complied and "X" - Not Complied)										Inspected by (Signature)	Remarks
				1	2	3	4	5	6	7	8	9	10		
1 2 3 4	Diameter Cutting Length Straightness Defects free	10-04-2025 9:30 AM	DMM DVC Rolling Method Microscope	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	[Signature]	[Remarks]
				✓	✓	✓	✓	✓	✓	✓	✓	✓	✓		
		10:30 AM		✓	✓	✓	✓	✓	✓	✓	✓	✓	✓		
				✓	✓	✓	✓	✓	✓	✓	✓	✓	✓		
		11:30 AM		✓	✓	✓	✓	✓	✓	✓	✓	✓	✓		
				✓	✓	✓	✓	✓	✓	✓	✓	✓	✓		
		12:30 PM		✓	✓	✓	✓	✓	✓	✓	✓	✓	✓		
				✓	✓	✓	✓	✓	✓	✓	✓	✓	✓		
		01:30 PM		✓	✓	✓	✓	✓	✓	✓	✓	✓	✓		
				✓	✓	✓	✓	✓	✓	✓	✓	✓	✓		
		02:30 PM		✓	✓	✓	✓	✓	✓	✓	✓	✓	✓		
				✓	✓	✓	✓	✓	✓	✓	✓	✓	✓		
		03:30 PM		✓	✓	✓	✓	✓	✓	✓	✓	✓	✓		
				✓	✓	✓	✓	✓	✓	✓	✓	✓	✓		
04:30 PM	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓					
	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓					
05:20 PM	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓					
	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓					
06:00 PM	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓					
	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓					
Sample Inspected Quantity		Accepted Batch Quantity		Remarks											
Defects Observed (Type)															
Post Quality Inspection Result				Inspected By (Name)		LAKSHMI		Approved By (Name)		MURIGESHAPPA R					
<input checked="" type="checkbox"/> Batch conform to the requirement and approved				Signature		[Signature]		Signature		[Signature]					
<input type="checkbox"/> Batch do not conform to the requirement and not approved				with date		10-04-2025		with date		10-04-2025					
Note: Annexure to be provided for additional test report (if required)															



## Quality Inspection Report (Inprocess Inspection)

Sl. No.	Parameter	Date and Time	Instrument Used	Inprocess Samples Inspection (Put "v" - Complied and "X" - Not Complied)										Inspected by (Signature)	Remarks
				1	2	3	4	5	6	7	8	9	10		
1 2 3 4	Diameter Cutting Length Straightness Defects free	11-04-2025 09:30 AM	DMM DVC Rolling Method Microscope	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓		
				✓	✓	✓	✓	✓	✓	✓	✓	✓	✓		
		10:30 AM		✓	✓	✓	✓	✓	✓	✓	✓	✓	✓		
				✓	✓	✓	✓	✓	✓	✓	✓	✓	✓		
		11:30 AM		✓	✓	✓	✓	✓	✓	✓	✓	✓	✓		
				✓	✓	✓	✓	✓	✓	✓	✓	✓	✓		
		12:30 PM		✓	✓	✓	✓	✓	✓	✓	✓	✓	✓		
				✓	✓	✓	✓	✓	✓	✓	✓	✓	✓		
		01:30 PM		✓	✓	✓	✓	✓	✓	✓	✓	✓	✓		
				✓	✓	✓	✓	✓	✓	✓	✓	✓	✓		
		02:30 PM		✓	✓	✓	✓	✓	✓	✓	✓	✓	✓		
				✓	✓	✓	✓	✓	✓	✓	✓	✓	✓		
		03:30 PM		✓	✓	✓	✓	✓	✓	✓	✓	✓	✓		
				✓	✓	✓	✓	✓	✓	✓	✓	✓	✓		
		04:30 PM		✓	✓	✓	✓	✓	✓	✓	✓	✓	✓		
				✓	✓	✓	✓	✓	✓	✓	✓	✓	✓		
05:20 PM	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓					
	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓					
06:00 PM	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓					
	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓					
Sample Inspected Quantity		Accepted Batch Quantity		Remarks											
Defects Observed (Type)															
Post Quality Inspection Result				Inspected By (Name)		LAKSHMI		Approved By (Name)		MURIGESHAPPA R					
<input checked="" type="checkbox"/> Batch conform to the requirement and approved				Signature				Signature							
<input type="checkbox"/> Batch do not conform to the requirement and not approved				with date		11-04-2025		with date		11-04-2025					
Note: Annexure to be provided for additonal test report (if required)															



## Quality Inspection Report (Inprocess Inspection)

Sl. No.	Parameter	Date and Time	Instrument Used	Inprocess Samples Inspection (Put "V" - Complied and "X" - Not Complied)										Inspected by (Signature)	Remarks	
				1	2	3	4	5	6	7	8	9	10			
1 2 3 4	Diameter Cutting Length Straightness Defects free	12-07-2025 09:40 AM	DMM DVC Rolling Method Microscope	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	[Signature]	NA
				✓	✓	✓	✓	✓	✓	✓	✓	✓	✓			
				✓	✓	✓	✓	✓	✓	✓	✓	✓	✓			
		10:40 AM		✓	✓	✓	✓	✓	✓	✓	✓	✓	✓			
				✓	✓	✓	✓	✓	✓	✓	✓	✓	✓			
		11:40 AM		✓	✓	✓	✓	✓	✓	✓	✓	✓	✓			
				✓	✓	✓	✓	✓	✓	✓	✓	✓	✓			
		12:20 PM		✓	✓	✓	✓	✓	✓	✓	✓	✓	✓			
				✓	✓	✓	✓	✓	✓	✓	✓	✓	✓			
		01:00 PM		✓	✓	✓	✓	✓	✓	✓	✓	✓	✓			
				NA												
Sample Inspected Quantity		500 PCS.	Accepted Batch Quantity		47000 PCS.					Remarks		-				
Defects Observed (Type)		-														
Post Quality Inspection Result				Inspected By (Name)		LAKSHMI		Approved By (Name)		MURIGESHAPPA R						
<input checked="" type="checkbox"/> Batch conform to the requirement and approved				Signature		[Signature]		Signature		[Signature]						
<input type="checkbox"/> Batch do not conform to the requirement and not approved				with date		12-07-2025		with date		12-07-2025						
Note: Annexure to be provided for additional test report (if required)																