





## Quality Inspection Report (Inprocess Inspection)

Report No	QIRI20253600	Select the Appropriate Inspection Stage / Process
Date	12-07-2025	Inspection of Cut length Wire
Production Order	PRO25-0924	
Item Code	0.80 CL Wire	
Product Description	Dia 0.80 mm Cut Length Wire 75 mm	
DHR No	20251681	
Batch No	WC0065/2025	
Reference Drawing	NA	

Sl.N o.	Parameter	Requirement	Instrument Used	Setup Approval (Actual Readings/Observation)										Result (Complied / Not Complied)	Remarks
				1	2	3	4	5	6	7	8	9	10		
1	Diameter	0.80 ± 0.005mm	DM	0.803	0.804	0.802	0.801	0.802	0.803	0.803	0.804	0.803	0.803	Complied	5
2	Length of cut Wires	75 ± 0.50 mm	DVC	75.09	75.12	75.22	75.32	75.29	75.05	75.12	75.25	75.33	75.37	Complied	
3	Straightness	Straight	Rolling Method	OK	OK	OK	OK	OK	OK	OK	OK	OK	OK	Complied	
4	Defects Free	Free from rust, burr, Damage.	Microscope	OK	OK	OK	OK	OK	OK	OK	OK	OK	OK	Complied	
Inspected By (Name)		LAKSHMI					Signature (with date)					12-07-2025			

## Quality Inspection Report (Inprocess Inspection)

Sl.N o.	Parameter	Date and Time	Instrument Used	Inprocess Samples Inspection (Put "v" - Complied and "X" - Not Complied)										Inspected by (Signature)	Remarks
				1	2	3	4	5	6	7	8	9	10		
1 2 3 4	Diameter Cutting Length Straightness Defects free	12-07-2025 01:30 PM	DMM DVC Rolling Method Microscope	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓		↓
		✓		✓	✓	✓	✓	✓	✓	✓	✓	✓			
		✓		✓	✓	✓	✓	✓	✓	✓	✓	✓			
		✓		✓	✓	✓	✓	✓	✓	✓	✓	✓			
		✓		✓	✓	✓	✓	✓	✓	✓	✓	✓			
		✓		✓	✓	✓	✓	✓	✓	✓	✓	✓			
		✓		✓	✓	✓	✓	✓	✓	✓	✓	✓			
		✓		✓	✓	✓	✓	✓	✓	✓	✓	✓			
		✓		✓	✓	✓	✓	✓	✓	✓	✓	✓			
		✓		✓	✓	✓	✓	✓	✓	✓	✓	✓			
		✓		✓	✓	✓	✓	✓	✓	✓	✓	✓			
		✓		✓	✓	✓	✓	✓	✓	✓	✓	✓			
		✓		✓	✓	✓	✓	✓	✓	✓	✓	✓			
		✓		✓	✓	✓	✓	✓	✓	✓	✓	✓			
		✓		✓	✓	✓	✓	✓	✓	✓	✓	✓			
		02:30 PM		✓	✓	✓	✓	✓	✓	✓	✓	✓	✓		
✓	✓	✓	✓	✓	✓	✓	✓	✓	✓						
✓	✓	✓	✓	✓	✓	✓	✓	✓	✓						
✓	✓	✓	✓	✓	✓	✓	✓	✓	✓						
✓	✓	✓	✓	✓	✓	✓	✓	✓	✓						
✓	✓	✓	✓	✓	✓	✓	✓	✓	✓						
✓	✓	✓	✓	✓	✓	✓	✓	✓	✓						
✓	✓	✓	✓	✓	✓	✓	✓	✓	✓						
✓	✓	✓	✓	✓	✓	✓	✓	✓	✓						
✓	✓	✓	✓	✓	✓	✓	✓	✓	✓						
✓	✓	✓	✓	✓	✓	✓	✓	✓	✓						
✓	✓	✓	✓	✓	✓	✓	✓	✓	✓						
✓	✓	✓	✓	✓	✓	✓	✓	✓	✓						
✓	✓	✓	✓	✓	✓	✓	✓	✓	✓						
✓	✓	✓	✓	✓	✓	✓	✓	✓	✓						
03:30 PM	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓		↓			
✓	✓	✓	✓	✓	✓	✓	✓	✓	✓						
✓	✓	✓	✓	✓	✓	✓	✓	✓	✓						
✓	✓	✓	✓	✓	✓	✓	✓	✓	✓						
✓	✓	✓	✓	✓	✓	✓	✓	✓	✓						
✓	✓	✓	✓	✓	✓	✓	✓	✓	✓						
✓	✓	✓	✓	✓	✓	✓	✓	✓	✓						
✓	✓	✓	✓	✓	✓	✓	✓	✓	✓						
✓	✓	✓	✓	✓	✓	✓	✓	✓	✓						
✓	✓	✓	✓	✓	✓	✓	✓	✓	✓						
✓	✓	✓	✓	✓	✓	✓	✓	✓	✓						
✓	✓	✓	✓	✓	✓	✓	✓	✓	✓						
✓	✓	✓	✓	✓	✓	✓	✓	✓	✓						
✓	✓	✓	✓	✓	✓	✓	✓	✓	✓						
✓	✓	✓	✓	✓	✓	✓	✓	✓	✓						
✓	✓	✓	✓	✓	✓	✓	✓	✓	✓						
Sample Inspected Quantity	200 PCS.	Accepted Batch Quantity	7000 PCS.	Remarks											
Defects Observed (Type)	✓														
<b>Post Quality Inspection Result</b>				Inspected By (Name)		LAKSHMI		Approved By (Name)		MURIGESHAPPA R					
<input checked="" type="checkbox"/> Batch conform to the requirement and approved				Signature				Signature							
<input type="checkbox"/> Batch do not conform to the requirement and not approved				with date		12-07-2025		with date		12-07-2025					
Note: Annexure to be provided for additional test report (if required)															