

Specification Book

Section 4.1.2: Poles must be buried at least 6 feet deep.

Section 4.2.1: Conductors must be copper, not aluminum.

Section 4.2.2: Minimum clearance from ground is 12 feet.

Section 4.3.1: All bolts must be grade 8.8.

Section 4.3.2: Insulation must be rated for 600V.

Section 4.4.1: Anchors must be galvanized steel.

Section 4.4.2: Minimum anchor depth is 5 feet.

Section 4.5.1: Crossarms must be fiberglass.

Section 4.5.2: Maximum pole spacing is 150 feet.

Section 4.6.1: All hardware must be stainless steel.