

Gas Leak Emergency Procedure

Alarm Level

25 ppm

Emergency Response

Evacuate affected personnel.

Activate emergency ventilation.

Close nearby valves.

Notify emergency response team.

Possible Sources

Flange leak

Valve seal failure

Pipe corrosion

Maintenance

Replace damaged seals.

Pressure test affected section.

Verify gas detectors.