

UNIVERSITY OF ST ANDREWS / THE SCOTTISH OCEANS INSTITUTE

A compelling business case. A stronger measured outcome.

At the University of St Andrews, continuous HVAC optimisation delivered a stronger annualised financial result as fuller system control became available - building on a prudent initial forecast.

ORIGINAL COMMERCIAL FORECAST	REPORTED ANNUALISED BENEFIT	DIFFERENCE IN FINANCIAL VALUE
£12,478 per year Original gross energy-cost estimate at 2024 modelling rates	£19,400 per year Gross annualised result at the later reported energy prices	+£6,922 per year Difference in annualised £ value, including energy-price changes

With the £4,393 annual subscription unchanged, the original forecast indicated ~£8.1k net/year versus ~£15.0k at the later annualised position.

ORIGINAL FORECAST, REPRICED

£15,268 / year

Original forecast valued at 25p/kWh electricity and 6p/kWh heating.

ABOVE THE REPRICED FORECAST

+£4,132 / year

Approximately 27% above the original forecast at comparable energy prices. A further ~£2,790 of the £6,922 difference comes from the change in valuation rates.

The measured evidence behind the outcome

VERIFIED FIRST REPORTING PERIOD	SUBSEQUENT HVAC ELECTRICITY EVIDENCE
£14.4k gross savings April 2025–April 2026 158 MWh saved Includes the initial months before full fan control was available; not presented as the mature-system outcome.	26.3% in the later 12-month view July 2025–June 2026 30.1 MWh saved The September 2025–June 2026 ten-month view recorded 31.5% (29.2 MWh). These are distinct reporting windows.

Why performance developed

myCoreAI works alongside the established Siemens Desigo CC BMS, adjusting setpoints every 15 minutes. Full fan-speed control was established on 17 September 2025, enabling additional optimisation. Later results therefore better reflect the available control scope; the first reporting period includes earlier operation without full fan control.

WHAT THIS SHOWS

The original forecast established a compelling business case using prudent assumptions. Later operation demonstrated greater annualised value as fuller HVAC control became available. The £6,922 headline difference includes both improved energy-saving performance and updated energy prices; it should not be attributed to optimisation alone.

Measurement and commercial qualifications

Basis: The April 2024 assessment forecast 29,425 kWh electricity savings at 20p/kWh and 131,865 kWh heat savings at 5p/kWh; electricity savings applied to estimated controllable demand, not all site electricity. The £19,400 is a rounded annualised gross result in the St Andrews case study (weather-normalised and University-meter based), not a completed post-control year. University-confirmed February 2026 prices were 25p/kWh electricity and 6p/kWh heat; current rates may differ. Sources: EcoAI April 2024 St Andrews assessment; University tariff confirmation (Feb 2026); Gatty case study (Apr 2025–Apr 2026) and July 2026 electricity update.