Submodular Optimization for Control of Prosumer Networks

Nicolas Gensollen, Vincent Gauthier, Monique Becker and Michel Marot
CNRS UMR 5157 SAMOVAR,
Telecom SudParis/Institut Mines Telecom
Email: {nicolas.gensollen, vincent.gauthier, monique.becker, michel.marot}@telecom-sudparis.eu

Abstract—We study the placement of storage in networks of prosumers that may both consume and produce electricity using renewable generators (DER). In this stochastic context, power imbalances are very likely, such that the system might lose synchrony and require control to bring it back to the synchronized state. We consider the control inputs as being the amount of power injected in the grid at the chosed storage locations. In a context where generators and loads are stochastic and not fixed, the optimal placement of the storages beforehand is not trivial. The dynamic is written as a system of differential equations and the physical constraints of the system are included. We then propose and validate an algorithm based on a submodular optimization that minimizes the average energy required to control the system.

I. Introduction

Modernizing the power grid and increasing the share of renewables in the production are substantial objectives of the energetic transition. Because of progresses in communication, data management, and storage, the upcoming emergence of a power grid "2.0", often called smart grid, appears as a cross-disciplinary challenge of the 21st century [1].

The today centralized top-down architecture is set to evolve to more distributed and bi-directional systems. Furthermore, the emergence of renewable and stochastic distributed energy resources (DER) in the distribution networks will require more flexibility. Within these systems, it is assumed that multiple aggregation levels will be required in order to organize and optimize communication. Agents responsible for generation and load portfolio managment, the so-called prosumers [2] because they may both produce and consume electricity, will provide services (generation, load shedding, frequency regulation) against remuneration. Insure grid stability within this uncertain context appears as a complex task.

In this paper, we explore the use of storage in a network of prosumers whose power outputs are susceptible to change due to various external causes. In such a scenario with a high penetration of renewables, perturbations in the power distributions of the prosumers are very likely. Re-balancing the production and the consumption is then necessary and requires that we have the capability to control the grid's dynamic. In [3], the authors study the placement of storage equipments within microgrids in a collaborative scheme. The authors solve an interesting optimization problem mixing placement-dimensioning of storage with utilization. Moreover, [3] uses a Nash bargaining framework to determine how prosumers

should share the costs and benefits of the storages. However, [3] does not take into account the grid dynamic as well as its controllability. Control of smart grid systems has been recently studied in [4], where the authors use linear-quadratic optimal control theory in order to compute DER outputs. Control inputs rely on information collected by sensors and phasor measurement units and a communication network is used for sharing the information. The performance is then studied under practical limitations such as latency, sampling rate, or signal-to-noise ratio. The objective of [4] is the control of the system when perturbations occur. The control signals are applied to the DER, meaning that [4] does not consider a system where storage would be present and used for control.

The present work differs from [3] and [4] in that we study the placement of the storages from a controllability perspective in a stochastic context due to DER. Moreover, we aim at models and methods that could be scalable to some extent.

We are given a prosumer network and we have to find both the number and locations of the storages that should be deployed. Once this choice is made, we have to stick with it whatever perturbations may occur. We are looking for the smallest set of storages, as well as their locations, that will require small control energy. Since we do not have any prior on the future perturbations, we minimize the average control energy required to move the system around the state space.

The power grid dynamic is represented by a coupled oscillator network [5]. Each node, representing a prosumer, is modeled as an oscillator with a phase angle and a natural frequency that depends on its production/consumption. The oscillators are interconnected such that their frequencies are impacted by the ones of their neighbors. As we will see, the phase angles dynamics can be written as a system of coupled second order differential equations [5].

Optimal control theory can be used to compute the control inputs needed to restaure synchrony. However, there is no guarantee that these inputs will respect the physical constraints of the system. Electrical lines have indeed maximum capacities, and storages are also limited with bounded rates of charge/discharge which limit the possible inputs. We incorporate these constraints in the model such that the control inputs remain realistic. Furthermore, we propose an optimization method that uses submodular set functions in order to find both the number of storages and their locations such that the average control energy required to maintain stability in this

constrained system is minimized.

This paper is organized as follows, section II presents recent advances about control in networks, section III introduces the oscillator model of the grid's dynamic and derives the constraints on the control inputs. In section IV we propose the optimization method for finding the subset of driver nodes. Finally, in section V, we show performance results and validation.

II. CONTROL IN NETWORKS

In this section, we introduce some key notions related to the controllability of complex networks. We consider a graph $G = (V, E)$ of N nodes, where V is the vertex set and E is the edge set. The topology of this network can be encoded through the adjacency matrix M, which element $m_{ij} \in \{0, 1\}$ indicates whether i and j are connected. If the edges are weighted we can set $m_{ij} = w_{ij}$ where w_{ij} is the weight of edge(i, j), and zero if there is no edge. Graphs are often used to model complex interactions inside a population. Let us attribute to each node i the variable x_i that represents the state of node i. Depending on the model, this state can represent an opinion, a physical quantity, a probability and so on. If there is an edge between i and j, we might expect some interaction that would eventually change the values of x_i and x_j. Such a dynamic is usually described with a system of differential equations. If we assume a linear first order dynamic, this can be written as $\dot{X}(t) = AX(t)$, where $X(t) = \{x_0(t), ..., x_{N-1}(t)\}$ is the vector of node states at time t, and matrix A encodes both the dynamics and the topology of the system (A can be, among other, the weighted adjacency matrix of the underlying graph).

If there is no action from the outside, the system state will evolve according to $X(t) = X_0 e^{At}$ where X_0 is the initial state of the system. Imagine now, that this dynamic could be somehow influenced by injecting some signals. More precisely, let us assume that we can inject these signals in a subset of the nodes, called drivers, such that the dynamics becomes $\dot{X}(t) = AX(t) + Bu(t)$, where the matrix B indicates which nodes receive the signals and $u(t)$ is the vector of inputs at time t. Assume that the system is in some initial state X_0 and we aim at bringing it to some final state X_T in some amount of time T. Control can be seen as finding the sequence of inputs $\{u(t_0), ...u(t_T)\}$ that would do it given the dynamics A. Furthermore, we say that the system is controllable in T steps if it can be steered from any initial state X_0 to any final state X_T through a sequence of control inputs.

It was shown by Kalman that a linear system (A, B) is controllable if the controllability matrix $C = [B, AB, A^2B, ..., A^{N-1}B]$ has full rank, that is, $rank(C) = N$. Nevertheless, when studying the controllability of non trivial networks, using the Kalman's criterion is not a simple task since matrix C becomes huge. Furthermore numeric precision becomes quickly an issue when computing the rank of C. A different approach to study controllability in complex network was introduced later on by Lin [6]. This relates the search of the minimum driver set to a maximum matching in a bipartite graph, which can

be done with the Hopcroft-Karp algorithm in $O(|E|\sqrt{|V|})$ in the worst case. This requires that the system (A, B) is a structured system, meaning that all elements in A and B are either fixed zeros or independant free parameters. In such a situation, structural control is extremely powerfull since it allows to discuss network control easily even if the exact weights of the edges are unknown. Note however that the independance of the parameters is a key assumption. If A is the adjacency matrix of an undirected network for instance, independance is not verified (since A is symmetric). In this case, one should use different tools to study controllability [7].

The fact that a system is controllable or not is not the only criterion of interest. Indeed, if it is controllable, the amount of control energy required also appears as a key criterion. Actually, if the system is controllable, there might be more than one sequence of control inputs $u(t)$ that could drive it from X_0 to X_T. Among all these possibilities, optimal control is devoted to find the sequence that minimizes some cost function that can depend on the states of the system $X(t)$, the control inputs $u(t)$, and the final state X_T. In the following, these control inputs will be used to model the actions of storage devices in a power grid. We are therefore particularly interested in the sequence that requires the minimum amount of control energy [8]. Let $\mathcal{E} = \int_0^T \|u(t)\|^2 dt$ be the energy used for the control of the system. It can be shown [9] that the control inputs that minimize $\mathcal{E}$ can be written as :

$$u^\star(t) = B^T e^{A^T(T-t)} W^{-1}(T) v_f \qquad (1)$$

where $\nu_f = X_T - X_0 e^{AT}$ is the difference between the desired final state X_T and the final free state $X_0 e^{AT}$, and $W(t) = \int_0^t e^{A\tau} BB^T e^{A^T\tau} d\tau$ is called the Gramian matrix of the system. It can also be shown that the system is controllable if and only if the Gramian is not singular, and that its rank indicates the dimension of the controllable subspace. Besides, the minimum control energy associated with the inputs $u^\star(t)$ can be written as :

$$\mathcal{E}_{min} = \nu_f^T W^{-1}(T) \nu_f \qquad (2)$$

In cases where W is not invertible, the pseudo-inverse $W^\dagger$ can be used to obtain similar information in the controllable subpsace.

III. MODEL DESIGN FOR POWER GRID DYNAMICS

A. Grid dynamic without constraint

In this section, we introduce the coupled oscillators network model used to simplify the power grid dynamic. More details can be found in [5].

The objective is to achieve synchronization of the grid at the main frequency $\Omega = 50Hz$. Each oscillator i has a phase angle δ_i and a frequency $\dot{\delta}_i$. Therefore, we seek an equilibrium of the form : $\forall i, \ \dot{\delta}_i = \Omega$. For convenience, we express the dynamic of the oscillators in terms of the deviations from the main frequency : $\delta_i(t) = \Omega t + \theta_i(t)$. Let $\omega_i = \dot{\theta}_i$, such that $\dot{\delta}_i =$

$\Omega + \omega_i$. The equilibrium, in terms of the deviations dynamics, is : $\forall i, \ \omega_i = 0$

The next step consists in translating the dynamics of the generators and machines into equations involving the phase angles θ_i and the frequencies ω_i. Generators and machines are composed of a turbine that dissipates energy at a rate proportional to the square of the angular velocity :

$$P_{diss,i}(t) = K_{Di}(\dot{\delta}_i(t))^2 \qquad (3)$$

where K_{Di} is the dissipation constant of entity i. Furthermore, it also accumulates kinetic energy at a rate :

$$P_{acc,i}(t) = \frac{1}{2} I_i \frac{d}{dt}\left(\dot{\delta}_i(t)^2\right) \qquad (4)$$

where I_i is the moment of inertia of entity i. For simplicity, we consider that all entities have the same dissipation constants(K_D) and moment of inertia (I).

The condition for the power transmission between i and j is that the two devices do not operate in phase. The phase difference between i and j is : $\delta_j(t) - \delta_i(t) = \Omega t + \theta_j(t) - \Omega t - \theta_i(t) = \theta_j(t) - \theta_i(t)$. The transmitted power along the line can be written as :

$$P_{transmitted} = -P_{ij}^{MAX} sin(\theta_j - \theta_i) \qquad (5)$$

with P_{ij}^{MAX} being the maximum capacity of the line (i,j). Each entity i is then described by a power balance equation of the type :

$$P_{S,i} = P_{diss,i} + P_{acc,i} + P_{transmitted,i}, \qquad (6)$$

where $P_{S,i}$ is the power of an ideal source or sink at node i. By substituting equations 3, 4, and 5 into equation 6 and re-arranging the terms, we obtain the following non-linear coupled system of equations :

$$P_{S,i} = I\Omega\ddot{\theta}_i + \left[I\ddot{\theta}_i + 2K_D\Omega\right]\dot{\theta}_i + K_D\Omega^2$$
$$+ K_D\dot{\theta}_i^{\ 2} - \sum_{j\in\mathcal{N}_i} P_{ij}^{MAX} sin\left[\theta_j - \theta_i\right] \qquad (7)$$

We now use simplifications based on the fact that we consider small deviations from the main frequency : $\dot{\delta}_i \sim \Omega$ which means that $\omega_i = \dot{\theta}_i << \Omega$, such that the squared term $K_D\dot{\theta}_i^2$ can be neglected. Moreover, we assume that the rate at which energy is stored in the kinetic term is much less of the rate at which energy is dissipated by friction : $\ddot{\theta}_i << \frac{2K_D}{I}$ (see [5] for more details). Equation 7 becomes :

$$\ddot{\theta}_i \sim \psi_i - \alpha\dot{\theta}_i - \sum_{j\neq i} K_{ij} sin\left[\theta_j - \theta_i\right], \qquad (8)$$

where $\alpha = \frac{2K_D}{I}$ is the dissipation term, $K_{ij} = \frac{P_{ij}^{MAX}}{I\Omega}$ are the coupling strengths, $\psi_i = \left[\frac{P_{S,i}}{I\Omega} - \frac{K_D\Omega}{I}\right]$. In order not to overload the equations, we simplify the constant term $\frac{K_D\Omega}{I}$ by working in a rotating frame such that $\psi_i = \frac{P_{S,i}}{I\Omega}$.

The dynamic is still non linear because of the sine coupling. Therefore, we also assume that the phase angle differences

are small such that $sin\left[\theta_j - \theta_i\right] \sim \theta_j - \theta_i$. By using vector notations, the dynamic can be written in the following form :

$$\ddot{\theta} = \Psi - \alpha\dot{\theta} - (K \circ L)\theta \qquad (9)$$

Where $A \circ B$ represents the Hadamard product between matrices A and B, and L is the Laplacian matrix of the underlying topology ($L_{ij} = k_i$ if $i = j$ and $L_{ij} = -m_{ij}$ otherwise). Equation 9 is a continuous time second order linear system of N equations.

By introducing $X = \begin{pmatrix} \theta \\ \dot{\theta} \\ 1 \end{pmatrix}$, we transform this into a first order linear system of $2N + 1$ equations, which is discretized with time step Δt, leading to :

$$X(t + \Delta t) = AX(t) \qquad (10)$$

With transition matrix A :

$$A = \begin{pmatrix} I & I\Delta t & 0 \\ -(K \circ L)\Delta t & (1 - \alpha\Delta t)I & \Psi\Delta t \\ 0 & 0 & 1 \end{pmatrix} \qquad (11)$$

Note that the transition matrix A encodes all the system parameters, topology, and power distribution. So far we have expressed the grid dynamic as a coupled oscillators network, but we did not incorporate the different physical constraints on the network.

B. Flow Constraints

[10] showed that a condition for synchronisation in a coupled oscillators network is $\|L^\dagger \omega\|_{\infty,E} \leq sin(\gamma)$, where $L^\dagger$ is the Moore-Penrose pseudo inverse of the Laplacian matrix of the network, ω is the vector of the natural frequencies of the oscillators, and $\|x\|_{\infty,E} = max_{(i,j)\in E}|x_i - x_j|$. If this condition is satisfied, the oscillators synchronize at the common frequency ω_{SYNC} with the phase lock $|\theta_i - \theta_j| \leq \gamma \in [0, \frac{\pi}{2}], \ \forall(i,j) \in E$.

On the other hand, the power that flows on line $(i,j) \in E$ can be written as $P_{i\longrightarrow j} = -P_{ij}^{MAX} sin\left(\theta_j(t) - \theta_i(t)\right)$. If $\theta_j(t) - \theta_i(t)$ is small, the flow constraints at time t are straightforward :

$$\forall(i,j) \in E, \ | \ \theta_j(t) - \theta_i(t) \ | \leq 1 \qquad (12)$$

If these constraints are verified for all instants t during the control phase then no line gets overloaded by the action of the control inputs. Writing the synchronisation condition in our settings thus gives :

$$\| (L \circ K)^\dagger \Psi\|_\infty \leq sin(1) \qquad (13)$$

If constraint 13 is satisfied, the oscillators synchronize to a common frequency $\omega_{SYNC} = \frac{\sum_{k=1}^N \Psi_k}{\sum_{k=1}^N \alpha_k} = \frac{\sum_{k=1}^N P_{S,k}}{I\Omega N\alpha}$.

Since the dynamics is expressed in term of deviations from Ω, synchronization at Ω is achieved if $\omega_{SYNC} = 0$. Which gives the production consumption balance constraint :

$$\sum_{k=1}^{N} P_{S,k} = 0 \qquad (14)$$

Constraints 12 13 and 14 ensure that the system is able to synchronize at Ω without overloading lines.

C. Battery Constraints

A storage i has a maximum charge/discharge rate r_i, some amount of energy stored $\Lambda_i(t)$ at time t, and a maximum capacity $\Lambda_{i,MAX}$. We assume that all maximum rates (r) and all maximum capacities Λ_{Max} are the same accross the storage equipments. We also denote by $\Lambda(t)$ the vector of energy level at time t. Since $u^\star(t)$ specifies the control inputs, the energy level dynamic of the batteries is $\Lambda(t+\Delta t) = \Lambda(t) - u^\star(t)I\Omega$. Which can also be written as :

$$\Lambda(t) = \Lambda(0) - I\Omega \sum_{k=0}^{t} u^\star(k) \qquad (15)$$

where $\Lambda(0)$ is the vector of initial levels in the batteries. Obviously, $\Lambda(t)$ has to stay within possible bounds : $\forall t, \quad 0 \le \Lambda(t) \le \Lambda_{MAX}$. Which can be written in terms of the control inputs :

$$\forall t, -\frac{\Lambda(0)}{I\Omega} \le -\sum_{k=0}^{t} u^\star(k) \le \frac{\Lambda_{MAX} - \Lambda(0)}{I\Omega} \qquad (16)$$

During each time slot, the battery cannot charge or discharge at a rate higher than r :

$$\forall t, \quad \mid u^\star(t)I\Omega \mid \le r \qquad (17)$$

We now arrive at the main question of the present paper, given the dynamic of equation 10 and the constraints of equations 12, 13, 14, 16, and 17, how can we select the driver nodes such that we use low control energy on average ?

IV. Finding the driver nodes

In this section, we explain the method that we used in order to find the driver nodes for the grid's dynamic (eq. 10).

A. Gramian based optimization

Recall that $\mathcal{E}_{min}$ (see eq. 2) depends on the initial and final states as well as on the inverse of the gramian matrix W, which only depends on A and B. W can thus be used to obtain information about the average control energy required to move the system in the state space. In the prosumer network that we consider, generators and loads (Ψ) are suceptible to change, meaning that initial (X_0) and final (X_f) states might also vary. In such a scenario, we prefer to aim at good performance on average, rather than very good performance in few specific cases and bad performance in all other situations.

Since the control energy is related to W^{-1}, systems with "large" W will tend to be controlled with low energy. Still, this notion of "large" W is not very accurate and we need to quantify it by taking some metric based on W. We already mentioned the rank of W as being the dimension of the

controllable subspace, but it is also known that the trace of W and W^{-1} give information about average controllability and average control energy [11]. In such a situation, we can build a set function that, given a set of driver nodes S, returns the value of one of these metrics. Indeed, given A and S, we can obtain the system dynamics (A, B_S) and compute the gramian W_S. In other word, such a function would quantify the ability of a given set of nodes to contol the system on average. The objective would then be to find the set $S_k^\star$ of size k that maximizes this function.

A key point, demonstrated in [11], is that the set function $F : S \longrightarrow Tr[W_S]$ is modular and the two functions $F : S \longrightarrow Tr[W_S^{-1}]$ ans $F : S \longrightarrow rank[W_S]$ are submodular. As we will see in the next section, this nice result enables us to look for the driver node set that optimizes the average control energy with a simple greedy heuristic that also provides a worst case guarantee.

B. Submodularity

We introduce here submodular set functions and explain how their maximization can be achieved in reasonable time. More information about submodularity can be found in [12].

A set function $F : 2^V \longrightarrow \Re$ defined over a finite set V is said to be submodular if for all sets $X, Y \in V$, such that $X \subseteq Y$ and for all element $x \in V \setminus Y$, we have :

$$F(X \cup \{x\}) - F(X) \ge F(Y \cup \{x\}) - F(Y) \qquad (18)$$

This basically means that submodular functions exhibit a diminishing return property which makes them particularly interesting for optimization. Generally speaking, finding the set $S_k^\star$ of size k that maximizes a set function F is a difficult problem because the number of sets grows exponentially with the number of nodes. Therefore complete enumeration and evaluation is only feasible on very small examples. Nevertheless, if the set function is submodular, a simple greedy heuristic returns a solution $S_k^\star$ such that, in the worst case, $\frac{F(S_k^\star)}{F(S_k^{OPT})} \sim 63\%$ (where S_k^{OPT} is the optimum set of size k) [12]. This heuristic starts with a set S (possibly empty) and iteratively adds the element i that exhibits the highest marginal gain : $F(S \cup \{i\}) \ge F(S \cup \{j\}) \; \forall j$.

For a ground set of N elements, this heuristic computes F $\frac{k(2N-k+1)}{2}$ times. Since the evaluation of F can be costly, a well-known lazy-greedy variation has been proposed by [13]. This smart implementation uses the submodular structure of the marginal gains in order to reduce the number of calls to F. This requires to maintain a sorted table of marginal gains for all elements. When looking for new element i to add to set S, the top one is selected and the new marginal gain $F(S \cup \{i\}) - F(S)$ is computed. If this gain is larger than the gain of the second element in the table, then i is added to S. Otherwise i is inserted back in the table with its updated gain and the same treatment is applied to the element that is now on the top of the table. Because of the submodularity of F, this method performs as well as the original one, but can result in speedups of several order of magnitudes.

Figure 1: At $t = 800$, P_5 goes from -1 to -2 (power imbalance). Consequently, the frequencies $\dot{\theta}_i$ deviate from the synchronized state. At $t = 1000$, optimal control inputs (see equation 1) are injected at nodes 0, 2, and 4 (nodes with ellipses) such that the system is brought to the synchronized state at time $t = 1500$ (control time $T = 500$).

Theoretically, we are now able, for a given prosumer network, to compute A, B, and W. For some trajectory in the state space, we can use equation 1 to find the optimum control inputs. However, these inputs do not take into account the physical constraints on the possible trajectories due to lines and batteries finite capacities.

C. Optimization with grid constraints

Finding the driver set S_k of size k using the gramian W_{S_k} of the system (A, B_{S_k}) does not require initial and final states. Besides, W_{S_k} does not depend on the modified power distribution Ψ of the nodes. We are indeed looking for k controllers that perform well on average over all possible situations. On the contrary, the constraints derived above (eq. 12, 13, 16 and 17) are bounded to a particular trajectory in the state space. We indeed check wether the power grid can sustain the controlled dynamics when transitioning from a given initial state to a target final state. As we do not know what these states could be, we could use multiple scenarios and test wether S_k can control the system without violation of constraints. In this paper, we use a slightly different approach. We consider that the system is initially at equilibrium (all elements are synchronized at Ω) and that control will be necessary if a perturbation (power imbalance) occurs and takes the system out of equilibrium (see figure 1). Depending on how much time we need to start the control phase, the state of the system (the initial state for control) might be "somewhere around" the synchronized state. In order to test wether a set S_k can control the system without violation of constraints, we sample initial states within some hypersphere centered on the synchronized state and check all the constraints. If for all trajectories, the constraints are respected, then we consider that S_k enables the control of the system.

Increasing k means that we deploy more strorage which increases the costs but tends to lower the energy required as we will see in the next section. Using the submodularity of the set functions introduced above, we can build a sequence of growing sets $S_1 \subset S_2 \subset ... \subset S_k$ and stop as soon as S_k enables the control of the system for some k.

Algorithm 1 Optimization with grid constraints

$k = 0$
$S_k = \emptyset$
while Not Constrained control **do**
$\quad k \leftarrow k + 1$
$\quad S_k = S_{k-1} \cup argmax_{i \in N \setminus S_{k-1}} F(S_{k-1} \cup \{i\})$
end while

V. RESULTS

The purpose of selecting the drivers according to a Gramian related metric is to minimize, on average, the amount of control energy needed. Conversely, if we select the drivers randomly, we expect to need, on average, more energy to control the system. In figure 2, we compare the average control energy $\mathcal{E}$ in function of the proportion of drivers among the total number of nodes $n_D = N_D/N_{nodes}$, for a set of drivers selected thanks to our algorithm with randomly selected drivers (in both cases overloading and battery limits constraints are satisfied). We draw 10^4 scale-free topologies with 50 nodes, and random power distributions and line capacities. For each system we select a random number of drivers $N_D \sim \mathcal{U}(1, N_{nodes})$ and we find two driver sets of size N_D. One is chosen randomly and the other is found with algorithm 1. For both sets, if the control is possible, we draw a random initial state Y_i and a random final state Y_f, and we compute the control energy required for driving the system from Y_i to Y_f. Since the algorithm is based on $Tr[W^{-1}]$, we could plot $Tr[W^{-1}]$ in function of n_D but we prefer to validate our method by computing the actual average energy. As expected, both curves decrease as the number of drivers increases, meaning that, as the number of drivers grows, the average control energy tends to decrease, but we tend to use less energy when the drivers are selected with our algorithm. Note that this difference tends to zero when n_D tends to one, because almost all nodes are then selected, yielding little flexibility for optimization.

We investigate next how the topology of the grid and the physical constraints affect the minimum size of the driver set. n_D is no longer selected randomly, but minimized. We consider the simple case of an Erdös-Rényi topology with probability of connection p. We show on Figure 3 how the minimum size of the driver set evolves with p for different Gramian based metrics and for two levels of constraints :

- Level 1 : full control and grid constraints (see section III). The system is controllable (i.e it can be moved from any point to any other point) and under the constraints (i.e it can be moved without overloading any line or breaking any battery limits).

Figure 2: $log(\mathcal{E})$ against n_D for random and optimized driver sets ($N_{nodes} = 50$).


Figure 3: n_D against link probability p for erdos-renyi topologies ($N = 100$). Curves are averaged over 100 realizations. The top three curves show the results for the three metrics taken into consideration when all constraints are considered (see Level 1 in the main text). The bottom three curves exhibit the results for the same metrics when only the full controllability constraint is considered (see Level 2).

- Level 2 : full control only : the system can be moved from any point to any other point of the state space, without considering any overloading or battery limit constraints.

When $p \sim 0$, nodes tend to be very poorly connected such that we need to control almost all nodes in the grid. As p increases, the connectivity of the graph rises and the number of drivers decreases. At some point, the connectivity of the graph starts to harm its controllability, and more drivers are needed (this effect is in accordance with the litterature). As expected, the driver sets for the level 1 of constraints are larger than for level 2 (for all metrics) because we impose far more constraints on the control inputs.

VI. Conclusion

In this paper, we considered the case of networks of prosumers which can behave as generators or loads depending on

weather conditions. We believe that the originality of this work was to study the storage placement in such a stochastic context through the optimal control theory. This approach enabled us to take the grid's dynamic and its physical constraints into account. Because perturbations could be of any kind, and because we only place the storages once, we proposed an optimization method, that rely on submodular set functions and the gramian matrix, for minimizing the average energy that should be injected or absorbed by the storage equipments.

We believe that interesting work could be done by combining this model with real production and consumption data. There are indeed complex spatial and temporal correlations that impacts these distributions [14]. Weather perturbations would therefore affect the nodes not completely at random, and affect how control should be designed.

REFERENCES

[1] S. D. Ramchurn *et al.*, "Putting the 'smarts' into the smart grid: A grand challenge for artificial intelligence," *Commun. ACM*, vol. 55, no. 4, pp. 86–97, Apr. 2012.

[2] Y. Parag and B. K. Sovacool, "Electricity market design for the prosumer era," *Nature Energy*, no. March, p. 16032, 2016. [Online]. Available: http://www.nature.com/articles/nenergy201632

[3] L. Gkatzikis, G. Iosifidis, I. Koutsopoulos, and L. Tassiulas, "Collaborative placement and sharing of storage resources in the Smart Grid," *2014 IEEE International Conference on Smart Grid Communications, SmartGridComm 2014*, pp. 103–108, 2015.

[4] A. Farraj, E. Hammad, and D. Kundur, "On Using Distributed Energy Resources to Reshape the Dynamics of Power Systems During Transients," *2015 IEEE International Conference on Smart Grid Communications, SmartGridComm 2015*, pp. 756–761, 2015.

[5] G. Filatrella, a. H. Nielsen, and N. F. Pedersen, "Analysis of a power grid using a Kuramoto-like model," *The European Physical Journal B*, vol. 61, no. 4, pp. 485–491, mar 2008. [Online]. Available: http://www.springerlink.com/index/10.1140/epjb/e2008-00098-8

[6] C.-T. Lin, "Structural controllability," *IEEE Transactions on Automatic Control*, vol. 19, no. 3, pp. 201–208, Jun 1974.

[7] Z. Yuan, C. Zhao, W. X. Wang, Z. Di, and Y. C. Lai, "Exact controllability of multiplex networks," *New Journal of Physics*, vol. 16, 2014.

[8] G. Yan, J. Ren, Y. C. Lai, C. H. Lai, and B. Li, "Controlling complex networks: How much energy is needed?" *Physical Review Letters*, vol. 108, no. 21, pp. 1–5, 2012.

[9] Y.-Y. Liu and A.-L. Barabási, "Control Principles of Complex Networks," pp. 1–55, 2015. [Online]. Available: http://arxiv.org/abs/1508.05384

[10] F. Dörfler, M. Chertkov, and F. Bullo, "Synchronization in complex oscillator networks and smart grids." *Proceedings of the National Academy of Sciences of the United States of America*, vol. 110, no. 6, pp. 2005–2010, 2013. [Online]. Available: http://www.ncbi.nlm.nih.gov/pubmed/23319658

[11] T. Summers, F. Cortesi, and J. Lygeros, "On Submodularity and Controllability in Complex Dynamical Networks," *arXiv preprint arXiv:1404.7665*, pp. 1–10, 2014. [Online]. Available: http://arxiv.org/abs/1404.7665

[12] A. Krause and D. Golovin, "Submodular function maximization," *Tractability: Practical Approaches to Hard Problems*, vol. 3, pp. 71–104, 2014.

[13] M. Minoux, "Accelerated greedy algorithms for maximizing submodular set functions," in *Optimization Techniques*, ser. Lecture Notes in Control and Information Sciences, J. Stoer, Ed. Springer Berlin Heidelberg, 1978, vol. 7, pp. 234–243. [Online]. Available: http://dx.doi.org/10.1007/BFb0006528

[14] N. Gensollen, V. Gauthier, M. Marot, and M. Becker, "Coalition Formation Algorithm of Prosumers in a Smart Grid Environment," pp. 5896–5902, 2014. [Online]. Available: http://arxiv.org/abs/1410.8776