

Government of Tripura
Directorate of Fire & Emergency Services
Tripura, Agartala.

Phone: 0381-2326451. Fax: 0381-2324826. Email: dfireservicetripura@gmail.com. Website: www.fireservice.tripura.gov.in

No.3-8/TFES/2021/ **3684-86**

Dated, Agartala, the **30th** March, 2021.

To
The Secretary,
Saint John's High School,
Rio, Killa, Udaipur, Gomati Tripura.
Email- saintjohnschool@rediffmail.com.
Mobile No. 7005975477.

Subject: - Issuance of Renewal Fire NOC.

With reference to your compliance report under letter No. F. 42(1)/SCY/STJHS/RIO/UDO/Fire Service/2013/314 dated 23.02.2021, it is hereby certified that the building /premises as per description below has been inspected by the officer concerned of this Department on 10.03.2021. In respect of implementation of Fire Safety measures, it was found that said building have complied with the Fire Prevention and Fire Safety requirements in accordance with provisions of the Part-4 of the latest National Building Code, 2016. The premises/building is issued NOC with effect from **30.03.2021** for a period of 01 (one) year subject to compliance of the conditions for the validity of Fire NOC.

Name & address of the proposed building / premises: - Saint John's High School, Rio, Killa, Udaipur, Gomati Tripura.
--

Issued on 30/03/2021 at Agartala.


Joint Director,
Tripura Fire & Emergency Services.

Conditions for the Validity of Fire NOC.

1. All the fire safety and means of escape facilities shall be maintained in good working condition at all times. Any lapse in this regard shall make the owner /management liable for action.
2. There should not be any change of Trade for which this License has been issued.
3. Building sanctioning authority may verify any deviation with regard to the construction / occupancy in the building. In case of any deviation, the Fire Safety Certificate stands null and void.
4. Water reservoir should always be kept full up to the brim.
5. The entrance and exit and the water reservoir should always be free from any obstructions.
6. The staff shall be trained for operating fire fighting system and mock evacuation drills be conducted at regular intervals and record be maintained.

Copy to :-

1. The Divisional Fire Officer, Gomati Tripura, Udaipur for information.
2. OC, Udaipur Fire Station for favour of Information.