Evidence of Performance

Airborne sound insulation of building elements

Test report 163 33841/Z2e

This is a translation of the test report 163 33841/Z2 of 20th June 2007.



Client

Press Glas S.A. **Nowa Wies** Kopalniana 9

42-262 Poczesna Poland

Foundation

EN ISO 140-1:1997+A1:2004 EN 20140-3:1995+A1:2004 EN ISO 717-1: 1996+A1:2006

Isolation glass unit Product Float 8 mm / 16 / 55.2 Thermofloat Stratophone Ar. Designation 1230 mm × 1480 mm Size $(w \times h)$


8/16/10 LG SI Construction Gas filling Argon Area related

Special items

weight

45,5 kg/m²

Representation



Informations for use

This test report may be used to validate the sound reduction of a building element.

Validity for germany:

 R_w corresponds to $R_{w,P}$ for DIN 4109 Annex 1 table 40

Validity

The data and results given relate solely to the described, tested object.

Testing the acoustic properties does not allow any statement to be made on further characteristics of the present structure which could define performance and quality.

Weighted sound reduction index R_w Spectrum adaptation terms C and C_{tr}



 $R_w(C; C_{tr}) = 44 (-3; -7) \text{ dB}$

Notes on publication

The ift notice "Conditions and notes for the use of ift test documents" applies.

The cover sheet can be used as a summary.

Contents

This test report includes 6 pages

- Test specimen
- Test procedure
- Test results
- Instructions for use Data sheet (1 page)

ift Rosenheim 20. Juni 2007

Dr. Voachim Hessinger, Opl.-Phys Head of test laboratory ift centre for acoustic

Bernd Saß, Dipl.-Ing. (FH vice head of test laboratory ift centre for acoustic