Evidence of Performance

Airborne sound insulation of building elements

Test report 163 33053/Z3e

This is a translation of the test report 163 33053/Z3 of 16th February 2007. ROSENHEI



Client

Press Glas S.A. Nowa Wies Kopalniana 9

42-262 Poczesna Polen

Product	Isolation glass unit
Designation	33.1 Silence / 16 / Thermofloat 6 mm Ar.
Size (w × h)	1230 mm × 1480 mm
Construction	6 LG SI/16/6
Gas filling	Argon
Area related weight	30,2 kg/m²
Special items	-/-

Weighted sound reduction index R_w Spectrum adaptation terms C and C_{tr}




 $R_w(C; C_{tr}) = 40 (-2;-6) dB$

Foundation

EN ISO 140-1:1997+A1:2004 EN 20140-3 :1995+A1:2004 EN ISO 717-1 : 1996+A1:2006

Representation



Informations for use

This test report may be used to validate the sound reduction of a building element.

Validity for germany:

 R_w corresponds to $R_{w,P}$ for DIN 4109 Annex 1 table 40

Validity

The data and results given relate solely to the described, tested object.

Testing the acoustic properties does not allow any statement to be made on further characteristics of the present structure which could define performance and quality.

Notes on publication

The **ift** notice "Conditions and notes for the use of **ift** test documents" applies.


The cover sheet can be used as a summary.

Contents

This test report includes 6 pages

- 1 Test specimen
- 2 Test procedure
- 3 Test results
- 4 Instructions for use Data sheet (1 page)

ift Rosenheim 16. Februar 2007



Bernd Saß, Dipl.-Ing. (FH) vice head of test laboratory ift centre for acoustic