

SAMPLE REPORT — illustrative data, not a real client's figures. This is what your monthly email will look like once you're logging data.

Sunnyvale Rooftop Array

Monthly generation report — July 2026

2,487.39 kWh

-14.5% vs. last month · -19.8% vs. expected

Per-inverter breakdown

Inverter 1	666.58 kWh
Inverter 2	584.31 kWh
Inverter 3	662.31 kWh
Inverter 4	574.19 kWh

Performance

Capacity Utilization Factor

12.7%

Specific yield

94.2 kWh/kWp

Estimated savings

Rs. 21,143

Estimated CO2 offset

1,781 kg

Flags raised this month

- Inverter 4's generation is 55% below its 30-day average (last 7 days: 12.9 kWh/day vs 25.1 kWh/day).
- No reading logged for Inverter 2 for 3 days (last: Jul 29).

Savings and CO2 figures are estimates, not certified measurements. View the live dashboard at <https://your-solar-dashboard.vercel.app/dashboard>.