

SAMPLE REPORT — illustrative data, not a real client's figures. This is what your monthly email will look like once you're logging data.

Sunnyvale Rooftop Array

Monthly generation report — July 2026

2,653.54 kWh

-18.5% vs. last month

Per-inverter breakdown

Inverter 1	668.54 kWh
Inverter 2	654.43 kWh
Inverter 3	667.57 kWh
Inverter 4	663 kWh

Performance

Capacity Utilization Factor

13.5%

Specific yield

100.5 kWh/kWp

Estimated savings

Rs. 22,555

Estimated CO2 offset

1,900 kg

Flags raised this month

- Inverter 4's generation is 55% below its 30-day average (last 7 days: 12.9 kWh/day vs 25.1 kWh/day).
- No reading logged for Inverter 2 for 3 days (last: Aug 14).

Savings and CO2 figures are estimates, not certified measurements. View the live dashboard at <https://your-solar-dashboard.vercel.app/dashboard>.