



**HINDUSTAN COPPER LIMITED
INDIAN COPPER COMPLEX.
MOUBHANDAR WORKS.
GHATSILA-832103
JHARKAND.**

Dated: 20 July, 2015

NO: HCL/ICC/PP-ALT/2015

Notice for “Pre-Application Conference”

Sub: “Pre-Application conference meeting” for undertaking supply, erection & commissioning of utility service equipments (Steam & Power) required for smelter & refinery plant at HCL’s Ghatsila unit, Jharkhand.

1.0 Hindustan Copper Limited (HCL), a public sector undertaking under the administrative control of the Ministry of Mines, was incorporated on 9th November 1967. It is the only vertically integrated copper producing company with presence in mining, beneficiation, and smelting, refining and downstream saleable products. The company has its corporate and registered office in Kolkata and has four operating units namely Malanjkhand Copper Project, Malanjkhand M.P, Khetri Copper Complex, Khetrinagar, Rajasthan, India Copper Complex, Ghatsila Jharkhand and Taloja Copper Project, Taloja, Maharashtra. Further details about the company and its operations can be obtained from its website www.hindustancoper.com.

1.1 HCL invites Companies, having experience and capabilities of executing engineering, procurement and construction (EPC) projects for utility services at metallurgical plants, to a pre-application conference meeting. The details of venue, date & time are given below:

**Venue: Conference Hall, R&D Department,
HCL/ ICC Moubhandar Works,
Ghatsila. Jharkhand.
Date: 10th AUG. 2015
Time: 11.0 am onwards**

1.2 Participation in the meeting, although encouraged, is optional and not mandatory for submission of the Tenders. The interested parties are requested to undertake site visit at HCL/ICC Moubhandar Works, Ghatsila to understand the field requirements, conditions and scope of supply and work.

1.3 The interested parties are requested to depute senior technical personnel to attend the conference to participate in the technical interactive session and are requested to make a presentation (if required) of about 10 minutes, highlighting their key technical capabilities.

2.0 Objective:

HCL intends to explore potential vendors for **Study, Design, engineering, supply, installation, testing and commissioning of plants as per prescribed technology scheme:-**

2.1. Uninterrupted Supply of Saturated Steam for process requirement of Smelter & Refinery.

2.2. Supply of High volume blast air at low Pressure for Copper Converting Operations at Smelter.

2.3. Convertor tilting arrangement in case of Power Failure.

2.4. To meet the Emergency Power requirement of Plant in case of Grid power failure.

2.5. Alternative Option for Turbo feed Pump & Turbo Circulating Pump of Waste-Heat-Boiler attached to Flash Furnace of Smelter Plant.

3.0 Desired technology scheme:-

3.1. FO Fired Package Boiler -For supply of Process-Steam(Saturated) -02 Nos. (1W + 1 S/by).

Net Steaming Capacity- 14 TPH.+(-)5%

Outlet Steam Pressure- 12 Kgs/Cms.Sq.(g).+(-)5%

Preferred Make:- BHEL/THERMAX/Isgec John Thompson (IJT)/OR any other reputed make.

3.2. Electric Driven Motor Blowers for Copper Converting Operations.-02 Nos. (1W+1S/by)

Design Air Volume Flow - 15000 Nm³/hr.

Design Outlet Air Pressure-2.21 Kg/Cms.Sq. absolute

Normal Operating Conditions of Blowers:-

Air Volume- 18000 to 20000 Nm³/hr.

Air Pressure- 0.8 to 0.9 Kg/Cms. Sq.(g).

Preferred Make- Howden/SIEMENS/Man Turbo/OR any other reputed make.

3.3. Air Motors Complete Set along with Electric Motor, Gear Box, VVFD, PLC & Compressors, for Converter tilting in case of Power failure. (02 SETS- 01 each for 02 Nos. Converter).

Radial Piston Air Motors-5.82 KW.

Motor RPM-950

Air Pressure-06 bar.

Magnetic Coupling- 24 V DC.

Electric Motor- 45 KW, 1500 RPM, 415 V, 50 Hz.

Preferred Make- MUKAND/ OR any other reputed make.

3.4. DG Sets for Essential Power requirement of Plant in case of grid failure.

(a.) 2000 KVA, 11 KV DG Sets for intermittent operation during grid failure.-02 Nos.(1W+1 S/by).

(b.) 100 KVA, 415 V DG Set-01 No. for intermittent operation during Copper Anode Casting.

Preferred Make- WARTSILA/JACKSON/KIRLOSKAR/OR any other reputed make.

3.5. Small Steam Turbines-3000 RPM (Prime Mover for Waste-Heat-Boiler's Turbo Feed Pump -75 KW -01 No. & Turbo Circulating Water Pump-22 KW-01 No.) to be operated with Saturated Steam- Operating Steam Pressure-11 bar. Temp.-185 deg.C.

Preferred Make- SIEMENS TURBO MACHINERY/BHEL/ Or any other reputed make.

(a.) Boiler Feed Pump details:-

Make: - KSB Pumps Ltd.

Type-HAD-50/12. Sl.No.-9019103.

Head-620 mlc. RPM-2975.

Capacity-15 m³/hr.

KW-75. HP-100.

(b) Boiler Circulating Water Pump details:-

Make: - SULZER, KARHULA, FINLAND.

Type: - NEH-K10H-1. Sl. No.-Z-24236.

Head-40 meters. Flow-1500 Ltrs./min. (90 TPH).

Speed-2900 RPM. Power-22 KW.

4.0 Who should attend the Pre-Application Conference Meeting:

Companies having experience and capabilities of successfully executing engineering, procurement and construction (EPC) projects related to utility services at metallurgical plants. The Prospective bidders having the above experience as a single entity may attend the Pre-Application Conference meeting.

5.0 The interested parties are requested to undertake site visit at HCL/ICC Moubhandar Works to familiarize themselves with the site conditions and understand the field requirements, conditions and scope of supply and work and contact Shri S.K. Jha, AGM (Mech.), Contact No. 09430185390 / 08102921090/mail- shravan_kj@hindustancopper.com for any assistance. Further enquiry regarding this notice may be directed to the following official:

Name, Designation	Address	Phone No	e-mail
Shri Sanjay Singh, AGM(ES), ICC	Indian Copper Complex, Ghatsila, Distt Singhbhum Jharkhand-832303	09430173137	singh_sk@hindustancopper.com

Prospective bidders intending to attend the meeting are requested to inform us by sending an e-mail. We look forward to your participation in this informative pre-application interaction.
