

三、社會主義與社會主義





RECTIFIER TRANSFORMER

MADE IN INDIA BY
EMCO TRANSFORMERS LTD.

BOMBAY

SPECIFICATION
TYPE OF COOLING **IS:2026/1977,IS:4540**
RATING PRIMARY KVA **2 1 1**
SECONDARY KVA **2 2**
INSULATION LEVEL **3 1 1**
HV: L160 AC20 LV: AC4

DIAGRAM DRG. NO. **2/11/0074/R-**
MAKER'S SERIAL NO. **ONAN**
YEAR OF MANUFACTURE **5272**
FREQUENCY **2 X 5728**
NO. OF PHASES PRIMARY **2 X 3**
SECONDARY **2 X 3**

POSN	SWITCH	NO LOAD VOLTS	CURRENT (AMPS)	KVA	IMPEDANCE
	CONN. 1 2	HV	LV	HV	LV
1	-	298.2	-	2 X 5728	5272
2	3-12 13-4	276.12	426.97	2 X 5452	4881
3	3-12 13-5	254.02	392.86	2 X 5175	4491
4	3-12 13-6	231.93	358.66	2 X 2899	4100
5	3-12 13-7	213.54	330.23	2 X 2669	3775
6	3-12 13-8	195.12	301.70	2 X 2439	3449
7	3-12 13-9	184.08	284.65	2 X 2301	3254
8	3-12 13-10	173.04	267.59	2 X 2163	3059
9	3-12 13-11	162.00	250.54	2 X 2025	2864
10	3-12 13-12	150.95	233.39	2 X 1887	2668
11	3-4 13-5	128.86	199.27	2 X 1611	2278
12	3-4 13-6	106.77	165.07	2 X 1334	1887
13	3-4 13-7	88.36	136.64	2 X 1105	1562
14	3-4 13-8	69.95	108.21	2 X 874	1237
15	3-4 13-9	58.91	91.06	2 X 736	1041
16	3-4 13-10	47.86	74.00	2 X 598	846
17	3-4 13-11	36.82	56.95	2 X 460	651
18	3-4 13-12	25.77	39.89	2 X 322	456

INTERPHASE TRANSFORMER
FREQUENCY HZ **150** VOLTS **2 X 126**
CORE AND WINDING MASS KG **14200**
GUARANTEED MAXIMUM TEMPERATURE RISE IN OIL **2 X 12.5 KA**
GUARANTEED MAXIMUM TEMPERATURE RISE IN WINDING **1 3**
TEMPERATURE OF WATER AT INLET
CUSTOMER'S REFERENCE **P.O NO.C-63122514 DTD.23/11/96**
CUSTOMER **M/S ABB A/C SWIL.**

305

2/11/0073/R

Revision Details		
Rev No	Sl No	EL's Comments
1	1	Description in the title block changed to "Rating Plate 25kA, 160V System" from "Rating plate"
1	2	Switch connection details for top positions 2-18 revised
1	3	ABB's Comments: Interphase transformer current changed to 2x12.5kA from 2x25kA
2	1	Type of cooling changed to ONAN from ONWF
2	2	Rating of primary KVA changed to 5237 from 5272
		Other clarification sought by EL on revision "Q" are given in ABB's letter No. M02MB5104-006 dt. 970527.
3	1	Rating of primary KVA changed to 5272 from 5232

NOTES :

- 1) ALL DIMENSIONS ARE IN mm EXCEPT OTHERWISE STATED.
- 2) THICKNESS OF THE RATING PLATE SHALL BE 20 SWG.
- 3) SIZE OF THE RATING PLATE SHALL BE 305 X 255 mm
- 4) MATERIAL OF THE DIAGRAM PLATE SHALL BE STAINLESS STEEL.
- 5) THE PLATE IS REQUIRED TO BE USED FOR OUTDOOR DUTY.

CUSTOMER : **ABB A/C SWIL.**
CONSULTANT : **E.L.L.**
CUSTOMER'S REF : **P.O NO. C-63122514 DTD. 23/11/96**

REV.3 : 16/12/97	REV.2 : 31/08/97	W.O. : U0085/A	RATING PLATE	EMCO TRANSFORMERS LTD.
AS BUILT	TYPE OF COOLING CHANGE TO ONAN FROM ONWF	DRIN : VLK	25 kA, 160V SYSTEM	MUMBAI
		PRD : VSP	SCALE - NTS	DRG. No. 2/11/0073 R3
		CHD : VSP		
		APPD : VSP		
		DATE : 31/08/97		
		MAN : -		