

Job Title:	Equinix FR12.1 Frankfurt	Purpose of Issue:	D2	Date:	03 February 2023
Job Number:	285668-00	Checked by:	DD	Revision:	P02
Made by:	BP				

Service Code	Fluid	Pipe Code	Material	Max Press bar (g)	Max Operating Temp C	Notes
Fuel - Internal	Heizöl (Diesel)	BI	Carbon Steel	16	45	1. All pipework not within banded areas to be twin skinned with leak detection and drain points at low points
Fuel - External	Heizöl (Diesel)	BI	Stainless steel - Stainless steel - Polyethylen	25	50	Flexwell double wall pipework - three layers with vacuum leak detection
ADB - Internal	Adblue	PE	Stainless steel	10	45	1. All pipework not within banded areas to be twin skinned with leak detection and drain points at low points
ADB - External	Adblue	PE	Stainless steel - Stainless steel - Polyethylen	25	50	Flexwell double wall pipework - three layers with vacuum leak detection

Additional Information

- 1 This equipment data sheet **must** be read in conjunction with all other parts of the Specification and drawings.
- 2 Contractor to verify pipework expansion and make allowances for them. Any expansion provision to be fully compliant with manufacturers requirement.