

Equipment Data Sheet Air Handling Unit FR121-ARP-DC-XX-SP-M-HVAC-8004

Job Title: Equinix FR12.1 Frankfurt

Purpose of Issue: D2

Checked by: DD

Date: 03 February 2023 Revision: P02

Legend

Unit Reference Phase 1 Unit Reference Future Phases

Made by: BP

Job Number: 285668-00

Ge	:11	er e	aı	U	aι	a

Specification	Type	Reference
---------------	------	-----------

Phase

Туре

Model

Area Served

	1-AHU-M3R1-1	1-AHU-M4R1-1	1-AHU-M5R2-1	1-AHU-M5R2-2
I	Phase 1	Phase 1	Future phases	Future phases
	Supply AHU + Condensing DX Outdoor Unit	Supply AHU + Condensing DX Outdoor Unit	Supply AHU + Condensing DX Outdoor Unit	Supply AHU + Condensing DX Outdoor Unit
	D-AHU Professional 1100x1000	D-AHU Professional 1100x1000	D-AHU Professional 1100x1000	D-AHU Professional 1100x1000
I	Data Halls	Data Halls	Data Halls	Data Halls

Ambient Temperature

Summer Winter

38.3°C	38.3°C	38.3°C	38.3°C
-17.4°C	-17.4°C	-17.4°C	-17.4°C

FAN								
Performance Data	Required	Offered	Required	Offered	Required	Offered	Required	Offered
Fan Type	Plug		Plug		Plug		Plug	
Fan Scroll Material								
Fan Scroll Joint Construction								
Air Leakage Class (DW 144)								
Impeller Material								
Impeller Finish								
Mounting Method								
Balance Grade ISO 1940								
Bearing Design Life L ₁₀ Hours	40000		40000		40000		40000	
Fan Test Arrangement (ISO 5801)								
Fan Diameter (Ø) mm								
Speed Control	VSD		VSD		VSD		VSD	
Drive Type	Belt-driven		Belt-driven		Belt-driven		Belt-driven	
Flow Rate Complete Design m³/h	5250		5250		5250		5250	
Airside Pressure Drop (External to AHU) Pa	350		350		350		350	
Fan Total Efficiency %								
Specific Fan Power W/(m³/s)	<1500		<1500		<1500		<1500	
Maximum SFP class to DIN EN 13779/EnEV	SFP 3		SFP 3		SFP 3		SFP 3	
Fan Speed rpm								
Electrical Supply V/Ø/Hz	400/3/50		400/3/50		400/3/50		400/3/50	
Drive Efficiency %								
Motor Efficiency %								
Absorbed Power kW	1.98		1.98		1.98		1.98	
Motor Rating kW	2.5		2.5		2.5		2.5	
Motor Type	EC		EC		EC		EC	
Motor Efficiency Class (CEMEP) EFF	IE5		IE5		IE5		IE5	
Motor Speed rpm								
Starting Method								
Starting Current A	3.1		3.1		3.1		3.1	
Full Load Running Current A	3.1		3.1		3.1		3.1	
Power Source	From A	HU board	From	AHU board	From AHI	J board	From AH	U board
Fan Diameter (Ø) mm								



Drain Connection Size / Type

DX COIL (for heating and cooling) Condensate Tray Material Withdrawal Space Required

mm

mm

RUP

Equipment Data Sheet Air Handling Unit

EQUINIX FR121-ARP-DC-XX-SP-M-HVAC-8004 Job Title: Equinix FR12.1 Frankfurt Date: 03 February 2023 Job Number: 285668-00 Purpose of Issue: D2 Revision: P02 Made by: BP Checked by: DD <u>Legend</u> Unit Reference Phase 1 Unit Reference Future Phases Anti-Vibration Mountings Fan Anti Vibration Mount (AVM) YES YES YES YES Fan AVM Static Deflection mm Unit Anti Vibration Mount (AVM) YES YES YES YES Unit AVM Static Deflection mm HEAT EXCHANGER - COUNTERFLOW Summer efficiency Supply air leaving condition summer °C db/wb No heat exchanger No heat exchanger Summer total capacity kW No heat exchanger required No heat exchanger required required required Winter efficiency Supply air leaving condition winter °C db/wb Winter total capacity HEATING Performance Data Frost coil Electric Frost Coil Type Electric Electric Electric Frost Coil Capacity 53 53 53 53 Coil Face Velocity m/s Frost Coil Temp Air Entering °C -17.4 -17 4 -17 4 -17.4 Frost Coil Temp Leaving °C 12.1 12.1 12.1 12.1 IP54 Protection Class IP54 IP54 IP54 Control Type Thyristor Thyristor Thyristor Thyristor Re-heat coil Electric Electric Re-Heat Coil Type Electric Electric 27 27 Coil Heating Capacity kW 27 27 m/s Coil Face Velocity 10.5 10.5 10.5 °C 10.5 Entering Air Temperature 25/40% 25/40% 25/40% 25/40% Leaving Air Temperature °C/%RH IP54 IP54 IP54 IP54 Protection Class Thyristor Control Type Thyristor Thyristor Thyristor DX COIL (for heating and cooling) Performance Data Cooling Type DX DX DX DX Total Coil Cooling Capacity kW 77 77 77 77 Coil Max Face Velocity m/s 4 No of refrigerant circuits 4 4 4 38.3/24.1 38.3/24.1 38.3/24.1 38.3/24.1 Entering Air Condition Cooling °C db/wb 9.7/9.7 9.7/9.7 9.7/9.7 9.7/9.7 °C db/wb Leaving Air Condition Cooling Moisture content air Cooling g/kg 10.5 10.5 10.5 Coil Heating Capacity (max) kW 10.5 °C db 10 10 10 10 Entering Air Condition Heating Leaving Air Condition Heating °C db 18 18 18 18 R410A R410A R410A Refrigerant Type R410A Coil Connection Size / Type mm



Equipment Data Sheet Air Handling Unit FR121-ARP-DC-XX-SP-M-HVAC-8004

EQUINIX

Job Title: Equinix FR12.1 Frankfurt

Job Number: 285668-00 Purpo Date: 03 February 2023 Revision: P02 Purpose of Issue: D2

Job Number: 285668-00	Purpo	se of issue:	DZ				Revision:	P	02
Made by: BP	C	Checked by:	DD						
<u>Legend</u>									
Unit Reference Phase 1									
Unit Reference Future Phases									
STEAM HUMIDIFIER									
Performance Data									
Max Steam Injection Rate/Unit	kg/hr	34		38		38		38	
Face Velocity	m/s								
Entering Air Condition	°Cdb/%RH	18 / 4%		18 / 4%		18 / 4%		18 / 4%	
Leaving Air Condition	°Cdb/°Cdp	18 / 45%		18 / 45%		18 / 45%		18 / 45%	
Moisture content leaving air	g/kg								
Туре		External hum provided with	softened water feed nidifier module to be n housing and trace weather protection	External hur provided wit	softened water feed midifier module to be th housing and trace weather protection	Suitable for so fee External huming to be provided and trace h weather p	ed difier module with housing leating for	fe External humion be provided wind trace heating	oftened water ed diffier module to th housing and g for weather ection
Electrical Data (Humidifier)									
Electrical Supply	V/Ø/HZ	400/3/50		400/3/50		400/3/50		400/3/50	
Power Rating	kW	26		26	·	26		26	
Maximum Current	Α	38		38		38		38	
IP Rating		54	_	54		54		54	
Power Source		From	AHU board	From	AHU board	From AH	U board	From Al	IU board

DΑ	м	Р	F	R	s
		•	_	٠.	•

Performance Data		Required	Offered	Required	Offered	Required	Offered	Required	Offered
Туре		Control/		Control/		Control/		Control/	
Туре		Shut-off		Shut-off		Shut-off		Shut-off	
Pressure Drop @ Open	Pa								
Max Differential Pressure (Closed)	Pa								
Air Leakage @ 500 Pa	(l/s)/m2				Low Leakage Crite	ria Required			
Blade Material									
Blade Profile									
Blade Length	mm								
Blade/Shaft Fixing									
Blade Seal Material									
Edge Seal Material									
Shaft Material									
Shaft Diameter	mm								
Shaft Seal Type									
Linkage Type									
Actuator Type		Motorized		Motorized		Motorized		Motorized	
Operating Torque @	Nm								

77

102

127

Side

Required



Equipment Data Sheet Air Handling Unit

FR121-ARP-DC-XX-SP-M-HVAC-8004

Job Title: Equinix FR12.1 Frankfurt

Job Number: 285668-00 Purpose of Issue: D2 Made by: BP Checked by: DD

Pa

Pa

Pa

77

102

127

Side

Required

Offered

Date: 03 February 2023

<u>Legend</u>

Unit Reference Phase 1 Unit Reference Future Phases Revision: P02

77

102

127

Side

Required

Offered

Panel Filter

Clean Filter Pressure Drop Dirty Filter Pressure Drop Design Filter Pressure Drop Dust Holding Capacity Filter Group & Class Filter Media

Filter Module Fixing Method

Seal Type

Access Arrangement

Bag Filter

Clean Filter Pressure Drop Dirty Filter Pressure Drop Design Filter Pressure Drop Dust Holding Capacity Filter Group & Class Filter Media Filter Module Fixing Method Seal Type

	G4	G4		G4		G4	
	Side	Side	;	Side		Side	
Pa	63	63		63		63	
Pa	113	113		113		113	
Pa	163	163		163		163	
g							
	F7	F7		F7		F7	
	·			_	·		

77

102

127

Side

Required

Offered

OVERALL BODY / BUILD

Access Arrangement

Construction Data Panel Type Panel Thickness Panel Construction Overall Weight

DIN EN 1886 Classes

Casing Strength Class Casing Thermal Transmittance Class Casing Thermal Bridging Class Negative Test Pressure Negative Test Pressure Air Leakage Class Negative Test Pressure Air Leakage Positive Test Pressure Positive Test Pressure Air Leakage Class Positive Test Pressure Air Leakage

Filter Bypass Air Leakage at 400Pa

	Insulated	d, Mineral Wool	Insulate	d, Mineral Wool	Insulated, M	ineral Wool	Insulated, N	Ineral Wool
mm	42		42		42		42	
	Do	ouble Skin	Do	ouble Skin	Double	Skin	Doub	le Skin
kg	1557		1557		1557		1557	
	D1		D1		D1		D1	
	T2		T2		T2		T2	
	TB2		TB2		TB2		TB2	
Pa	400		400		400		400	
	Α		Α		Α		А	
l/s/m ²								
Pa	700		700		700		700	
	Α		Α		Α		А	
l/s/m ²								
					t			

Offered

Standard



ARUP

Equipment Data Sheet Air Handling Unit FR121-ARP-DC-XX-SP-M-HVAC-8004

Non-flam.

30

0.035

Standard

YES

YES

YES

YES YES

YES

YES

Offered

Job Title: Equinix FR12.1 Frankfurt

Purpose of Issue: D2

Checked by: DD

Date: 03 February 2023 P02 Revision:

Non-flam.

30

0.035

Standard

YES

YES

YES

YES

YES

YES

YES

Legend

Jnit Reference Phase 1

DIN EN 13053 Classes

Offic Reference	riiase i
Unit Reference	Future Phases

Job Number: 285668-00

Made by: BP

ir Velocity Class	
anel Insulation Material	
anel Insulation Thickness	mm
nsulation Density	Kg/m ³
nsulation Thermal Conductivity	W/mK
nner Skin Material	

Inner Skin Thickness Inner Skin Finish Outer Skin Material Outer Skin Thickness Outer Skin Finish

Section AHU Elements

Inlet Louvre Inlet Damper Access Section Panel Filter Bag Filter Access Section Frost Coil (Electric) Access Section Inlet Attenuator Access Section

	Non-flam.	Non-flam.
nm	30	30
m³		
nΚ	0.035	0.035
nm		
nm		

	Require
	Standar
mm	
mm	

Required	Offered	Required	Offered	Required	Offered	Require
YES		YES		YES		YES
YES		YES		YES		YES
YES		YES		YES		YES
YES		YES		YES		YES
YES		YES		YES		YES
YES		YES		YES		YES
YES		YES		YES		YES
YES		YES		YES		YES
YES		YES		YES		YES
YES		YES		YES		YES
YES		YES		YES		YES
YES		YES		YES		YES
YES		YES		YES		YES
YES		YES		YES		YES
YES		YES		YES		YES
YES		YES		YES		YES

Access Section	
Re-Heat Coil	(Electric)
Access Section	
Fan Section	
Control Panel	
Discharge Attenua	ator
Access Section	
Steam Humidifier	
Drop Separator	
Air tight shut off D	amper
External Heat Pun	np Unit

DX Coil Heating and Cooling

Drop Separator

External Heat Pump Unit	YES		YES	
Component Data - Access Sections t	o be prov	vided as requi	red to me	et VDI 6022

YES

YES

YES

YES

YES

YES

Overall Dimensions

Max Overall Length	mm	9940	11000	11000	11000	
Max Overall Width	mm	1000	1150	1150	1150	
Overall Height	mm	1100	1400	1400	1400	
Side Access Clearance	mm					
Overall Unit Pressure Drop	Pa					

YES

YES

YES

YES

YES

YFS



Equipment Data Sheet Air Handling Unit FR121-ARP-DC-XX-SP-M-HVAC-8004

Job Title: Equinix FR12.1 Frankfurt

Job Number: 285668-00 Purpose of Issue: D2 Made by: BP Checked by: DD

Date: 03 February 2023 Revision: P02

<u>Legend</u>

Unit Reference Phase 1 Unit Reference Future Phases

Acoustic Data		Required	Offered	Required	Offered	Required	Offered	Required	Offered
Casing Radiated	63 Hz	61		61		61		61	
	125 Hz	68		68		68		68	
	250 Hz	65		65		65		65	
Sound Power Level @	500 Hz	61		61		61		61	
Lw dB	1 kHz	59		59		59		59	
	2 kHz	53		53		53		53	
	4 kHz	38		38		38		38	
	8 kHz	30		30		30		30	
Inlet Air	63 Hz	63		63		63		63	
inlet Air	125 Hz	64		64		64		64	
In Duct	250 Hz	60		60		60		60	
Sound Power Level @	500 Hz	56		56		56		56	
Lw dB	1 kHz	50		50		50		50	
LW UB	2 kHz	47		47		47		47	
	4 kHz	47		47		47		47	
	8 kHz	48		48		48		48	
Discharge Air	O KI IZ	10		10		10		10	
_	63 Hz	70		70		70		70	
	125 Hz	75		75		75		75	
In Duct	250 Hz	75		75		75		75	
Sound Power Level @	500 Hz	70		70		70		70	
Lw dB	1 kHz	65		65		65		65	
	2 kHz	63		63		63		63	
	4 kHz	62		62		62		62	
	8 kHz	61		61		61		61	
Max. Noise Level (Lw) (Night)	dB(A)								



Equipment Data Sheet Air Handling Unit FR121-ARP-DC-XX-SP-M-HVAC-8004

Job Title: Equinix FR12.1 Frankfurt

Job Number: 285668-00 Purpose of Issue: D2 Made by: BP Checked by: DD

Date: 03 February 2023 Revision: P02

Unit Reference Phase 1 Unit Reference Future Phases									
CORRESPONDING OUTDOOR UNIT									
Unit Reference		1DX_ 1DX_	M3R1_1 M3R1_2 M3R1_3 M3R1_4	1DX 1DX	_M4R1_1 _M4R1_2 _M4R1_3 _M4R1_4	1DX_M 1DX_M 1DX_M 1DX_M	5R2_6 5R2_7	1DX_N 1DX_N 1DX_N 1DX_N	15R2_2 15R2_3
Phase		Ph	ase 1	Р	hase 1	Future p	hases	Future	phases
Model (based on Daikin)		ERQ2	200AW1	ERC	Q200AW1	ERQ20	0AW1	ERQ20	00AW1
Туре		Hea	t Pump	He	at Pump	Heat F	ump	Heat	Pump
Location		Le	evel 4	L	evel 4	Leve	el 4	Lev	el 4
Performance Data									
Total Heat Rejection Capacity all units	kW	77		77		77		77	
Total Heat Rejection Capacity per unit	kW	19.3		19.3		19.3		19.3	
Design Ambient Temperature Summer	°C	38.3		38.3		38.3		38.3	
Min Operating Temperature	°C	-17.4		-17.4		-17.4		-17.4	
Max. Operating Temperature	°C	40		40		40		40	
No of Outdoor Units	final	4		4		4		4	
No of Condenser Fans / Unit	ĺ	1		1		1		1	
Condenser Fan Type		Axial		Axial		Axial		Axial	
Condenser Fan Speed	rpm								
Condenser Fan Size (Ø)	mm								
Refrigerant Type		R410A		R410A		R410A		R410A	
Total Refrigerant Charge per unit	kg	7.7		7.7		7.7		7.7	
Coefficient of Performance @	_								
Compressor Type		Scroll		Scroll		Scroll		Scroll	
Suction Pipe Equivalent Length	m								
Liquid Pipe Equivalent Length	m								
Suction Pipe Maximum Height	m								
Liquid Pipe Maximum Height	m								
Capacity Steps	%								
Noise Level (Lw) (Day / Night)	dB(A)	STA		STA		STA		STA	
Construction Data Casing Material	ĺ	1		 		T			
Casing Finish/Colour	mm								
Coil Tube/Fin Material Material									
Refrigerant Liquid Line Size									
Refrigerant Suction Line Size									
Unit Operating Weight	kg	187	-	187		187		187	
CONDENSING UNIT Electrical Data		Required	Offered	Required	Offered	Required	Offered	Required	Offered
Unit Max Absorbed Power	kW	18.5		18.5		18.5		18.5	
Unit Max Running Current	Α	25		25		25		25	
Unit Max Starting Current	Α								
Compressor Motor Rating	kW								
Fan Motor Rating	kW								
Power Source									
Electrical Supply	V/Ø/Hz	400/ 3/ 50		400/ 3/ 50		400/ 3/ 50		400/ 3/ 50	



EQUINIX				FR121-ARP-DC	equipment Da Air Hand XX-SP-M-HV	ling Unit
Job Title: Equinix FR12.1 Fran	kfurt					ary 2023
Job Number: 285668-00	Purpose of Issue:	02		Re	evision:	02
Made by: BP	Checked by:	DD				
Legend						
Unit Reference Phase 1						
Unit Reference Future Phases						
Dimonologal Data						
Dimensional Data	mm 765		765	765	765	
Overall Width			930	930	930	
Overall Width			1680	1680	1680	
Overall Height			1000	1000	1000	
Front Clearance End Clearance	mm mm					
End Clearance						
Accessories	Required	Offered			Required	Offered
Weatherproof Construction	✓		Access Door	Security Locks	✓	
Pitched Water Shedding Roof	7		Inlet Hood			
Glazed Viewing Ports in Access Doors	✓		Discharge H	ood		
Bulkhead Luminaires in Access Sections	✓		Special Finis	sh .		
Magnahelic Pressure Gauges on Filters	✓		Spare Set of	Filters	✓	
Manometers on Filters	7		Flow Measur	ring Station	✓	
High Efficiency Motors	✓		Cooling Coil	Eliminator Plates	✓	
Motors Wired to External Isolators	7		Frost protect	tion	✓	
Fan Motor Located Out of Airstream			Control Pane	el incl. Full control system	✓	
BMS Interface	✓		Thyristor cor	ntrol for electric heaters	✓	
Electrical Supply Panel			Protection S	creens for external units	✓	
Automatic restart after power outage	▼		Safety temper	erature limiter (110°C)	✓	
Drip trays for all necessary components	7		Big Foot Mo	unting System for outdoor ur	nits 🗸	
High Efficiency Motors	✓		(or equal and	d approved)		
Testing	Required	Offered	Samples		Required	Offered
Factory Acceptance Test (FAT)			Type Sample	29	- Koquilou	
Site Acceptance Test (SAT)	 		rype dampie	23		
one neceptance rest (O/(1)	ت ا	Ш				
Works Performance Tests	Required	Offered				
Noise Performance Tests						
Pressure & Leakage Performance Tests						
Manufacturer	Pre	eferred	Alternative			
Manufacturer	D	aikin	AL-KO			
Contact Name	Aleksai	ndar Knodt	Markus Wollenw	veber		
Telephone Number		21 7711 115	+49 (0)6182 99			
Fax Number	. 10(0) 00		5 (5)5152 55			
		<u> </u>	wollenweber@wolle	nweber-		
E-mail Address	<u>danojlic.a</u>	a@daikin.de	gmbh.com			
Internet Address	dai	kin.de	http://www.al-ko.d	com/en		
	•		•	•		



Equipment Data Sheet Air Handling Unit FR121-ARP-DC-XX-SP-M-HVAC-8004

Job Title: Equinix FR12.1 Frankfurt

Job Number: 285668-00 Purpose of Issue: D2
Made by: BP Checked by: DD

Date: 03 February 2023
Revision: P02

Legend

Unit Reference Phase 1
Unit Reference Future Phases

Additional Information

- This equipment data sheet must be read in conjunction
 with all other parts of the Specification, including:
 - the Scheme report.
 - the Materials and Workmanship Specification,
 - the Scheme drawings.
- 2 All alarm volt free contacts shall be fail safe 3A inductive at 230V AC. Required BMS contacts/alarms outlined in BMS specification.
- Type test data shall be provided to demonstrate that the equipment performs to the required standards.
- 4 Fan Test Arrangement ISO 5801
 - Type B Free Inlet & Ducted Outlet
 - Type C Ducted Inlet & Free Outlet
 - Type D Ducted Inlet & Ducted Outlet (AHU02)
- 5 Air leakage and mechanical performance to DIN EN 1886
- Rating and performance to DIN EN 13053, EU1253/2014
- 7 Flow measuring station, comprising air flow sensing device and sensor with (0-10VDC/4-20mA) output,
- to be calibrated at AHU manufacturer's works and on site.
- Power supply (24Vac) to be provided by BMS/Controls Specialist.
- Rating standards to be in line with DIN EN 13053 and DIN EN 779
- 9 Allow for a pulley change on each belt driven fan.
- 10 Provide thermistors in motor windings wired out to terminals for connection to variable speed drives
- 11 Isolators and electrically shielded power cables
 between isolators, motors and variable speed drive
 shall be selected in accordance with the variable speed
 drive manufacturer's recommendations to ensure that the
 complete power installation satisfies all electromagnetic
 noise requirements.

- 12 The AHU manufacturer to fit variable frequency drive and BMS controls enclosure to the AHUs.
- 13 All lighting circuits wired to single terminal box for connection of power supply from local distribution board.
- 14 See the drawings for arrangement to access unit and hence determine the side for access panels and services connections.
- 15 Units to be constructed and certified to VDI 6022.
- 16 All control points are to be confirmed by the controls / BMS contractor
- 17 AHU to shut down on humidifier failure or fault
- 18 Flow measuring station, comprising air flow sensing device and sensor with (0-10VDC/4-20mA) output, to be calibrated at AHU manufacturer's works.
- 19 Condensate connections to be supplied with Siphon with trace heating
- 20 VSD specifications to comply with electrical requirements,
- 21 All units and components to be suitable for external
- location.
- 22 Connection of cables and pipework to unit to be installed and completed by equipment manufacturer
- 23 Testing and Commissioning is to be carried out and whitnessed with General Contractor, AHU and Heat Pump
 - Supplier and BMS Contractor present
- 24 AHU to be fitted out with smoke detectors at fresh air inlet,
- supply air outlet and extract air inlet.





FR12.1 – Equinix Data Centre Air Handling Units

Document Reference: FR121-ARP-DC-XX-SP-M-HVAC-8004

Revision: P02

Date: 2023-02-03

Purpose of Issue: D2 – Tender Pack

Job number: 285668-00

Arup Deutschland GmbH Mayfarthstraße 15 60314 Frankfurt www.arup.com

P02	03.02.2023	Tender Pack	BP / DD / DW
P01	16.12.2022	RIBA 4 design	KW / DD / DW
REV	DATE	Description	DWN / CHK / APP