

SOP-2210 Centrifugal Pump Vibration Monitoring

1. Purpose

Defines routine vibration monitoring of centrifugal pumps in the Crude Distillation Unit, including P-101A and P-101B.

2. Acceptance Criteria

Overall vibration velocity shall be assessed against ISO 10816-3 Zone boundaries. The alert threshold is 4.5 mm/s RMS. The shutdown threshold is 7.1 mm/s RMS. Readings are taken at the drive end and non-drive end in horizontal, vertical and axial directions.

3. Frequency

Monthly for pumps in continuous service. Weekly once a reading exceeds the alert threshold, until the cause is corrected.