ISO 50001 EnMS
Internal audit report No 3

EnMS System	ISO 50001:2011
Revision Number	1.0
Issue Date	Jan 30, 2016

1 Audit checklist

ISO clause no.	Description	Covered in this audit
4.1	EnMS: General requirements	N/A
4.2 Management responsibility		
4.2.1	Management responsibility: Top management	
4.2.2	Management responsibility: Management representative	
4.3	Energy policy	
4.4 Energy planning		
4.4.1	Energy planning: General requirements	N/A
4.4.2	Energy planning: Legal requirements and other requirements	
4.4.3	Energy planning: Energy review	✓
4.4.4	Energy planning: Energy baseline	✓
4.4.5	Energy planning: Energy performance indicators	✓
4.4.6	Energy planning: Energy objectives, energy targets and energy management action plans	✓
4.5 Implementation and operation		
4.5.1	Implementation and operation: General requirements	
4.5.2	Implementation and operation: Competence, training and awareness	
4.5.3	Implementation and operation: Communication	
4.5.4	Implementation and operation: Documentation	
4.5.5	Implementation and operation: Operational control	
4.5.6	Implementation and operation: Design	
4.5.7	Implementation and operation: Procurement of energy services, products, equipment and energy	
4.6 Checking		
4.6.1	Checking: Monitoring, measurement and analysis	
4.6.2	Checking: Evaluation of compliance with legal requirements and other requirements	
4.6.3	Checking: Internal audit of the EnMS	
4.6.4	Checking: Nonconformities, correction, corrective action and preventive action	
4.6.5	Checking: Control of records	
4.7	Management review	

2 Audit finding

RECORD OF INTERNAL AUDIT NONCONFORMITY/CONCERN/POSITIVE FINDING		
Organization: MGM MACAU	Auditor: Han Lee	Standard: 4.4.3
Date: 26 January 2017	Location of Finding: eSight and PMS	
Type of Finding (check one): ☐ Nonconformity ☐ Concern ☒ Positive Finding		
Facts Concerning the Finding* Statement of Criteria (Requirement): 4.4.3- Energy Review Objective Evidence (Statement of Finding): Energy review was conducted and it was observed that, EnPI A and EnPI B have decreased by 18.8% and 15.5% when compared to the baseline (2013) while Energy Consumption has reduced by 2.9% percent when compared to the previous year (2015). ** Statement of Criteria (Requirement) is not required for positive findings, but should be provided if appropriate.*		
Documentation Reference: EnMS procedural manual v3 appendix and Monthly Energy Consumption 2016 updated spreadsheet.		
ISO Requirement Reference: As per 4.4.3		
Auditee Signature:	Auditor Signature	
Auditee signature indicates that facts concerning the nonconformity are correct.		

RECORD OF INTERNAL AUDIT NONCONFORMITY/CONCERN/POSITIVE FINDING

Organization: MGM MACAU	Auditor: Han Lee	Standard: 4.4.4
Date: 26 January 2017	Location of Finding: EnMS Procedural Manual v3	

Type of Finding (check one): ☐ Nonconformity ☐ Concern ☒ Positive Finding

Facts Concerning the Finding*

Statement of Criteria (Requirement):
4.4.4- Energy Baseline

Objective Evidence (Statement of Finding):
The energy baseline was reviewed (2013). As EnPI reflect organizational energy use and there have been no major changes to process, operational patterns or energy systems; the baseline was not changed.

** Statement of Criteria (Requirement) is not required for positive findings, but should be provided if appropriate.*

Documentation Reference:
EnMS procedural manual v3.

ISO Requirement Reference:
As per 4.4.4

Auditee Signature:	Auditor Signature

Auditee signature indicates that facts concerning the nonconformity are correct.

RECORD OF INTERNAL AUDIT NONCONFORMITY/CONCERN/POSITIVE FINDING

Organization: MGM MACAU	Auditor: Han Lee	Standard: 4.4.5
Date: 26 January 2017	Location of Finding: EnMS Procedural Manual V3	

Type of Finding (check one): ☐ Nonconformity ☐ Concern ☒ Positive Finding

Facts Concerning the Finding*

Statement of Criteria (Requirement):
4.4.5- Energy Performance Indicators

Objective Evidence (Statement of Finding):
Cooling degree days and total floor area were two parameters which affected Energy Consumption of the facility the most.

Thus, two Energy Performance Indicators were defined:

EnPI A: Total Energy Consumed (GJ) / CDD

EnPI B: Total Energy Consumed (GJ) / total floor area (m2)

** Statement of Criteria (Requirement) is not required for positive findings, but should be provided if appropriate.*

Documentation Reference:
EnMS procedural manual v3.

ISO Requirement Reference:
As per 4.4.5

Auditee Signature:	Auditor Signature

Auditee signature indicates that facts concerning the nonconformity are correct.

RECORD OF INTERNAL AUDIT NONCONFORMITY/CONCERN/POSITIVE FINDING

Organization: MGM MACAU	Auditor: Han Lee	Standard: 4.4.6
Date: 26 January 2017	Location of Finding: eSight	

Type of Finding (check one): ☐ Nonconformity ☒ Concern ☐ Positive Finding

Facts Concerning the Finding*

Statement of Criteria (Requirement):
4.4.6- Energy planning: Energy objectives, energy targets and energy management action plans.

Objective Evidence (Statement of Finding):

EnPI A of 2016 when compared with 2015 increases by 1.06% while EnPI B of 2016 when compared with 2015 decreases by 2.6%. Energy milestone defined in the EnMAP and EMO registers is not met.

This was because LPG consumption in 2016 increased by 3.4% when compared to 2015 while the Electricity consumption and CDD decreased by 4.2% and 3.8% respectively.

The increase in LPG consumption was because of Boiler Plant operational issues. This was discussed during the Jan 2017 EMT meeting and the issue was fixed.

** Statement of Criteria (Requirement) is not required for positive findings, but should be provided if appropriate.*

Documentation Reference:
EnMS procedural manual v3 appendix and Monthly Energy Consumption 2016 updated spreadsheet.

ISO Requirement Reference:
As per 4.4.6

Auditee Signature:	Auditor Signature

Auditee signature indicates that facts concerning the nonconformity are correct.