

Grid Code Requirements

Grid Code Requirements Summary: - Reactive power support must be maintained within Q-V curve limits. - Frequency-Watt and Volt-Watt responses mandatory for grid stability. - Curtailment may be operator-mandated during congestion or contingency events.