EVENT ANALYSIS REPORT								
UNIT NO: 01	TPS: Khaperkl	S Unit Capaci			city: 2	ity: 210 MW		
1. *HO Code			Time -				No. of days from last sync. :	
:	T003		08:40 Hrs	2	3/03/2017		1 day	
2. Operating conditions at the time of Event :-								
Loa	Coal Cycles in service				Oil Support			
125 MW			B, C, D & E				Nil	
3. Nature of Event: T.A. Set tripped due to "Flame Failure" protection.								
4. Name of First Up, Main Protections & Protection on which GCB tripped: Flame Failure (First Up), Turbine Tripped, Gen. Protection Operated, Generator Reverse Power Protection.								
<b>5A) Observations</b> : Three coal cycles (B, D & E) were in service with oil support in AB elevation. Coal mill-F was under permit and coal feeder A & C were out for shear pin failure. After establishing four coal cycle operations (Coal cycle-C added) oil support was withdrawn. While withdrawing oil support, furnace flame was disturbed. Variation in furnace draft was observed and Boiler tripped on flame failure, which resulted in tripping of unit.								
5 B) Remedial Action/work done: No work done.								
<b>6. Root Cause Analysis :</b> While withdrawing oil support, furnace flame disturbed. Due to this, draft variation observed and boiler tripped on flame failure.								
7. Preventive action suggested (Short Term):								
8. Preventive action suggested (Long Term):								
9. Similar event occurred last time:- Unit I			No # 1, 210 MW Time: 18:03		hrs	Date: 04/11/2016		
Event: - T.A. Set tripped on "Flame Failure".  Remedial Actions: No work done.								
9A. Implementation Status of Long Term/Short Term measures stated at Sr No 7 & 8:-								
10. Boiler lighted up			<b>Time -</b> 08:55 Hrs			Dat	<b>Date-</b> 23/03/2017	
11. T-A Set Synchronized			<b>Time</b> - 11:55 Hrs			Dat	<b>Date-</b> 23/03/2017	
12. Remark:								
Chief Engineer								
13. Recommendations of Works Section:								
1. Procurement/Replacement Plan:								
2. Operational Error:								
3. Delay in Maintenance:								
4. Delay in bringin								
5. Training of Staff								
6. Whether remedial action is completed satisfactory & point is closed:								
	6					CE	/Dy C E (Works)	