	I	EVENT ANALYSIS REI	PORT			
UNIT NO: 02	TPS: Khaperkheda TPS Unit Capacity: 210 MW					
1. *HO Code :	Station Code: T003	Time - 17:20 Hrs 2	Date - 1/10/2016	No. o	f days from last sync. : 5 days	
2. Operating conditions at the time of Event :-						
			Coal Cycles in service		Oil Support	
3. Nature of Event: Set tripped due to F.D fan p		A, C, D & F			AB x 2	
4. Name of First Up, Main Protections & Protection on which GCB tripped: Both FD fans off [First Up], Turbine Tripped, Generator Reverse Power Relay Operated,						
5A) Observations: Set was sharing 145 MW load with four coal cycles (B and E standby) in service. "FD Fan A Off", "FD Fan B Off" indications appeared and both the fans were found tripped. Boiler tripped on "Both FD Fans Off" protection and GCB opened on reverse power protection.						
5B) Remedial Action/Work done: No work carried out.						
Sb) Remedial Action, Work dolle. No work carried out.						
6. Root Cause Analysis: At 17:20 hrs. both FD Fans got off and ID Fan-B got off on interlock. No cause of FD Fans getting off could be traced out. All interlock circuits & breakers checked. No abnormalities observed. As such the tripping of unit appears to be spurious one.						
7. Preventive action suggested (Short Term): As per the event log generated, both FD fans off found as normal off command. Hence, no corrective action could be suggested.						
8. Preventive action suggested (Long Term):-						
9. Similar event occurred last time:-		Unit No # 2 , 210 MW	Time: Hrs		Date:	
Event: No similar event found. Remedial Actions:-						
9A. Implementation Status of Long Term/Short Term measures stated at Sr. No 7 & 8:-						
10. Boiler light	lighted up Time - 18:55 Hrs		'S	Date - 21/10/2016		
11. T-A Set Synchronized		Time - 21:20 H	21:20 Hrs Date -		21/10/2016	
12. Remark :- Remark :- Chief Engineer						
13. Recommendations of Works Section:						
1. Procurement/Replacement Plan:						
2. Operational Error:						
3. Delay in Maintenance:						
4. Delay in bringing back the Unit:						
5. Training of Staff:						
6. Whether remedial action is completed satisfactory & point is closed:						
C E/Dy C E (Works)						