EVENT ANALYSIS REPORT						
UNIT NO: 04 TPS: Khaperk		heda TPS Unit (t Cap	apacity : 210 MW	
1. *HO Code :	Station Code:	Time -	Date -	1	No. of days from last sync. : 6 days	
	T003	15:59 Hrs	02/02/2016			
2. Operating conditions at the time of Event :-						
Load		Coal Cycles in service			Oil Support	
160 MW		A, I	A, B, C, D & E		NIL	
3. Nature of Event: TA set tripped due to furnace pressure very low.						
4. Name of First Up, Main Protections & Protection on which GCB tripped:						
Furnace Pressure Very Low. (First Up), Turbine Tripped, MFT Operated.						
5 A) Observations: - Set was on load at 160 MW with A, B, C, D and E coal mills in service. Consequent upon						
sudden falling of a large clinker disturbance occurred in furnace draft which led to boiler tripping on						
'Furnace Pressure Very Low' protection. This resulted in set tripping on boiler interlock at 15:59 Hrs on						
date 02/02/16.						
5 B) Remedial Action/work done: - No specific work carried out.						
6. Root Cause Analysis: - Due to falling of clinker, furnace draft disturbed and set tripped due to furnace						
pressure very low. It is suspected that clinker formation might be due to very poor quality of coal.						
7. Preventive action suggested (Short Term):-						
8. Preventive action suggested (Long Term) :-						
9. Similar event occurred last time		ne:- Unit N	- Unit No # 4,210 MW		Time : .7:40 Hrs	Date: 08/12/2015
Event: Boiler tripped on "Furnace Pressure Very Low" which resulted in set tripping on boiler interlock.						
Remedial Actions: - No work done.						
9A. Implementation Status of Long Term/Short Term measures stated at Sr No 7 & 8:-						
10. Boiler lighted up		Time -	Time - 16:46 Hrs		Date- 02/02/2016	
11. T-A Set Synchronized		Time -	Time - 21:27 Hrs		Date- 02/02/2016	
12. Remark:-						
Chief Engineer						tallas ngineer
13. Recommendations of Works Section:						
1. Procurement/Replacement Plan:						
2. Operational Error:						
3. Delay in Maintenance:						
4. Delay in bringing back the Unit:						
5. Training of Staff:						
6 Whether remedial action is completed satisfactory & point is closed.						

C E/Dy C E (Works)