# State Estimation for Distribution Grids

# Table of Contents

Table of figures	2
Introduction	3
General outline	3
Retrieving a grid and associated profile	4
Creating measurements	4
Internal data structures	5
Estimation	6
Kalman Filter Formulation	6
Discussion	8
Implementation	12
Appendix	13

# Table of figures

Figure 1: Difference in no. of buses	5
Figure 2: pd2ppc lookup table	6
Figure 3: Relative error with Jacobian inverse	8
Figure 4: Estimation with Jacobian inverse	8
Figure 5: Estimation without Jacobian inverse	9
Figure 6: Error distribution for 50 runs	9
Figure 7: Error distribution for 10 runs	10
Figure 8: voltage angle estimation	10
Figure 9: voltage magnitude estimation	10
Figure 10: Trace of Pk for normal steps	11
Figure 11: Trace of Pk for error step	11
Figure 12: Kalman Filter fig. 1	13
Figure 13: Kalman Filter fig. 2	14
Figure 14: Kalman Filter fig. 3	14
Figure 15: Kalman Filter fig. 4	
Figure 16: Kalman Filter fig. 5	14
Figure 17: Kalman Filter fig. 6	14
Figure 18: Kalman Filter fig. 7	14

# Introduction

This document is a reference for the state estimation of distribution grids implemented in python using various libraries and benchmark grids. The following libraries are used in the program:

#### 1. Pandapower

It is an easy to use network calculation program aimed at automation of analysis and optimization in power systems.

You can install this from http://www.pandapower.org/start/

#### 2. filterpy

This library provides Kalman filtering and various related optimal and non-optimal filtering software written in Python.

You can install this from <a href="https://github.com/rlabbe/filterpy">https://github.com/rlabbe/filterpy</a>

#### 3. simbench

This library contains several benchmark grid data and can be used within pandapower.

You can install this from https://simbench.readthedocs.io/en/latest/about/installation.html

#### 4. numpy

installation <a href="https://numpy.org/">https://numpy.org/</a>

#### 5. pandas

installation <a href="https://pandas.pydata.org/">https://pandas.pydata.org/</a>

#### 6. matplotlib

installation <a href="https://matplotlib.org/users/installing.html">https://matplotlib.org/users/installing.html</a>

According to the requirement, various files inside these libraries are already edited (details are provided in the respective codes). Therefore, the following files should be placed in the working directory to override the respective files in the packages:

- 1. Matrix\_calc.py
- 2. Matrix base.py
- 3. ppc conversion.py
- 4. EKF\_iter.py

# General outline

There are some fundamental differences between simbench and pandapower. The main difference is in the sign of power. Therefore, it is necessary to convert simbench convention to pandapower convention:

#### Simbench:

Static generation (sgen): generation is positive power

# Pandapower:

Static generation (sgen): generation is negative power

Bus power flow results: generation is negative power and consumption is positive power

Measurements: generation is positive power and consumption is negative power.

# General outline of the program:

- 1. Retrieve a grid and associated profile (timeseries data for loads and generation) from simbench
- 2. Create the necessary measurements for the grid for each timestep in the profile
- 3. Run the estimation (eg. Weighted Least Squares or Extended Kalman Filter)
- 4. Plot the error distribution for WLS and EKF compared to the true state

# Retrieving a grid and associated profile

A pandapower network includes various parameter tables like:

- bus
- load
- sgen
- switch
- ext grid
- line
- trafo
- bus geodata
- loadcases
- measurements

Some of these tables are pandas dataframe while others are numpy arrays. The number of elements in each table will be according to the grid structure.

# Creating measurements

There might be some measurements already available for the network. So, it is advisable to delete these before creating our own measurements. For the new measurements, a powerflow is first run to determine the real state of the grid. After the powerflow, the results will be available in the result tables of the network. For eg.,

'net.res\_bus' has the bus results like voltage magnitude and angles, P and Q injections, etc. 'net.res\_line' has the line results like P and Q flows.

Required measurements are then created by adding a random noise (sampled from a normal distribution with given standard deviation) over the true values. Measurements are in the order

- P\_(non slack buses)
- P\_(slack bus)
- P (lines)
- Q\_(non slack buses)
- Q\_(slack bus)
- Q\_(lines)
- V\_(non slack bus)
- V\_(slack bus)

# Internal data structures

For the internal calculations within pandapower, there are various other data structures apart from the pandapower network. They are

'ppc' - An internal PyPower datastructure

'eppci' – An internal extended PyPower datastructure

Calculations such as finding the admittance matrix, powerflow, etc are done with 'eppci' internally. Below are the main differences between these datastructures:

Suppose for a sample grid ("1-MV-comm--0-sw" – a medium voltage commercial grid):

The number of buses in the pandapower network (called as 'net' from now on) is 144.

The number of buses in the 'ppc' is 155.

The number of buses in 'eppci' is 150.

```
ppc = {dict} < class 'dict'>: {'baseMVA': 1, 'version': 2,
      'baseMVA' (2292501091888) = {int} 1
      u 'version' (2292362793200) = (int) 2
   'bus' (2292436079920) = {ndarray} [[0.000e+00 3.00]
         min = {float64} 0.0
         max = {float64} 154.0
      shape = {tuple} < class 'tuple'> (155, 15)
      dtype = {dtype} float64
         size = (int) 2325
      array = {NdArrayltemsContainer} < pydevd_plu</p>
Eppci = {ExtendedPPCl} {'baseMVA': 1, 'version': 2, 'bus
  E = {ndarray} [ 0. 0. 0. 0. 0. -0. -0. -0. 0. 0. 0. 0. 0.
  ► E_init = {ndarray} [ 0. 0. 0. 0. 0. -0. -0. -0. 0. 0. 0. 0.
  ► V = {ndarray} [1.025+0.j 1. +0.j 1. +0.j 1. +0.j 1.
  _MutableMapping_marker = {object} < object object</p>
  _abc_impl = {_abc_data} <_abc_data object at 0x000</p>
     baseMVA = (int) 1
  branch = {ndarray} [[ 1.00000000e+00+0.j 6.0000000
  ▼ = bus = {ndarray} [[ 0.00000000e+00 3.00000000e+00
         min = {float64} nan
         max = {float64} nan
     shape = {tuple} < class 'tuple'> (150, 25)

► ≡ dtype = {dtype} float64

         o size = {int} 3750
```

```
This pandapower network includes the following parameter tables:

- bus (144 elements)

- load (139 elements)

- sgen (134 elements)

- switch (305 elements)

- ext_grid (1 element)

- line (147 elements)

- trafo (2 elements)

- measurement (584 elements)

- bus_geodata (144 elements)

- substation (2 elements)

- loadcases (6 elements)

and the following results tables:

- res_line (147 elements)

- res_trafo (2 elements)

- res_ext_grid (1 element)

- res_load (139 elements)

- res_sgen (134 elements)

- res_bus_power_flow (144 elements)

- res_ext_grid_power_flow (1 element)

- res_line_power_flow (147 elements)

- res_load_power_flow (139 elements)

- res_sgen_power_flow (134 elements)

- res_sgen_power_flow (2 elements)
```

Figure 1: Difference in no. of buses

In this grid, there are 139 bus in service, 5 bus not in service and 11 dummy bus for open switches.

**net:** 139 + 5 (Not seperated)

**ppc:** 139 + 11 + 5 (Seperated, first 'in service bus' followed by 'dummy bus' and last 'out of service bus' in the table)

eppci: 139 + 11 (Seperated, first 'in service bus' followed by 'dummy bus' in the table)

In the code, these are nBusAct = 139, nBuspp = 144 and nBus = 150.

Most of the calculations are done with 'eppci' and later the required results are extracted. The admittance matrix in this case will be a 150x150 matrix according to the bus number in 'eppci'.

In order to extract the required results (in this case states for 139 in service buses) from net, we need to create a mask. This is done from the data in net['\_pd2ppc\_lookups']. The repeated numbers indicate the 'out of service bus'. These results are masked out so that they do not appear in the result.

Figure 2: pd2ppc lookup table

# **Estimation**

We want to estimate the values of voltage magnitudes and relative angles of each bus in the grid from the given measurements. If the grid has 'n' buses of which there are 'k' slack buses, at least '2n-k' measurements are needed theoretically for the estimation to converge, but practically '4n' measurements is often considered reasonable (Reference:

https://pandapower.readthedocs.io/en/v2.0.1/estimation.html).

The pandapower library has a module called estimation which has several estimators such as:

- Weighted least squares estimator (WLS):
  - Minimising the squared error of residues (difference between actual measurement and estimated measurement from a measurement function) weighted by measurement error covariance matrix.
- Least Absolute value estimator (LAV):
   Minimising the absolute error of residues.
- Schweppe Huber Generalised Maximum likelihood estimator (SHGM):
   This estimator combines both WLS and LAV estimators. It uses LAV for outlier points because squared norm contributes large values to the loss function in case of outliers.

We chose to do WLS estimation to compare the results with the Kalman Filter estimation and to visualize the error distribution.

# Kalman Filter Formulation

Kalman Filter (KF) is a linear state estimator which combines measurements from the actual system and prediction from the model of the system to find the optimal estimate of the states. Extended

Kalman Filter (EKF) is the extension of KF to the nonlinear case. A detailed review of these are provided at the appendix of the document.

Since the power flow equations are nonlinear, we use EKF to estimate the states. In the Iterated Extended Kalman Filter (IEKF) approach, we are repeating the update/correction step until the difference between the old and new states after update is less than a given threshold.

The state vector ' $\mathbf{x}$ ' is the voltage magnitudes and phase angles of each bus.

$$\mathbf{x} = [\theta_1 ... \theta_N, V_1 ... V_N]^T$$

Measurements 'z'

$$z = [P_{hus}, P_{line}, Q_{hus}, Q_{line}, V_{slackbus}]^T$$

Power flow equations:

$$g_P = P_i - V_i \sum_{j=1}^{N} V_j [G_{ij} cos\theta_{ij} + B_{ij} sin\theta_{ij}] = 0$$

$$g_Q = Q_i - V_i \sum_{j=1}^{N} V_j [G_{ij} sin\theta_{ij} - B_{ij} cos\theta_{ij}] = 0$$

Prediction step of EKF:

$$x_{k}^{-} = x_{k-1}^{+}$$
 $P_{k}^{-} = P_{k-1}^{+} + Q$ 

Correction step of EKF:

$$K_{k} = P_{k}^{-} H_{k}^{T} (H_{k} P_{k}^{-} H_{k}^{T} + R)^{-1}$$

$$x_{k}^{+} = x_{k}^{-} + K_{k} (z_{k} - h_{k})$$

$$P_{k}^{+} = (I - K_{k} H_{k}) P_{k}^{-} (I - K_{k} H_{k})^{T} + K_{k} R K_{k}^{T}$$

Where

Pk is the state error covariance matrix at time step 'k'

Q is process noise caused due to linearization errors

K is the Kalman gain

R is the measurement error covariance matrix

H is the Jacobian matrix of the measurement function 'h'

z is measurement vector

h is the measurement estimations

# Discussion

In the reference paper "Power system state estimation based on Iterative Extended Kalman Filtering and bad data detection using normalized residual test" (and in some other papers as well), the authors propose to use the prediction step as

$$x_k^- = x_{k-1}^+ + J_k^{-1}[u_k - u_{k-1}] + J_k^{-1}e$$

Where 'u' is the power injections (input),  $u = [P_{bus}, Q_{bus}] = [P_1...P_N, Q_1...Q_N]^T$ 

and 'J' is the jacobian of power flow equations with respect to states.

$$J = \begin{bmatrix} \frac{\partial g_{P}}{\partial \theta} & \frac{\partial g_{P}}{\partial V} \\ \frac{\partial g_{Q}}{\partial \theta} & \frac{\partial g_{Q}}{\partial V} \end{bmatrix}$$

And  $J_k^{-1}e$  as the process noise.

But we did not get a good estimation when we used this approach. It also tends to have some numerical issues due to the inverting of sparse jacobian matrix.

Reference: https://ieeexplore.ieee.org/abstract/document/7064881




Figure 4: Estimation with Jacobian inverse




Figure 3: Relative error with Jacobian inverse

Then we decided to use the previous state as the next predicted state (identity matrix as the state transition matrix).

$$x_{k}^{-} = x_{k-1}^{+}$$

The results got improved considerably by following this approach for the update step. We think the problem with the previous method is that we are essentially using a subset of the measurement as the input and we therefore basically end up using part of measurement twice in the model.




Figure 5: Estimation without Jacobian inverse

To get a general idea of the relative error distribution for IEKF compared to the WLS estimation, we ran the estimation for several times. Each time the measurement will be different even though they are from the same profile because of the random noise added on top of actual values.




Figure 6: Error distribution for 50 runs




Figure 7: Error distribution for 10 runs

In the error distribution for just 10 runs, there are some peaks at higher error for IEKF (around 1.5% and 3 %) even though in general IEKF performs better than WLS (as seen from distribution for 50 runs). These peaks are due to the higher initial errors for IEKF in every run. This can be seen from the figures below. After some timesteps, the error covariance of the filter decreases and becomes adapted to the model.




Figure 9: voltage magnitude estimation

Figure 8: voltage angle estimation

It was observed that with large grids (for e.g., with 150 bus), sometimes the inversion of the matrix  $\left(H_k P_k^- H_k^T + R\right)^{-1}$  leads to matrix inversion error if the state change of EKF does not converge to the given threshold within a small number of update steps (on average it converges below 10 update steps).

While debugging the inversion error, we found that the entries in the matrix are increasing after a particular update step and the values later starts to explode. The estimation error covariance matrix,  $P_k$  is increasing uncharacteristically which eventually leads to the inversion error. So, it means that we can check for the value of  $P_k$  and find out whether there is a chance of matrix inversion problem soon in this time step if we continue to execute the update step. We can then stop the update step for this timestep without the matrix inversion happening. But due to the uncharacteristic increase in the value of  $P_k$ , the state vector will be already corrupted and can't be used for that timestep.

Also, if we proceed to the next time step, it will again cause the inversion problem because our model is already corrupted (because we found out about possible inversion error from the corrupted values in  $P_k$ ). One solution to this problem is to have a copy of the estimation object which is updated every timestep. We copy the current object before doing the prediction and update steps. If we find out that an inversion error is about to happen, we resort to some other means to find the state for that particular timestep (like a WLS estimation) and discard the corrupted object. For the next timestep we use the previous copy of the estimation object so that we don't run into inversion problem in the subsequent steps.

The trace of  $P_k$  for a normal run and for an error run is shown below:

```
Timestep: 25
Update step: 1.0, 0.003979568911779835
Update step: 2.0, 0.003977380255462606
Update step: 3.0, 0.003976417195866888
Update step: 4.0, 0.0039772047618974425
Update step: 5.0, 0.003977803561421578
Update step: 6.0, 0.003976979488657795
Update step: 7.0, 0.003978626713782375
Update step: 8.0, 0.003977222453303864
Update step: 9.0, 0.003976819538548271
Update step: 10.0, 0.003975200180241416
Update step: 47.0, 0.003976903910380287
Update step: 48.0, 0.0039767862369320395
Update step: 49.0, 0.003993587101194223
Update step: 50.0, 1.0746473519318798
Update step: 51.0, 64.63336454275625
Update step: 52.0, 14552.514726000541
Update step: 53.0, 42795.412365441385
Update step: 54.0, 6.173591732585055e+42
Update step: 55.0, 1.060484676549918e+93
Update step: 56.0, 2.9462984603917425e+173
```

Figure 11: Trace of Pk for error step

```
Timestep: 26
Update step: 1.0, 0.003984399537847206
Update step: 2.0, 0.0039818263109127425
Timestep: 27
Update step: 1.0, 0.003986929055822201
Update step: 2.0, 0.003985852887162666
Update step: 3.0, 0.00398549608052525
Update step: 4.0, 0.00398528986283079
Update step: 5.0, 0.003985155402591923
Timestep: 28
Update step: 1.0, 0.003991456094700998
Update step: 2.0, 0.003989336025882974
Timestep: 29
Update step: 1.0, 0.003996468596701499
Update step: 2.0, 0.003993402729483002
Update step: 3.0, 0.003993105915020942
Update step: 4.0, 0.003992940745121266
Update step: 5.0, 0.003992840421867042
Update step: 6.0, 0.003992753937843914
Timestep: 30
Update step: 1.0, 0.003998341189200915
Update step: 2.0, 0.003996795333773748
Update step: 3.0, 0.003996631617780348
```

Figure 10: Trace of Pk for normal steps

We can see that after 50 update steps, the matrix starts to explode.

From the above figures, we see that for normal runs, the trace of  $P_k$  continuously decrease with each update steps in a timestep. In the error timestep of 25, we can see that the trace of  $P_k$  increases in the 4<sup>th</sup> update step and then onwards it kind of oscillates without a general trend until collapsing.

So, we could also stop after the 4<sup>th</sup> timestep without considerably corrupting the estimation object.

We are analysing the filter for a possible reason for the increase in the variance of  $P_k$ . We looked at the measurement jacobian matrix H but could not find anything unusual happening to it.

In the present implementation, in case of this singularity error, a WLS estimation is done only for that timestep and revert to EKF from the next timestep onwards. Another possible way is to limit the maximum number of update steps in a timestep so that singularity does not arise.

# **Implementation**

The various functions and their descriptions are given below:

We used PyCharm for debugging the code.

### • find\_state\_and\_measurements():

Runs the powerflow to find the real states, bus and line power measurements

# make\_meas():

Create a single measurement in the pandapower network

#### create\_measurements():

To create the required number and type of measurements in the network

#### • getBusInfo():

Returns different bus numbers and slack bus index

#### createResultMask():

Creates a mask to avoid unwanted buses in the final results

#### storingArraysInit():

Initialise arrays to store the states for visualizing

#### runWLS():

Runs the Weighted least squares estimation

#### saveArrays():

To save the array of states locally for further testing if any

# plotError():

Plots the error distribution of WLS and EKF estimates

#### plotStates():

Plotting the estimated and real values of a particular state variable to see the error per timesteps

- estimate\_EKF():
   Estimate the states with iterated Extended Kalman Filter
- runSimulations():
  Run the estimation of states according the given profile for the given number of times

# **Appendix**

A detailed review of Kalman Filter algorithm and context is given in the following figures:




Figure 12: Kalman Filter fig. 1




Figure 13: Kalman Filter fig. 2




Figure 14: Kalman Filter fig. 3

```
Let man gain, K_{k} = P_{k}C^{T}(CP_{k}C^{T}+R) applied only A_{k} = A_{k} + K_{k}(y_{k} - CA_{k})

But all explore a man A_{k} = A_{k} + K_{k}(y_{k} - CA_{k}) + K_{k}RK_{k}

Lineary a man A_{k} = A_{k} + C(I - K_{k}C)P_{k}

Nok:

Nok:
```

Kalman filler is a linear filler that can be applied only to linear syntem.
But all uniteres are althoughty mon-linear
Linenje a non-linea system
Taylor series experien of a non-lisear friting around a morninal point to
f(n) = f(\(\bar{\pi}\) + f'(\(\bar{\pi}\) \(\delta\) + f''(\(\bar{\pi}\)) \(\delta\) + f''(\bar{\pi}\) + f''(\\\\\\\\\\\\\\\\\\\\\\\\\\\\\\\\\\\
Where an = n+n
$\ell_{\xi}$ : $\omega_{\xi}(n)$ around $\overline{n}=0$
$Cos(\pi) = Cos(0) - sin(0)(\pi - 0) - cos(0)(\pi - 0)^{2}$
$ > \omega_1(x) = 1 - x^2 + \dots $
2nd order taylor sene expansion = 1 2nd order taylor sene expansion = 1-76

Figure 15: Kalman Filter fig. 4

If difference blow is and in is small,
taglir series approximation give a good entimate
Linearizing a function > expanding to future in 1st order taylor sense expansion count .
Lineanyed Kalman Filk
-> start with a non-likear syptem  -> find a linear syptem whose states represent  deviations from normal trajecting of the
non-linear hystem.  The Kalman Filter to estimate the deviation  from normal trajectory of states
-> Indirectly given in the estimation of states
ACREA COMPANIE DE LA

General non-tirear system model
Stake egn: Mutt = f(Mu, Mu) + w u  olpegn: yu = h(Mu) + v u
olpegn; yh = h(xh) + lek
f(.) > Stake equalism
h(.) -) manuferent egration.
I any of there has a non-linear term  -> system non-linear.
liverige stak eguchen & output equetion
Ground worminal state (It is a further of
howinal state of the day as a second what he
Morninal state - based on gnem of what he system behaviour night book like
9: lif 190th epichen represent olynamia
of cirpline, nominal state = planned flight
but actual longertong will be different, but
if the difference is small > Taylor series expension is reasonably atterate

Figure 16: Kalman Filter fig. 5

```
, affer extinating one, we need to add the
 = f(πω, μω)+f'(πω, μω) Δηω+ ων ω

γω = h(πω) + υω

~ h(πω) + h'(πω) Δηω + υω.
                                                     estimate smy to nominal state in to get
                                                     for estimate of state.
                                                   -> If tow state x get too for fam normal
                                                      state in the liverged kalman Filh will
 Devichum from normal torjectory can be
                                                      not give good result.
  WAIHER as:
    AM K+1 = 7 K+1 - 7 K+1
                                                    > synta egos: nk+1 = f(nk, nk)+wk
            = 2k+1 - f(mu, nu)
                                                                      yk = h(Mh)+ Wh
   \Delta y_{k} = y_{k} + \overline{y}_{k}
= y_{k} - h(\overline{x}_{k})
                                                   -> nominal towjectory is known about of time
                                                            1/2 = f (x, nu)
Combining both let of earl >
                                                             y = h(m)
                                                   -> At each time step, calculate partial derivative matrices evaluated at morninal state (with the
    1 mk+1 = f'( nk, nk) Ank + wk
    ay = h'(xk) Axx + uk
                                                           Au = { (mu, mu)
-> linear model -> Apply kalman Filter
                                                            Ck - h'(Th)
                     entimate onk
```

Figure 17: Kalman Filter fig. 6




Figure 18: Kalman Filter fig. 7