EPF Challan

PC / IN / 2026 /10280

STRUCTURAL STABILITY CERTIFICATE

SITE NAME	:	Thanthai Periyar Nagar 1
INDUS ID	:	IN-3640920
SITE ADDRESS	:	NO:13,Sixth cross street,thhanthai periyar nagar, Ellapillaichandy,Puducherry - 605005
BUILDING HEIGHT	:	10.10m (G+2)
BUILDING AGE	:	7 years
TOWER HEIGHT	:	15m 3L RITA TOWER
LOCATION OF THE TOWER	:	Third Floor Open Terrace WITH 3.3m column raising
LOCATION OF THE BTS EQUIPMENT	:	Third Floor Open Terrace

NOT OFFICIAL

We hereby certify that the above mentioned site location with **10.10m(G+2)** height will be Proposed to **1.36 tonne** weight of the **15m 3L RITA TOWER** with **3.3m column raising** and **2.0 tonne** weight of the BTS equipment's to be placed at **Third Floor Open Terrace.**

Building physical condition ok.

Building NDT ok.

SAMPLE — NOT OFFICIAL

This certificate will not hold good in case of natural calamities like fire, flood, earthquake etc. The applicant is advised to do periodical maintenance of the building.

Place : Coimbatore

Date : 01-10-2026

J. SENTHIL KUMAR,
Registered Engineer Grade - 1 No-057/2021
Chartered Engineer., AM1714832
Pinnacle Consultants
Coimbatore

NEXUS
COMMERCIAL MANAGER
27/10/2026
CHENNAI - 600002

NEXUS
COMMERCIAL MANAGER
27/10/2026
CHENNAI - 600002